



C.B.R. SUB-GRADE (%)	BELOW 2	2	3	4 OR MORE
SUB BASE (NO CAPPING LAYER)				
SUB-BASE THICKNESS (mm)	625	475	350	300
SUB BASE + CAPPING LAYER COMPRISING				
SUB-BASE THICKNESS (mm)	150	150		
CAPPING LAYER THICKNESS (mm)	600	350		

- NOTES:
- DO NOT SCALE. USE FIGURED DIMENSIONS ONLY.
 - THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL OTHER RELEVANT ARCHITECTURAL AND ENGINEERING DRAWINGS.

ROAD CONSTRUCTION:
 30mm CLOSED GRADED ASPHALT CONCRETE SURFACE TO CLAUSE 912 ON
 30mm ASPHALT CONCRETE BINDER SURFACE TO CLAUSE 906 ON
 75mm ASPHALT CONCRETE BASE TO CLAUSE 906 ON
 300mm TO 625mm SUB-BASE - CLAUSE 808 GRANULAR MATERIAL
 NOTE: THE DEPTH OF THIS SUB-BASE IS DEPENDENT UPON THE CBR OF THE FORMATION. SEE TABLE 1.



ROAD CONSTRUCTION:
 30mm CLOSED GRADED ASPHALT CONCRETE SURFACE TO CLAUSE 912 ON
 30mm ASPHALT CONCRETE BINDER SURFACE TO CLAUSE 906 ON
 75mm ASPHALT CONCRETE BASE TO CLAUSE 906 ON
 300mm TO 625mm SUB-BASE - CLAUSE 808 GRANULAR MATERIAL
 NOTE: THE DEPTH OF THIS SUB-BASE IS DEPENDENT UPON THE CBR OF THE FORMATION. SEE TABLE 1.



LEGEND:

- INDICATES EXISTING ROAD
- INDICATES PROPOSED FOOTPATH
- INDICATES PROPOSED ROAD WIDENING
- INDICATES EXTENTS OF ROAD WIDENING

REV.	DATE	AMENDMENT	DRN	APPD

STATUS: **FOR PLANNING ONLY**
NOT FOR CONSTRUCTION

Waterman Moylan
 Engineering Consultants
 BLOCK 5, EASTPOINT BUSINESS PARK, ALFIE BYRNE ROAD,
 DUBLIN D03 H3F4 IRELAND. Tel: (01) 664 8900
 Email: info@waterman-moylan.ie www.waterman-moylan.ie

CLIENT: TRAILFORD LTD
 ARCHITECT: NDBA ARCHITECTS
 PROJECT: **PROPOSED RESIDENTIAL DEVELOPMENT, RATHMULLAN, DROGHEDA**
 TITLE: **PROPOSED ROAD UPGRADE WORKS**

DRAWN G.Byrne	DESIGNED BW	APPROVED JG	DATE AUG. '19
SCALE AS SHOWN @A1	JOB NO. 18-014	DRG. NO. P012	REVISION

PLAN VIEW
 SCALE 1:750