





GREEN ROOF SCHEMATIC
SCALE: NTS




TYPICAL SECTION THROUGH GREEN ROOF
SCALE: 1:25




ROAD GULLY DETAILS SECTION



GULLY WITH CONNECTION ON OPPOSITE SIDE OF ROAD




GULLY WITH ADJACENT CONNECTION



TYPICAL ROAD GULLY TO TREE PIT DETAIL
SCALE: 1:25

ROAD GULLY DETAILS
SCALE: 1:25



GRADED MANHOLE INLET CHAMBER - CROSS-SECTION
SCALE: N.T.S.

- GENERAL NOTES:
- ALL SURFACE WATER MANHOLES AND DRAINAGE ARE TO BE CONSTRUCTED IN ACCORDANCE WITH THE REQUIREMENTS OF THE GREATER DUBLIN CODE OF PRACTICE FOR DRAINAGE WORKS.
 - ALL FOUL DRAINAGE WORKS TO BE IN ACCORDANCE WITH IRISH WATERS' CODE OF PRACTICE FOR WASTEWATER SUPPLY AND WASTEWATER INFRASTRUCTURE STANDARD DETAILS.
 - SURFACES FINISHES FOR CONCRETE:
 - CLASS F1 FOR ALL CONCRETE 100mm OR MORE BELOW GROUND LEVEL.
 - CLASS F3 FOR ALL EXPOSED CONCRETE ABOVE 100mm BELOW GROUND LEVEL.
 - ALL EXPOSED CORNERS ON CONCRETE SHALL BE CHAMFERED WITH 25mm x 25mm CHAMFERS.
 - ALL STRUCTURAL CONCRETE (HEADWALLS, RC MANHOLES, PETROL INTERCEPTOR SLABS) TO RECEIVE MC DUR 1680 (OR SIMILAR APPROVED TAR MODIFIED EPOXY RESIN) TO ALL BURIED SURFACES. TO FINISH 100mm BELOW GROUND LEVEL.
 - ALL SEWERS SHALL BE PRESSURE TESTED PRIOR TO BACKFILLING.
 - TYPE 1 GRANULAR MATERIAL - BROKEN STONE OR GRAVEL TO PASS 10mm SIEVE AND BE RETAINED ON 5mm SIEVE. TYPE 2 GRANULAR MATERIAL - BROKEN STONE OR GRAVEL TO PASS 10mm - 25mm SIEVE, ACCORDING TO PIPE SIZE, (SEE TABLE) AND BE RETAINED ON 5mm SIEVE.
 - TYPE 3 SELECTED FILL - UNIFORM READY COMPACTED MATERIAL FREE FROM TREE ROOTS, VEGETABLE MATTER, BUILDING DEBRIS, AND FROZEN SOIL AND EXCLUDING CLAY LUMPS RETAINED ON A 75mm SIEVE AND STONES RETAINED ON A 37.5mm SIEVE.
 - ALL LADDERS, RUNGS, SAFETY CHAINS etc SHALL BE HOT DIPPED GALVANISED TO BS 729 OR EQUIVALENT.

P01	04-11-19	ISSUED FOR PLANNING	JJB	BK
rev	date	description	by	chkd.
		A - Approved		
		B - Approved with comments		
		C - Do not use		

suitability	issue purpose
S2 - INFORMATION	PLANNING



DUBLIN OFFICE Ormond House, Upper Ormond Quay, Dublin 7, Ireland
PHONE +353 1 400 4000
WATERFORD OFFICE Unit 2, The Chandlery, 1-2 O'Connell Street, Waterford, Ireland
PHONE +353 51 309 500

project ref.

**RESIDENTIAL DEVELOPMENT
SCHOLARSTOWN**

drawing title
TYPICAL DRAINAGE DETAILS SHEET
3

architect
JOHN FLEMING ARCHITECTS

designed by	author	scale	sheet size
BK	JJB	AS NOTED	A1
drawing no.	revision		
SCH-DBF-ZZ-XX-DR-C-3112	P01		