



GENERAL NOTES

1. ALL DIMENSIONS ARE GIVEN IN MILLIMETERS UNLESS OTHERWISE INDICATED.
2. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH THE SCOPE OF WORKS. ANY DISCREPANCIES ARE TO BE BROUGHT TO THE ATTENTION OF KELLIHERS FOR CLARIFICATION PRIOR TO ANY WORK COMMENCING.
3. CONTRACTOR TO FIELD VERIFY ALL DIMENSIONS, DISCREPANCIES ARE TO BE NOTIFIED TO THE CONTRACTOR AND DESIGN FOR RESOLUTION.
4. ALL WORKS TO COMPLY WITH PREVIOUSLY AGREED AND ISSUED SPECIFICATIONS

LEGEND

- Estate North
Results – Horizontal Illuminance (lux)
E_{av} = 6.17
E_{min} = 1.21
E_{max} = 20.19
E_{min}/E_{max} = 0.06
E_{min}/E_{av} = 0.20
- Estate South
Results – Horizontal Illuminance (lux)
E_{av} = 7.167
E_{min} = 20.39
E_{max} = 0.08
E_{min}/E_{av} = 0.23
- Estate Entrance – conflict zone
Results – Horizontal Illuminance (lux)
E_{av} = 10.02
E_{min} = 4.11
E_{max} = 18.87
E_{min}/E_{av} = 0.22
- Luminaire Data
Luminaire A XSPME – B – Type 2SH – DY1 4K
Lamp 3MD-SA1400 M DY1 4K MF 0.76
Luminaire B XSPME – B – Type 4ME – DY1 4K
Lamp 3MD-SA1400 M DY1 4K MF 0.76
Luminaire C XSPME – B – Type 3SH – DY3 4K
Lamp 3MD-SA1400 M DY3 4K MF 0.76
- Key
- Luminaire A Column
 - Luminaire B Column
 - Luminaire C Column
 - Beam Aiming Target
 - Photometric Centre
- All Dimensions in metres

NO.	REVISION	DATE	BY	CHKD	APP'D
1	ISSUED FOR CONSTRUCTION	DMD DC DC 23SEP19			
2	REVISED FOR CONSTRUCTION	DMD PS PS 11MAR19			

PROJECT: CAPDOO & ABBEYLANDS CLANE CO. KILDARE LIGHTING LAYOUT CREE XSPME LED		KELLIHERS ELECTRICAL LTD. 145B BUSINESS PARK, DUBLIN 12	
DESIGNED BY	DATE	PROJECT NO.	SCALE
DMD	11/04/2019	KE/KCC/04	1/1750/20A0
CHECKED BY	DATE	PROJECT NO.	SCALE
PS	11/04/2019	KE/KCC/04	1/1750/20A0