



THIS DRAWING IS COPYRIGHT © ALL RIGHTS RESERVED. NO PART OF THIS DRAWING MAY BE REPRODUCED, STORED IN A RETRIEVAL SYSTEM OR TRANSMITTED IN ANY FORM OR BY ANY MEANS WITHOUT THE PRIOR WRITTEN PERMISSION FROM MCELLIGOTT CONSULTING ENGINEERS LIMITED.

NOTES

01. DO NOT SCALE. USE FIGURED DIMENSIONS ONLY.
02. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL OTHER RELEVANT ARCHITECTURAL AND ENGINEERING DRAWINGS.
03. FINAL LOCATION OF MINIPILLARS & DUCTS TO BE AGREED WITH ESB SUPERVISOR PRIOR TO INSTALLATION.
04. PROVIDE FOR ESB METER CABINET, INTERNAL METER & BRACKETS, SURGE PROTECTION & CABLE TO PUMPING STATION CONTROL & CABLE TO PUMPING STATION CONTROL PANEL.
05. REFER TO ESB PUBLICATION ELECTRICAL SERVICES GUIDE BOOK FOR HOUSING SCHEMES FOR ALL INSTALLATION DETAILS.
06. THIS DRAWING SHOULD BE READ IN CONJUNCTION WITH THE NATIONAL CODE OF PRACTICE FOR CUSTOMER INTERFACE ISSUED BY ESB.
07. THIS PROPOSAL IS SUBJECT TO APPROVAL FROM THE LOCAL AUTHORITY & PLANNING PERMISSION.
08. ALL PUBLIC LIGHTING COLUMNS MUST BE A MINIMUM OF 800mm AWAY FROM THE KERB EDGE.
09. ALL PUBLIC LIGHTING COLUMNS TO BE A MINIMUM OF 7M AWAY FROM ANY TREES.
10. WHERE ACCESS TO LIGHTING COLUMNS IS OBSTRUCTED BY PATHWAYS ETC A RAISE & LOWER TYPE COLUMN SHOULD BE USED.
11. THIS DESIGN HAS NOT INCORPORATED THE USE OF A BAT SURVEY AND THEREFORE CANNOT COMPLY WITH THE RECOMMENDED GUIDELINES FOR BAT CONSERVATION.
12. THIS DESIGN IS COMPLETED WITHOUT THE USE OF A "TAKEN IN CHARGE" DRAWING.

LEGEND

- **COLUMN DETAILS:**
 HEIGHT :.6m
 BRACKET LENGTH :POST-TOP
 INCLINATION :.5.INCLINATION
 COLUMN QUANTITY :
LANTERN DETAILS:
 LANTERN TYPE :.15W LED
 MAKE & MODEL :.CU-PHOSCO-P852-12-R2B-NW-CB0350-15W
- **COLUMN DETAILS:**
 HEIGHT :.6m
 BRACKET LENGTH :POST-TOP
 INCLINATION :.5.INCLINATION
 COLUMN QUANTITY :
LANTERN DETAILS:
 LANTERN TYPE :.10W LED
 MAKE & MODEL :.CU-PHOSCO-P852-6-R3B-NW-F0600-12W
- **COLUMN DETAILS:**
 HEIGHT :.6m
 BRACKET LENGTH :POST-TOP
 INCLINATION :.5.INCLINATION
 COLUMN QUANTITY :
LANTERN DETAILS:
 LANTERN TYPE :.17W LED
 MAKE & MODEL :.CU-PHOSCO-P852-12-F2-CB0400-17W
- **COLUMN DETAILS:**
 HEIGHT :.6m
 BRACKET LENGTH :POST-TOP
 INCLINATION :.5.INCLINATION
 COLUMN QUANTITY :
LANTERN DETAILS:
 LANTERN TYPE :.17W LED
 MAKE & MODEL :.CU-PHOSCO-P852-12-P4-NW-CB0400-17W

ISSUE	DESCRIPTION	DRN	ORIG	APP	DATE
D	FOR PLANNING	RT	TMC	TMC	15/10/2019
C	FOR PLANNING	RT	TMC	TMC	05/07/2019
B	FOR INFORMATION (DRAFT)	RT	TMC	TMC	23/05/2019
A	FOR INFORMATION (DRAFT)	RT	TMC	TMC	16/05/2019

McElligott

CONSULTING ENGINEERS
 H2a Centrepoint Business Park, Oak Road, Dublin 12
 tel: +353 (0)1 424 3014 email: info@mcelligott.ie web: www.mcelligott.ie

CLIENT **COSGRAVE DEVELOPMENTS**

PROJECT **BLACKWOOD SQ, NORTHWOOD, SANTRY DEMENSE**

TITLE **PUBLIC LIGHTING LAYOUT SHD**

SHEET	SCALE	PROJECT No.	DRAWING No.
A1	1:500	19019	E005