


NOTES:

- LIGHTING TO BE CONTROLLED BY A COMBINATION OF TIMER SWITCHES AND PHOTOCELLS. THE PHOTOCELLS TO BE MOUNTED ON THE TOP OF EACH LUMINAIRE AND THE TIMER SWITCHES INSTALLED IN THE MINI PILLARS.
- LIGHTING TO BE SWITCHED OFF DURING NON-OPERATIONAL HOURS IN ACCORDANCE WITH PLANNING CONDITIONS AND THAT THE LIGHTING TO ONLY BE TRIGGERED BY SECURITY PERSONAL IN THE CASE OF TRESPASSERS ONTO THE SITE.
- THE COLOUR TEMPERATURE OF THE LIGHT TO BE 2700K OR LESS.
- THE LIGHTING CLASS ALONG THE PATHWAY TO BE IN ACCORDANCE WITH P5 CLASS.
- EXISTING LIGHTS TO BE UNINSTALLED, STORED AND REINSTATED AFTER COMPLETION OF CIVIL WORKS, WHERE REQUIRED.
- EXISTING ASTRO-TURF PITCH POLE MOUNTED FLOODLIGHTS TO BE RELOCATED TO NEW LOCATION AS INDICATED.

KEY

- PROPOSED MINI PILLARS
- EXISTING MINI PILLARS
- PROPOSED LED LANTERN C/W PHOTOCELL MOUNTED ON 6m HIGH COLUMN
- EXISTING CCTV
- RECESSED IN-GROUND PATHWAY LIGHT
- WALL WASHING LIGHT
- POLE MOUNTED FLOODLIGHTS AT ASTRO-TURF PITCH



Nicholas de Jong Associates
URBAN DESIGN

PL1	19/12/19	JT	KC	VA
Issue	Date	By	Chkd	Appd



Job Title
KING'S ISLAND
FLOOD RELIEF SCHEME

Scale at A1 1:500

Discipline
Infrastructure



Arup, 50 Ringsend Road
Dublin, D04 T6X0
Tel +353(0)1 233 4455 Fax +353(0)1 668 3169
www.arup.ie

Drawing Title
KIFRS Public Lighting Layout
Sheet 10 of 10
Areas B3

Job No KIFRS	Drawing Status Planning
Drawing No KIFRS-E-309	Issue PL1