


Web:

www.scottishpowerrenewables.com

EXISTING CARRIAGEWAY MATERIAL TO BE TESTED AT 25M INTERVALS TO CONFIRM CBR VALUES AND SUITABILITY FOR BEARING

EXISTING CARRIAGEWAYS FORMED ON PEAT ARE DEEMED NOT TO BE SUITABLE FOR BEARING, REQUIRES FULL DEPTH OF NEW FLOATING ROAD.



THIS DRAWING IS FOR PLANNING PURPOSES ONLY. IT IS <u>NOT</u> TO BE USED AS A CONSTRUCTION DRAWING.

ACCESS TRACKS DETAILS	Issue Details				Office Use Only	
	Designed:	JOD	Information		Drawing Number: 5952-400-401	
	Drawn:	A.McC	Approval	Х		
	Checked:	S.M	Tender			
	Approved:	DK	Construction		Date: Rev.	Rev.
	Scale: As Noted		Record		19/10/19	