

PERMANENT REINSTATEMENT WEARING COURSE TO MATCH EXISTING. TO BE FINISHED TO TII (TRANSPORT INFRASTRUCTURE IRELAND) SPECIFICATION/REQUIREMENT.		
		GROUND LEVEL
4 4 •	BASE COURSE	
BASE COURSE YELLOW MARKER WARNING TAPE. MUST BE FULL WIDTH OF TRENCH ESBN APPROVED MATERIAL ONLY EXISTING ROAD BUILD-UP TO BE CONFIRMED BY MEATH Co. COUNCIL AND TII BACKFILL IN LAYERS OF 150mm TO AVOID RESIDUAL CONSOLIDATION AND TO IMPROVE THERMAL PROPERTIES 15N/mm ² CBM4 LEAN-MIX CONCRETE 400mm RED CABLE PROTECTION STRIP, ESBN APPROVED MATERIAL ONLY. 1 No. 110mm OUTER DIAMETER HDPE COMMS DUCTS. ESBN APPROVED MATERIAL ONLY. COMMS DUCT TO BE PLACED TO THE SIDE OF TRENCH CLOSEST TO THE ROAD CENTRE. DUCTS LAID IN CBM4 (CL 1039), FULL TESTS REQUIRED. COMPACTED TO CL. 1035 OF TII SPECIFICATION FOR ROADWORKS (15N/mm ² AFTER 7 DAYS) 3 No. 110mm OUTER DIAMETER HDPE DUCTS. ESBN APPROVED MATERIAL ONLY 12mm DIA. PULL ROPE IN ALL DUCTS		
ISSUE/REVISION		
P02	18.12.19	Issued For Information
P01	05.12.19	Issued For Information
I/R	DATE	DESCRIPTION