



NOTES:
 All dimensions in metres.
 Do not scale from drawing.
 For any discrepancies found please consult with design office.
 This drawing should be read in conjunction with all contract drawings, documents and specifications.

Legend:

- ESB Underground Cable
- - - ESB Existing Overhead Cable
- - - ESB Existing Overhead Cable to be Removed
- ESB Mast

Existing Overhead Cable

Proposed End Mast Type 54D (12m) or similar approved by ESB

Proposed Underground Cable Route under stream see LHD ESD P04

Detail B

Proposed End Mast Type 54D (12m) or similar approved by ESB

Existing Overhead Cable To be Removed

Proposed End Mast Type 54D (12m) or similar approved by ESB

Detail A

Existing Overhead Cable

1:5000 @ A3

Rev/By	Date	Description

Drawing Status: PLANNING
NOT CERTIFIED FOR CONSTRUCTION

Project Title: Longview Estates Development

Drawing Title: Proposed ESB 38kV Diversion

Client: Longview Estate Ltd

M.H.L. & Associates Ltd.
 Consulting Engineers

Carrig Mór House,
 10 High Street,
 Douglas Road,
 Cork

Tel: 021-4840214
 Fax: 021-4840215
 E-Mail: info@mhli.ie

Designed: SM	Drawn: SFM	Checked: KM
Scale: As Shown	Date: Nov 2019	
Job No: 17066HD	Drawing No: LHD_ESBD_P01	Revision: