



Full Retention Class 1
CP3FR, FIA Filter, Volume 2,200 lit
Scale 1:25

Notes :

- All drawings are to be read in conjunction with all relevant Specifications, Bills of Quantities, Architectural, Services and Engineering Drawings.
- Any discrepancies between these documents shall be brought to the attention of the Engineer.
- All dimensions are in millimetres, unless noted otherwise.
- All levels are in metres related to Ordnance Datum.
- Drawings are not to be scaled.

NOTE:
Details as per Carlow Concrete Tanks, or similar approved.
Tanks are to be installed and backfilled to manufacturer's requirements.
Concrete lid and tank structure to be designed to suit loading conditions and approved prior to installation.

Rev.	Date	Description	JK	CM	HBR
A	03.07.2020	Issued For Planning			

Project: Carrowagowan Wind Farm

Title: Substation Compound Full Retention Class 1 Interceptor Details

Client:

Malachy Walsh and Partners
Consulting Engineers
Cork | Tralee | London | Limerick

Reen Point, Blennerville, Tralee, Co. Kerry
Tel: +353 (0)66 7123404
fax: +353 (0)66 7126586
E-mail: tralee@mwp.ie

Drawn	As Shown	18.11.2019	Drg. No.	Rev.
Ch'd (DO)	JK	18.11.2019	19107-5055	A
Ch'd (Eng)	CM	18.11.2019		
Approved	Jol	18.11.2019		