



Drumlins Park Wind Farm Cable Permitted Under Monaghan County Council Planning Ref. 19/486 (Connecting To Proposed 110kV substation)

Legend:

Ownership Boundary	—
Proposed Development Boundary	—
Permitted Drumlins Park Wind Farm	—
Area of Fill	■
Area of Cut	■
Substation Access Track	▨
Substation Buildings & Footpath	▨
150mm thick top layer of permeable compound stone consisting of 60mm single sized crushed Limestone	▨
Concrete Equipment Plinths	⊗
Proposed 110kV Underground Cable Connecting 110kV Substation to Existing Lisdrum-Shankill 110kV Overhead Line	—
Existing Lisdrum-Shankill 110kV Overhead Line	—
Battery Container	▭
2.95m High Palisade Fence	—
Concrete Post & Rail Fence	—
Post & Wire Stockproof Fence	—
100mm Ø uPVC Foul Water Pipe	—
150mm Ø uPVC Storm Water Pipe	—
Foul Water AJ	⊡
Storm Water AJ	⊡
Sheough Existing	—
Sheough to be Diverted	—
Concrete Headwall	▭
Proposed Sheough	—
Ø900mm Twin Wall Pipe to NRA Specification	—
Ø150mm Perforated Land Drain Wrapped in Non-Woven Geotextile Layer	—
Inspection Chamber	⊗
Spoil Deposition Area	▨
Existing Spot Heights	⊕
Proposed Levels	⊕
Site Notice	×

NOTES:

- All dimensions in millimetres unless otherwise stated
- All levels are in metres unless otherwise stated

Date:	Rev:	Description:	Drawn By:

Prepared By:

Galetech Energy Services
Clondorgan, Stradone
Co. Cavan, H12 NV06
info@galetechenergy.com
www.galetechenergy.com

Client: **Drumlins Park Ltd.**

Job Title: **Drumlins Park Wind Farm Substation & Grid Connection**

Drawing Title: **Figure 5: Site Layout Plan 1 of 6 (1:500)**

Drawing No. DRU001SS_PAG_LAY-0.01	Revision No. Rev00
Scale: (A1) 1:500	Date: 03/12/2020
Drawn By: J.B.	Checked By: C.M.P.
	Confirmed By: S.C.

OSI © Licence: EN 0062820 - Prepared Using Irish Transverse Mercator. OS Sheet Name: 1349 & 1350