



- Legend:**
- Substation Access Track
  - Substation Buildings & Footpath
  - 150mm thick top layer of permeable compound stone consisting of 50mm single sized crushed Limestone
  - Concrete Equipment Plinths
  - Proposed 110kV Underground Cable Connecting 110kV Substation to Existing Transmission Network
  - Battery Container
  - 2.95m High Palisade Fence
  - Concrete Post & Rail Fence

CORNAWALL  
(ED Drum)



Date:	Rev:	Description:	Drawn By:
-------	------	--------------	-----------

Prepared By:

Galetech Energy Services  
 Clondargan, Stradone  
 Co. Cavan, H12 NV06  
 info@galetechenery.com  
 www.galetechenery.com

**Client:** Drumlins Park Ltd.

**Job Title:** Drumlins Park Wind Farm Substation & Grid Connection

**Drawing Title:**  
  
**Substation Layout Plan**

<b>Drawing No.:</b> DRU001SS_EIAR_GA-0.02	<b>Revision No.:</b> Rev00
<b>Scale:</b> (A3) 1:1,000	<b>Date:</b> 03/12/2020
<b>Drawn By:</b> J.B.	<b>Checked By:</b> S.C.
<b>Confirmed By:</b> S.C.	

OST © Licence: EN 0062820 - Prepared Using Irish Transverse Mercator. OS Sheet Name: 1349 & 1350