

Typical Section Through Off Road Sections

A = 125mm: Outer Diameter HDPE ESB Approved Duct, SDR=17.6

B= 160mm: Outer Diameter HDPE ESB Approved Duct, SDR=21

NOTES:

- This design is subject to EirGrid design approval.
- This drawing is to be read in conjunction with all other relevant documentation.
- Dimensions are in millimeters, unless noted
- Drawings are not to be scaled use figured dimensions only.

Head Office

Abbeydorney,

Tralee, Co. Kerry

Tel: 00353 66 7135710

Beenreigh,

Ireland

CLIENT



Castlebanny Wind Farm 110kV Grid Connection

PROJECT NUMBER 05-699

SHEET NUMBER 05699-DR-100 Typical Double Circuit 110kV Ducting through Off Road Section

DRAWING STATUS For Planning

SHEET TITLE

ISSUE/REVISION		
P02	16.12.20	Issued for Planning
P01	02.12.20	Issued for Planning
P00	03.09.20	Issued for Information
I/R	DATE	DESCRIPTION

SCALE 1:10