



- NOTES**
- All works will be carried out in accordance with the requirements of Irish Water Codes of Practice for Wastewater.
 - The total impermeable runoff from the proposed roof and paved areas amounts to 2640m². The runoff will discharge to 2 no. storage attenuation tanks. Tank no. 1 is sized at 40m³ capacity to take 992m² area runoff and Tank no. 2 is sized at 80m³ capacity to take 1648m² area runoff. Both tanks are designed for the 100 year storm event inclusive of 20% allowance for climate change.
 - Outflow from each attenuation tank will be limited to 1 L/S. Therefore the maximum outflow from the development will be limited to 2 L/S.
 - Finished Floor Levels to be finalised with Architect.
 - All manholes in grassed areas to have 200mm wide x 100mm deep concrete plinth / kerb cast to their perimeter to ensure they are not overgrown. Concrete to be grade C20/C25.
 - External face of all proposed manhole chambers to be minimum 0.5 metre from the kerb line and the external face of the sewers to be minimum 1.0 metre from the kerb line.
 - New manholes constructed over existing Irish Water public sewer to be constructed to Irish Water Standards STD-WW-09, STD-WW-10, AND STD-WW-11
 - Concrete surround in accordance with Irish Water standard detail STD-WW-07 and STD-WW-08 to be provided to all sewers where minimum cover (900mm) is not achieved - note the absolute minimum depth of cover above the external crown of the pipe shall be 750mm.
 - All foul sewer pipe materials shall be in compliance with section 3.1.3 of the Irish Water Code of Practice for Wastewater.
 - Each house to have individual connections to main sewers as per Irish Water requirements.

LEGEND

- EXISTING FOUL SEWER
- EXISTING SURFACE WATER SEWER
- PROPOSED FOUL SEWER
- PROPOSED SURFACE WATER SEWER
- PIPE NUMBER, DIAMETER AND GRADIENT
- FOUL AND STORM MANHOLE NUMBER, COVER AND INVERT LEVELS
- PROPOSED STORAGE ATTENUATION TANK
- PROPOSED GULLY
- PROPOSED PERMEABLE PAVING
- PROPOSED FOUL WATER INSPECTION CHAMBER
- PROPOSED SURFACE WATER INSPECTION CHAMBER
- PROPOSED ACO DRAIN
- MAJOR PIPE RUNS TO BE SURROUNDED IN 150MM CONCRETE AS PER TYPE 'D' DETAIL SWD-W-08
- 150mm Dia PERIMETER LAND DRAIN WITH COLLECTION AJ

PLANNING DRAWING.
NOT FOR CONSTRUCTION.
 ALL LEVELS GIVEN ARE RELATIVE TO ORDNANCE DATUM.
 THIS DRAWING HAS BEEN ISSUED FOR INFORMATION PURPOSES ONLY AND MUST NOT BE USED FOR CONSTRUCTION UNDER ANY CIRCUMSTANCES

- NOTES**
- For setting out refer to Architect's drawings.
 - This drawing to be read in conjunction with all other Architectural and Engineering drawings and all other relevant drawings and Specifications.
 - DO NOT SCALE THIS DRAWING. Use figured dimensions only.
 - No part of this document may be reproduced or transmitted in any form or stored in any retrieval system of any nature without the written permission as copyright holder except as agreed for use on the project for which the document was originally issued.
 - Ordnance Survey Ireland Licence Number EN 0074021

Rev. No.	Date	REVISION NOTE	Drn. By	Chkd. By
P1	22.10.2020	Revised Site Layout	AB	NB
P2	05.11.2020	Revised Site Layout	AB	NB
P3	03.12.2020	Revised Site Layout	JS	NB
P4	22.01.2021	OSI Licence Updated	JS	NB

Reddy Architecture + Urbanism
 Residential Development
 Clonattin, Gorey

Proposed Drainage
 Sheet 2 of 3
 CLO-CSC-ZZ-XX-DR-C-0012

Date: May 2020
 Dim by: AB, GL, NB
 Chkd by: GL, NB
 Apprd by: NB
 Scale: 1:500@A1
 Revision: P4

CS Consulting Group
 DUBLIN | LONDON | LIMERICK

Head Office
 19-22 Dame Street, Dublin 2.
 T: +353 (0)1 5480863 F: +353 (0)1 9011355
 e: info@csconsulting.ie
 w: www.csconsulting.ie

Quality Environment IS: EN ISO 9001:2008
 Certified Energy IS: EN ISO 14001:2004
 Health & Safety OHSAS 18001:2007