









LEGEND:

- PROPOSED ROAD 
- PROPOSED FOOTPATH 
- PROPOSED RAMP 
- PROPOSED OFF ROAD CYCLE TRACK 
- PROPOSED ON ROAD CYCLE TRACK 
- PROPOSED TACTILE PAVING 
- PROPOSED CORDUROY PAVING 



(QA - 4.8)
IN RESPONSE TO ITEM 4.8 OF THE QUALITY AUDIT,
TREES REMOVED TO COMPLY WITH VISIBILITY SPLAY

(QA - 4.1 & 4.3)
IN RESPONSE TO ITEM 4.1 & 4.3 OF THE QUALITY AUDIT,
ADEQUATE CROSSING FACILITIES PROVIDED AT ALL ROADS
JUNCTIONS.

(QA - 4.1 & 4.3)
IN RESPONSE TO ITEM 4.1 & 4.3 OF THE QUALITY AUDIT,
ADEQUATE CROSSING FACILITIES PROVIDED AT ALL ROADS
JUNCTIONS.

(QA - 4.4)
IN RESPONSE TO ITEM 4.4 OF THE QUALITY AUDIT,
ACCESSIBLE PARKING SPACES HAVE BEEN PROVIDED SPREAD OUT
ACROSS THE SCHEME.

(QA - 4.6)
IN RESPONSE TO ITEM 4.6 OF THE QUALITY AUDIT,
ON-ROAD CYCLE LANES FACILITIES PROVIDED FROM CLONATTIN ROAD TO
EXISTING OFF-ROAD CYCLE LANE.

(QA - 4.10)
IN RESPONSE TO ITEM 4.10 OF THE QUALITY AUDIT,
ALL JUNCTIONS CHANGED FROM YIELD TO STOP SIGNS & ROAD MARKINGS.

PLANNING DRAWING.
NOT FOR CONSTRUCTION.
ALL LEVELS GIVEN ARE
RELATIVE TO ORDNANCE DATUM.
THIS DRAWING HAS BEEN ISSUED FOR INFORMATION
PURPOSES ONLY AND MUST NOT BE USED
FOR CONSTRUCTION UNDER ANY CIRCUMSTANCES

- NOTES**
1. For setting out refer to Architect's drawings.
 2. This drawing to be read in conjunction with all other Architectural and Engineering drawings and all other relevant drawings and Specifications.
 3. DO NOT SCALE THIS DRAWING. Use figured dimensions only.
 4. No part of this document may be reproduced or transmitted in any form or stored in any retrieval system of any nature without the written permission as copyright holder except as agreed for use on the project for which the document was originally issued.
 5. Ordnance Survey Ireland Licence Number EN 0074021

Rev. No.	Date	REVISION NOTE	Drn. By	Chkd. By

Architect
Reddy Architecture + Urbanism
Residential Development
Clonattin, Gorey

Title
Quality Audit
Sheet 1 OF 5

Dwg. No.
CLO-CSC-ZZ-XX-DR-C-0056

Date
May 2020

Drn. by
AB

Chkd. by
GL

Aprvd. by
NB

Scale
1:500@A1

Revision

CS Consulting Group
DUBLIN | LONDON | LIMERICK

Head Office
19-22 Dame Street, Dublin 2.
T: +353 (0)1 5480863 F: +353 (0)1 9011355
e: info@csconsulting.ie
w: www.csconsulting.ie

Quality
NSAI Certified

IS EN ISO 9001:2008
IS EN ISO 14001:2004
IS EN ISO 50001:2011
CHSAS 18001:2007