(QA – 4.4)
IN RESPONSE TO ITEM 4.4 OF THE QUALITY AUDIT, ACCESSIBLE PARKING SPACES HAVE BEING PROVIDED SPREAD OUT ACROSS THE SCHEME.

(QA – 4.6)
IN RESPONSE TO ITEM 4.6 OF THE QUALITY AUDIT, ON-ROAD CYCLE LANES FACILITIES PROVIDED FROM CLONATTIN ROAD TO EXISTING OFF-ROAD CYCLE LANE.

(QA – 4.10)
IN RESPONSE TO ITEM 4.10 OF THE QUALITY AUDIT, ALL JUNCTIONS CHANGED FROM YIELD TO STOP SIGNS & ROAD MARKINGS.

LEGEND:

- PROPOSED ROAD
- PROPOSED FOOTPATH
- PROPOSED RAMP
- PROPOSED OFF ROAD CYCLE TRACK
- PROPOSED ON ROAD CYCLE TRACK
- PROPOSED TACTILE PAVING
- PROPOSED CORDUROY PAVING



KEY PLAN.
SCALE 1:10000

A091

PLANNING DRAWING.
NOT FOR CONSTRUCTION.
ALL LEVELS GIVEN ARE RELATIVE TO ORDNANCE DATUM.
THIS DRAWING HAS BEEN ISSUED FOR INFORMATION PURPOSES ONLY AND MUST NOT BE USED FOR CONSTRUCTION UNDER ANY CIRCUMSTANCES

NOTES
1. For setting out refer to Architect's drawings.
2. This drawing to be read in conjunction with all other Architectural and Engineering drawings and all other relevant drawings and Specifications.
3. DO NOT SCALE THIS DRAWING. Use figured dimensions only.
4. No part of this document may be reproduced or transmitted in any form or stored in any retrieval system of any nature without the written permission as copyright holder except as agreed for use on the project for which the document was originally issued.
5. Ordnance Survey Ireland Licence Number EN 0074021

Rev. No.	Date	REVISION NOTE	Drn. By	Chkd. By

Architect	Reddy Architecture + Urbanism
Project	Residential Development Clonattin, Gorey
Title	Quality Audit Sheet 3 OF 5
Dwg. No.	CLO-CSC-ZZ-XX-DR-C-0058

Date	Drn by	Chkd by	Aprvd by	Scale	Revision
May 2020	AB	GL	NB	1:500@A1	

CS Consulting Group
DUBLIN | LONDON | LIMERICK
Head Office
19-22 Dame Street, Dublin 2.
T: +353 (0)1 5480863 F: +353 (0)1 9011355
e: info@csconsulting.ie
w: www.csconsulting.ie

NSAI Certified
Quality I.S. EN ISO 9001:2008
Environment I.S. EN ISO 14001:2004
Energy I.S. EN ISO 50001:2011
Health & Safety OHSAS 18001:2007