




- NOTES:
- C20/25 CONCRETE TO HAVE A MINIMUM CEMENT CONTENT OF 260kg/m³, MAXIMUM WATER/CEMENT RATIO OF 0.65 AND SLUMP CLASS S2.
 - C25/30 CONCRETE TO HAVE A MINIMUM CEMENT CONTENT OF 280kg/m³, MAXIMUM WATER/CEMENT RATIO OF 0.65 AND SLUMP CLASS S2.
 - C40/50 CONCRETE TO HAVE A MINIMUM CEMENT CONTENT OF 400kg/m³, MAXIMUM WATER/CEMENT RATIO OF 0.45 AND SLUMP CLASS S3.
 - WHERE CLASS 6F1/6F2 CAPPING MATERIAL IS PROPOSED WITHIN 500mm OF CONCRETE OR STEEL, CLASS 6N TO BE USED INSTEAD.

NOTE:
ALL WORKS & SPECIFICATIONS TO BE UNDERTAKEN IN ACCORDANCE WITH
• TII SPECIFICATION FOR ROADWORKS
• GREATER DUBLIN CODE OF PRACTICE FOR DRAINAGE WORKS
• RECOMMENDATIONS FOR SITE DEVELOPMENT WORKS
• IRISH WATER CODE OF PRACTICE AND STANDARD DETAILS




NOTE: FOR UNIT DIMENSIONS REFER TO MANUFACTURERS BROCHURE & DETAILS







TYPICAL PETROL INTERCEPTOR DETAIL



SCALE 1:25



INLET DIA,mm	H MIN,mm
225	600
300	600
375	750
450	750
525	750
600	750
750	750






RECTANGULAR PRECAST ROAD GULLY DETAIL



ACO CHANNELS

(SCALE 1:10)



PRIVATE DRAINAGE
[ALTERNATIVE IN-SITU REINFORCED CONCRETE MANHOLE DETAILS]
(STRUCTURAL ENGINEER TO PROVIDE CONSTRUCTION DETAILS)

rev	date	description	APW by	LMCL chkd.
P01	25/01/21	ISSUED FOR PLANNING		
A		Approved		
B		Approved with comments		
C		Do not use		

client approval

suitability S2 - INFORMATION PLANNING

DBFL Consulting Engineers
Civil, Structural & Transportation Engineering
www.dbfl.ie

DUBLIN OFFICE: Ormond House, Upper Ormond Quay, Dublin 7, D07 W704
PHONE: +353 (0) 1 454 4000
CORK OFFICE: Phoenix House, Monahan Road, Cork, T12 H1XV
PHONE: +353 (0) 21 2204338
WATERFORD OFFICE: Suite 10 The Arkun, Marzana Gate, Canada Street, Waterford, X91 W028
PHONE: +353 (0) 51 309 500

project ref.
LISSYWOLLEN RESIDENTIAL DEVELOPMENT AT BRAUNY ROAD, LISSYWOLLEN, ATHLONE, CO. WESTMEATH

drawing title
STANDARD DETAILS SHEET 3 OF 4

architect
DELPHI ARCHITECTS

designed by LMCL author KGO scale AS sheet size A1 drawing no. 180176-DBFL-XX-XX-DR-C-5004 P01 revision