









LEGEND:

-  PROPOSED FOULED WATER SEWER
-  PROPOSED SURFACE WATER SEWER
-  PROPOSED 150mm FOULED RISING MAIN
-  PROPOSED ABOVE GROUND ATTENUATION STORAGE WITH UNDERLYING STONE 400mm DEEP
-  PROPOSED RAIN GARDEN
-  EXISTING OPEN DITCH NETWORK
-  PROPOSED STORMTECH ATTENUATION STORAGE
-  PROPOSED GREEN ROOF

NOTES:

1. DO NOT SCALE. USE FIGURED DIMENSIONS ONLY.
2. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL OTHER RELEVANT ARCHITECTURAL AND ENGINEERING DRAWINGS.
3. IT IS THE CONTRACTOR'S RESPONSIBILITY TO ENSURE THAT ALL WORKS ARE CONSTRUCTED IN ACCORDANCE WITH THE IRISH WATER CODE OF PRACTICE AND STANDARD DETAILS. THE CODE OF PRACTICE AND STANDARD DETAILS ARE AVAILABLE TO DOWNLOAD FROM THE IRISH WATER WEBSITE AT WWW.WATER.IE/CONNECTIONS/DEVELOPER-SERVICES/ WHERE THE DETAILS CONTAINED ON THIS DRAWING DIFFER FROM THE IRISH WATER CODE OF PRACTICE OR STANDARD DETAILS THIS MUST BE BROUGHT TO THE ATTENTION OF THE ENGINEER IMMEDIATELY. IRISH WATER STANDARDS WILL TAKE PRECEDENCE.
4. ALL PROPOSED PUBLIC STORM WATER DRAINAGE WORKS TO BE IN ACCORDANCE WITH FINGLA COUNTY COUNCIL'S REQUIREMENTS FOR TAKING IN CHARGE AND IN ACCORDANCE WITH THE GREATER DUBLIN REGIONAL CODE OF PRACTICE FOR DRAINAGE WORKS.
5. ALL PROPOSED PUBLIC FOULED WATER DRAINAGE WORKS TO BE IN ACCORDANCE WITH IRISH WATER REQUIREMENTS.
6. ALL PRIVATE DRAINAGE WORKS SHALL BE IN ACCORDANCE WITH THE BUILDING REGULATIONS PART H.
7. ALL COVER LEVELS ARE INDICATIVE ONLY AND SHOULD BE SET TO SUIT THE FINISHED ROAD OR PAVED LEVEL. LEVELS IN REAR GARDENS HAVE BEEN ASSUMED AS STRAIGHT GRADE TO ADJACENT BOUNDARY FROM FFL - 150mm. EXTERNAL LEVELS TO BE GOVERNED BY ARCHITECT GRAVITY SEWER PIPE MATERIAL TYPES

WASTEWATER PIPE MATERIAL TYPES
 GRAVITY SEWER PIPE MATERIAL TYPES
 THE IRISH WATER CODE OF PRACTICE FOR WASTEWATER INFRASTRUCTURE. THE TYPES AND FITTINGS OUTLINED HEREIN SHALL BE USED IN THE CONSTRUCTION OF THE GRAVITY SEWERS. PIPE MATERIAL SHOULD NOT CHANGE BETWEEN MANHOLES. THE LIST BELOW DOES NOT APPLY TO PRES INSTALLED BY PIPE JACKING OR MICRO TUNNELING.
 CONCRETE: CONCRETE SEWER PRES WITH SPIGOT AND SOCKET JOINTS AND RUBBER RING FITTINGS SHALL COMPLY WITH IS EN 1916 (2002), BS 5911, (2007 - 2010) AND IS 6 (2004) OR EQUIVALENT STANDARD, STRENGTH CLASS 120 WITH MINIMUM STITCHING LOADS IN ACCORDANCE WITH TABLE 8 OF BS 5911-1 (2002/2010).
 ALL PRES AND FITTINGS SHALL HAVE GASKET TYPE JOINTS OF SPIGOT AND SOCKET OR REBARRED FORM (PIPE DIAMETERS 225MM AND ABOVE).
 THERMOPLASTIC STRUCTURED WALL PRES: THERMOPLASTIC STRUCTURED WALL PRES SHALL COMPLY WITH THE PROVISIONS OF IS EN 13476 (2007/2009). PRES TO BE OF STIFFNESS CLASS 8kN/m² AND TO BE CAPABLE OF DEFORMATION OF 2.600 PG (1600 PAGES WITHOUT DAMAGE WHEN TESTED IN ACCORDANCE WITH SECTION 3.3 OF BS-55-01 (2008). (SEWER DIAMETERS 150MM UP TO 450MM, SERVICE CONNECTIONS OF 100MM DIAMETER).
 UNREINFORCED PVC: UNREINFORCED PVC PIPES AND FITTINGS SHALL COMPLY WITH THE PROVISIONS IS EN 1401 2009/2012. PRES TO BE APPLICATION AREA CODE 'UD'. STIFFNESS CLASS 8kN/m². PROVISION FOR JETTING SHALL BE BASED ON THE WRC SEWER JETTING CODE OF PRACTICE, JUNE 1997. PRES TO BE CAPABLE OF RESISTING A MAXIMUM JETTING PUMP PRESSURE OF 2800PSI (180 BAR) WITHOUT DAMAGE. (SEWER DIAMETERS 150MM UP TO 450MM, SERVICE CONNECTIONS OF 100MM DIAMETER).
 NOTES: THE USE OF ALTERNATIVE PIPE TYPES AND MATERIALS WILL REQUIRE THE PRIOR WRITTEN AGREEMENT OF IRISH WATER.

WHERE 12m COVER TO FOULED WATER PIPE SLOTT IS NOT ACHIEVABLE IN ROADWAYS, CONCRETE SURROUND SHALL BE PROVIDED IN ACCORDANCE WITH STD-WM-06 OF WASTEWATER INFRASTRUCTURE STANDARD DETAILS.
 SERVICE LAYOUT DISTANCES:
 HORIZONTAL AND VERTICAL SERVICE LAYOUT DISTANCES SHALL BE AS PER IRISH WATER STANDARD DETAIL STD-WM-05.
 THE EXTERNAL FACE OF MANHOLES SHALL BE AT LEAST 0.5m FROM KERB LINE.
 RESTRICTIONS ON PLANTING:
 PLANTING ADJACENT TO WASTEWATER INFRASTRUCTURE SHALL BE IN COMPLIANCE WITH IRISH WATER STANDARD DETAILS STD-WM-06 AND STD-WM-06A.

REV.	DATE	AMENDMENT	DRN	APPO
A	07/11	REVISED FOR FINAL SUBMISSION	PJD	MD

Waterman Moylan
 Engineering Consultants
 BLOCK 5, EASTPOINT BUSINESS PARK, ALFIE BRYNE ROAD,
 DUBLIN D03 K7W7 IRELAND.
 Tel: (01) 604 8800 Fax: (01) 861 3878
 Email: info@watermanmoylan.ie www.watermanmoylan.ie

CLIENT KINNEST LTD.
ARCHITECT CONROY CROWE KELLY ARCHITECTS
PROJECT ALBURN, MALAHIDE, CO. DUBLIN

TITLE	DRAINAGE GENERAL ARRANGEMENT
DRAWN	DESIGNED
PJD	MD
SCALE	APPROVED
1:1000 @ A1	DATE
	APR '20
	REVISION
	1