

permission of Fehily Timoney & Company as copyright holder except as agreed for use on the project for which the document was originally issued. Do not scale. Use figured dimensions only. If in doubt - Ask!

UNIT REF No.	NOMINAL FLOW	DIM 'L'	APPROX EMPTY WEIGHT (Kg)	FALL ACROSS UNIT
NS3	3 L/S	1760	110	50
NS6	6 L/S	1760	110	50
NS10	10 L/S	2610	130	50
NS15	15 L/S	3910	167	50

500 Inlet 4 \triangleleft "L" ^LCONCRETE BASE SLAB CAST BY CLIENT (TO SUIT SITE CONDITIONS)

TYPICAL ELEVATION OF PETROL INTERCEPTOR

Scale 1:10

	Арр Ву	Date	PROJECT	
G APPLICATION	Н	11.12.19		
			DERNACART WINDFARM	
			TYPICAL FUEL RETENTION PETROL INTERCEPTOR	

Statkraft Scale (@ A1-) 1:10 Project number Date P1892 23.09.19 Drawing Number Drawn by Rev CS P1892-0400-0012 Α Checked by FB O:\ACAD\2019\P1892\P1892-0400-0012

CLIENT



