



- GENERAL NOTES:**
- For Symbols Legend see drawing CW-3-50-XX-XXX-DR-ETH-E-0001
  - For Standard Drawing notes see drawing CW-3-50-XX-XXX-DR-ETH-E-0001
  - Do not dimension from this drawing.
  - All dimensions are in millimeters. Unless otherwise stated.
  - The complete installation shall be in accordance with the building regulations, Design Guides & Model Engineering Specifications.
  - This drawings shall be read in conjunction with Schematics, Services Layouts, Specifications, relevant Architects, Structural & Fire Engineers drawings.
  - All dimensions shall be checked on site prior to fabrication, order or delivery.
  - Final dimensions of all equipment, materials & fittings shall be checked by the Electrical Contractor prior to order/ delivery to site.
  - The Electrical Contractor shall be responsible for co-ordinating all services on site.
  - The Electrical Contractor Shall be responsible for producing a full set of combined co-ordinated services working drawings.
  - All drawings to be read in conjunction with Architectural Drawings.
  - In the event of discrepancy between Ethos drawings and Specifications this should be highlighted to Ethos for resolution.
  - The Contractor shall allow for all necessary supports and fittings required to provide a fully functioning installation.
  - All drawings to be read in colour.

- DRAWING NOTES**
- ESB TO PROVIDE MINI PILLARS.
  - LIGHT FITTINGS TO BE INSTALLED AS PER SPECIFIED HEIGHT IN METERS.
  - AREA NOT IN PROJECT SCOPE, FOR FURTHER DETAILS REFER TO DRAWING: CHCWP2-ETH-ZZ-XX-DR-E-SS100.
  - AREA NOT IN PROJECT SCOPE.
  - BUILDING ENTRANCES REQUIRE A MINIMUM OF 100 LUX.
  - DISABLED CAR PARK SPACES REQUIRE A MINIMUM OF 20 LUX.
  - EXTERNAL STEPS REQUIRE AN AVERAGE OF 30 LUX WITH A MINIMUM OF 15 LUX.

- EXT-A AVENIDA LENS 49W 6350lm LED
- EXT-B AVENIDA LENS 19W 2700lm LED
- EXT-C P852 NW 29W LED - SABRE LIGHTS
- EXT-C P852 NW 29W LED
- EXT-D P852 NW 20W LED
- EXT-F P852 NW 38W LED
- EXT-G EMPHASIS 32W LED

Revision	Date	Details	By	App.
P2	26/05/21	Planning Issue		BML PR
P1	16/12/20	Planning Issue		BML LW

Drawing Status: **FOR INFORMATION ONLY**

**ethos** ENGINEERING  
 Penthouse Suite, Apex Business Centre, Blackthorn Road, Sandymount, Dublin 18.  
 Tel: +353 (0)1 2932220  
 Web: www.ethoseng.ie  
 Email: info@ethoseng.ie

Client: CAIRN HOMES PLC  
 Project: CITY WEST COOLDOWN COMMONS PHASE 3

Drawing Title: Electrical Services Site Services External Lighting Layout

Drawn By: BML	Designed By: BML	Checked By: LW
Scale: 1:500 @A1	Date: MAY 2021	
Project No.: 20_D052	Drawing No.: CW-3-60-SW-ZZZ-DR-ETH-E-08100	Revision: P2 Status: S4