



KEY	
	EXISTING PUBLIC ROAD
	PROPOSED PERMANENT ROAD
	APPROXIMATE WHEEL TRACK OF VEHICLE
	OVER-RUN SPACE REQUIRED FOR VEHICLE



16.6m Low Loader
Overall Length 16.633m
Overall Width 2.600m
Overall Body Height 3.425m
Min Body Ground Clearance 0.350m
Track Width 2.600m
Lock to lock time 6.00s
Wall to Wall Turning Radius 9.000m

VEHICLE CONFIGURATION - 16.6m-LONG ARTICULATED LOW-LOADER
SPECIFIC DELIVERY VEHICLE TO BE DETERMIND BY AIL CONSULTANT



AECOM

PROJECT

PROJECT CIRRUS

CLIENT

HUNTSTOWN
POWER COMPANY
LTD.

CONSULTANT

AECOM
Adelphi Plaza
Georges Street Upper
Dun Laoghaire
County Dublin
Ireland
T +353 (0)1 2383100
www.aecom.com

LEGEND

NOTES

- DRAWINGS ARE INDICATIVE ONLY AND SHOULD NOT BE USED FOR DETAILED DESIGN;
- THE EIRGRID SUBSTATION IS BASED ON THE LATEST EIRGRID STANDARD (01-09-2020) AND IS SUBJECT TO CHANGE BY EIRGRID. DRAWING REFERENCE XDN-LAY-ELV-STND-F004;
- THE EQUIPMENT LAYOUTS ARE INDICATIVE AND DIMENSIONS MAY CHANGE ONCE THE EXACT SPECIFICATIONS ARE DETERMINED.

ISSUE/REVISION

ISSUE/REVISION	DATE	DESCRIPTION
P2	14/09/2021	FOR PLANNING
P1	03/09/2021	FOR PLANNING
P0	28/06/21	FIRST ISSUE FOR PLANNING
I/R	DATE	DESCRIPTION

STATUS

FOR PLANNING

PROJECT NUMBER

60641561

SCALE

1:500 @ A1

SHEET TITLE

MOORETOWN 220 kV SUBSTATION
220 kV GIS SUBSTATION
GIS SWITCHGEAR DELIVERY

SHEET NUMBER

60641561-DWG-728

REV

P2

This drawing has been prepared for the use of AECOM's client. It may not be used, modified, reproduced or relied upon by third parties, except as agreed by AECOM or as required by law. AECOM accepts no responsibility and denies any liability whatsoever, to any party that uses or relies on this drawing without AECOM's express written consent. Do not scale this document. All measurements must be obtained from the stated dimensions.