

Column Ref	Type	Height	Luminaire Type	Mini Pillar/Circuit
C1	OCTAGONAL GALVANIZED STEEL	8 meters	Micro Germany Plus MPG-1N-40W	MP-8/ L1
C2	OCTAGONAL GALVANIZED STEEL	8 meters	Micro Germany Plus MPG-1N-40W	MP-8/ L1
C3	OCTAGONAL GALVANIZED STEEL	8 meters	Micro Germany Plus MPG-1N-40W	MP-8/ L1
C4	OCTAGONAL GALVANIZED STEEL	8 meters	Micro Germany Plus MPG-1N-40W	MP-8/ L1
C5	OCTAGONAL GALVANIZED STEEL	8 meters	Micro Germany Plus MPG-1N-40W	MP-8/ L1
C6	OCTAGONAL GALVANIZED STEEL	8 meters	Micro Germany Plus MPG-1N-40W	MP-8/ L1
C7	OCTAGONAL GALVANIZED STEEL	8 meters	Micro Germany Plus MPG-1N-40W	MP-8/ L2
C8	OCTAGONAL GALVANIZED STEEL	8 meters	Micro Germany Plus MPG-1N-40W	MP-8/ L2
C9	OCTAGONAL GALVANIZED STEEL	8 meters	Micro Germany Plus MPG-1N-40W	MP-8/ L2
C10	OCTAGONAL GALVANIZED STEEL	8 meters	Micro Germany Plus MPG-1N-40W	MP-8/ L2
C11	OCTAGONAL GALVANIZED STEEL	8 meters	Micro Germany Plus MPG-1N-40W	MP-8/ L2
C12	OCTAGONAL GALVANIZED STEEL	8 meters	Micro Germany Plus MPG-1N-40W	MP-8/ L3
C13	OCTAGONAL GALVANIZED STEEL	8 meters	Micro Germany Plus MPG-1N-40W	MP-8/ L3
C14	OCTAGONAL GALVANIZED STEEL	8 meters	Micro Germany Plus MPG-1N-40W	MP-8/ L3
C15	OCTAGONAL GALVANIZED STEEL	8 meters	Micro Germany Plus MPG-1N-40W	MP-8/ L3
C16	OCTAGONAL GALVANIZED STEEL	8 meters	Micro Germany Plus MPG-1N-40W	MP-8/ L3

SAFETY, HEALTH & ENVIRONMENTAL INFORMATION

IN ADDITION TO THE HAZARDS / RISKS NORMALLY ASSOCIATED WITH THE TYPES OF WORK DETAILED ON THIS DRAWING, NOTE THE FOLLOWING:

SIGNIFICANT RESIDUAL RISKS:

1. SERVICES AT HIGH LEVEL (WITHIN CEILINGS, VOIDS ETC.) - INJURY DUE TO RISK OF FALLING

2. WORKING IN CONFINED SPACES - CLAUSTROPHOBIA, INJURY DUT TO SPACE RESTRICTIONS.

ACTION TO BE TAKE:

1. INSTALLER TO ABIDE BY THE "WORKING AT HEIGHT REGULATIONS" AND USE OF THE CORRECT LIFTING PLANT, SUPPORT EQUIPMENT AND PPE.

2. USE OF THE CORRECT PPE AND PREFERABLY WORK WITH ANOTHER COLLEAGUE AT ALL TIMES.

DIMENSIONS

FIGURED DIMENSIONS TO BE TAKEN IN PREFERENCE TO SCALED DIMENSIONS. ALL DIMENSIONS ARE TO BE VERIFIED ON SITE PRIOR TO WORK COMMENCING.

DISCREPANCIES

ANY DISCREPANCY IS TO BE REFERRED TO CONSULTANT BEFORE PROCEEDING.





COPYRIGHT

THIS DRAWING IS ISSUED ON THE CONDITION THAT IT IS NOT COPIED OR DISCLOSED TO ANY OTHER UNAUTHORISED PERSON WITHOUT THE PRIOR CONSENT OF "WOODSPS".

RELATED DOCUMENTS

THIS DRAWING SHALL BE READ IN CONJUNCTION WITH THE WRITTEN SPECIFICATION WHERE APPROPRIATE

LEGEND

	A1	PUBLIC LIGHTING HOUSING ESTATE PATHWAYS	FITTING TYPE	Type A
			MANUFACTURE	Micro Plus Germany
			PRODUCT	MPG-1N-35W
			MOUNTING	4m OCTAGONAL COLUMNS
	B1	PUBLIC LIGHTING HOUSING ESTATE ROADWAYS	FITTING TYPE	Type B
			MANUFACTURE	Micro Plus Germany
			PRODUCT	MPG-1N-30W
			MOUNTING	6m OCTAGONAL COLUMNS
	C1	PUBLIC LIGHTING ACCESS ROAD	FITTING TYPE	Type C
			MANUFACTURE	Micro Plus Germany
			PRODUCT	MPG-1N-40W
			MOUNTING	8m OCTAGONAL COLUMNS
	PHOTOCELL	PHOTOCELL	FITTING TYPE	Photocell
			MANUFACTURE	Charles Endrelect
			PRODUCT	Long life Photocell
			MOUNTING	Nema Socket

- 100mm Ducting

MP-(1-9)

- Public Lighting Mini Pillars

SITE SPECIFIC NOTES

1. ALL ELECTRICAL INSTALLATION TO BE IN ACCORDANCE NATIONAL RULES OF ELECTRICAL INSTALLATIONS I.S.10101 OR THE LATEST AMENDMENT AT THE TIME OF CONSTRUCTION.
2. LUMINAIRES TO BE FITTED ON 4, 6 & 8 METER OCTAGONAL GALVANIZED STEEL COLUMNS.

P-02	FOR PLANNING	23/09/21	POT	K
P-01	FOR PLANNING	25/08/21	POT	K
Rev	Description	Date	Dm	C



STATUS:		PLANNING	
CLIENT			
VOYAGE PROPERTY LIMITED			
PROJECT:			
GREENPARK, DOCK RD, LIMERICK			
DRAWING TITLE:			
PUBLIC LIGHTING MINI PILLARS & DUCTING LOCATIONS AREA A			
SCALE (@ A1)	DRAWING NUMBER		Revision
1-500	114-1000- GP - E200		P-02

EXISTING LIGHTING COLUMN @ ROUNDABOUT



KEY PLAN

