



- NOTES:
- THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL OTHER RELEVANT ARCHITECTURAL AND ENGINEERING DRAWINGS. ANY DISCREPANCIES, ERRORS OR OMISSIONS TO BE BROUGHT TO THE ATTENTION OF THE DESIGNER.
 - ALL DIMENSIONS TO BE CHECKED BY THE CONTRACTOR ON SITE PRIOR TO COMMENCEMENT OF WORKS.
 - JBARRY'S TO BE INFORMED BY THE CONTRACTOR OF ANY DISCREPANCIES PRIOR TO THE COMMENCEMENT OF WORKS ON SITE.
 - DIMENSIONS OF ALL BOUNDARIES AND ADJOINING ROADS TO BE CHECKED ON SITE PRIOR TO COMMENCEMENT OF WORKS.
 - DO NOT SCALE. ALL MEASUREMENTS AND COORDINATES TO BE CHECKED ON SITE.
 - THE DEVELOPMENT SHALL HAVE A BULK WATER METER (EXACT LOCATION TO BE AGREED WITH IRISH WATER) IN ACCORDANCE WITH IRISH WATER CODE OF PRACTICE SECTION 3.15.4.
 - EACH HOUSE UNIT SHALL HAVE AN APPROVAL BOUNDARY BOX (REFER TO APPENDIX A OF THE IRISH WATER CODE OF PRACTICE FOR WATER INFRASTRUCTURE) WITH INTEGRAL STOPCOCK AND SUITABLE FOR THE RECEPTION OF A WATER METER (REFER TO IRISH WATER CODE OF PRACTICE FOR WATER INFRASTRUCTURE SECTION 3.14).
 - ALL PROPOSED WATERMAIN PIPEWORK TO BE HDPE WITH MINIMUM PE-80 SDR-17 IN ACCORDANCE WITH SECTION 3.9 OF IRISH WATER CODE OF PRACTICE FOR WATER INFRASTRUCTURE.
 - THE MINIMUM PIPE DIAMETER PROPOSED IS 100mm Ø (ID).
 - WATERMAIN TO BE LOCATED IN COMPLIANCE WITH STD-W-12A OF IW STANDARDS, IN RELATION TO PLANTING PROXIMITY.
 - SEPARATION DISTANCES FROM WATERMAIN TO BE IN COMPLIANCE WITH STD-W-11 OF IW STANDARDS.
 - ALL WATERMANS WILL HAVE A MINIMUM COVER OF 900mm. ALL SERVICE PIPES CONNECTING PROPERTIES WILL HAVE MINIMUM COVER OF 750mm.
 - HYDRANTS SHALL BE DOUBLE FLANGED DRILLED TO PN16 AND SHALL COMPLY WITH BS EN 14339, IS EN 1074 PART 6 AND 135 750 REFER TO IRISH WATER CODE OF PRACTICE FOR WATER INFRASTRUCTURE SECTION 3.16.5.
 - SLUICE VALVES HAVE BEEN PROVIDED SO THAT INDIVIDUAL SECTIONS CAN BE ISOLATED & WILL COMPLY TO BS 5163. THE DEPTH OF THE SLUICE VALVE SPINDLE CAP BELOW FINISHED GROUND WILL NOT EXCEED 300mm.
 - AIR VALVE AND HYDRANT COVERS, WHERE LOCATED IN GRASS AREAS, SHALL BE SURROUNDED BY CONCRETE FLINTH 200MM ALL AROUND AND 100MM DEEP, IN COMPLIANCE WITH IW STANDARDS.
 - INDIVIDUAL SERVICE CONNECTION TO EACH UNIT TO BE IN ACCORDANCE WITH STD-W-26 OF IW STANDARDS.
 - ALL WATERMAIN DETAILS TO BE IN ACCORDANCE WITH THE IRISH WATER INFRASTRUCTURE STANDARD DETAILS AND CODE OF PRACTICE FOR WATER INFRASTRUCTURE.

WATERMAIN LEGEND:

EXISTING 450mm Ø DN DI CLASS K9 DN16 TRUNK WATERMAIN	
EXISTING 250mm Ø D.I. WATERMAIN	
PROPOSED 100mm Ø (ID) HDPE WATERMAIN (PE-80 SDR-17)	
PROPOSED 150mm Ø (ID) HDPE WATERMAIN (PE-80 SDR-17)	
PROPOSED 200mm Ø (ID) HDPE WATERMAIN (PE-80 SDR-17)	
PROPOSED 250mm Ø (ID) HDPE WATERMAIN (PE-80 SDR-17)	
PROPOSED Ø25MM SERVICE CONNECTION AND BOUNDARY BOX TO INDIVIDUAL UNITS	
PROPOSED FIRE HYDRANT (Irish Water: STD-W-16)	
PROPOSED SLUICE VALVE (Irish Water: STD-W-15)	
PROPOSED SCOUR VALVE (Irish Water: STD-W-30A)	
PROPOSED WASHOUT HYDRANT (Irish Water: STD-W-30A)	
PROPOSED AIR VALVE (Irish Water: STD-W-22)	
PROPOSED BULK WATER METER (Irish Water: STD-W-26)	
10 M INDICATIVE WAYLEAVE FOR THE EXISTING 450mm DIA WATERMAIN	

LAYOUT UPDATED, ISSUED FOR PLANNING	SW	24.11.21	P05
GENERAL AMENDMENTS	LR	19.11.21	P04
LAYOUT UPDATED & HOUSE CONNECTION	SW	21.10.21	P03
LAYOUT AND LEVELS UPDATED	SW	11.05.21	P02
INITIAL ISSUE	SW	20.04.21	P01
Description:	Drawn:	Date:	Rev.:

Client:
Quintain Developments Ireland Limited

Project:
Portmarnock South Phase 1D

Clients Representative:
J. B. Barry and Partners Limited
Consulting Engineers

Classon House
Dundrum Business Park
Dundrum Road
Dublin 14
Tel: +353 1 485 1400
email: info@jbbarry.ie
web: www.jbbarry.ie

Drawn By: SW Date: MARCH 2021

Checked By: JOB Date: MARCH 2021 Approved By: JOB Date: MARCH 2021

Internal Project Ref: 21205 Stage: PLANNING Suit: S3

Drawing Title:
WATERMAIN LAYOUT SHEET 2

Scales: 1:500 @ A1

Drawing No.: 21205-JBB-00-XX-DR-C-03002 Rev.: P05

© Copyright
This drawing and any design here on is the copyright of the Consultants and must not be reproduced without their written consent.
All drawings remain the property of the Consultants.