

- FOR SETTING OUT REFER TO ARCHITECT'S DRAWINGS. • THIS DRAWING TO BE READ IN CONJUNCTION WITH ALL OTHER ARCHITECTURAL AND ENGINEERING DRAWINGS AND ALL OTHER RELEVANT DRAWINGS AND SPECIFICATIONS.
- DO NOT SCALE THIS DRAWING. USE FIGURED DIMENSIONS ONLY. • NO PART OF THIS DOCUMENT MAY BE REPRODUCED OR TRANSMITTED IN ANY FORM OR STORED IN ANY RETRIEVAL SYSTEM OF ANY NATURE WITHOUT THE WRITTEN PERMISSION OF O'CONNOR SUTTON CRONIN AS COPYRIGHT HOLDER EXCEPT AS AGREED FOR USE ON THE PROJECT FOR WHICH THE DOCUMENT WAS ORIGINALLY ISSUED.

| Rev No. | Date | Revision Note | Drn by | Chkd by |
|---------|----------|------------------------|--------|---------|
| P01 | 21.10.21 | SUITABLE FOR PLANNING. | B.M. | D.W. |
| P02 | 26.11.21 | SUITABLE FOR PLANNING. | B.M. | D.W. |

| Rev No. Date Revision Note | Drn by Chkd by | ENVIRONMENT ISO 14001/2015 NSAI Certified NSAI Certified | Head Office, 9 Prussia Street, Dublin 7. D07 KT57 | |
|----------------------------|----------------|---|--|---|
| | | | TEL +353 (0)1 8682000 | |
| | | bsi. BIM Verified Design & Construction Capital/Delivery PAS 1192-2 | e: contactus@ocsc.ie w: www.ocsc.ie | Multidisciplinary Consulting Engined |
| | | | Dublin London Belfast | t Galway Cork |

DRAWINGS NOTES:

- 1. LIGHTING TO BE SUPPLIED VIA A SOLAR TIME CLOCK WITHIN EACH PUBLIC LIGHTING MINI PILLAR.
- A MAXIMUM OF 6No. LUMINAIRES PER CIRCUIT & 4No. CIRCUITS PER PUBLIC LIGHTING MINI PILLAR.
- 3. ALL COLUMNS TO BE 6 METRES HIGH WITH A 1 METRE OUTREACH BRACKET &
- SETBACK 1 METRE FROM KERB.
- 4. ALL COLUMNS TO BE HINGED & TO BE AT LEAST 1 METRE CLEAR OF ALL OVERHEAD HIGH VOLTAGE POWER LINES.
- 5. FOR SCHEDULES OF EQUIPMENT SEE SPECIFICATION.

- 6. THE COMPLETE INSTALLATION TO BE CO-ORDINATED WITH ALL OTHER SERVICES.

LEGEND OF SYMBOLS:



- PRELUX VALO 30W 4K LUMINAIRE, 6 METRE POLE MOUNTED



REF: 'X1' LUMINAIRE

6 METRE POLE MOUNTED X25

REFER TO LUMINAIRE SCHEDULE

BEGA 84120 POLE TOP LUMINAIRE, 28W 3K LED

REF: 'X2' LUMINAIRE

6 METRE POLE MOUNTED

REFER TO LUMINAIRE SCHEDULE

RECESSED WALL LUMINAIRE. X17

1No. ROW OF 4No. M10 – SOCKET SCREWS

140mm BASE, 5mm WALL — 76mm SHAFT, 4mm WALL

METRO 47/57 ONLY

DOOR APERTURE 500x100mm

FLANGE PLATE

DETAIL No.1

Title: ELECTRICAL

OCSC

Multidisciplinary Consulting Engineers

TYPICAL 6 METRE POLE LIGHTING COLUMN SCALE N.T.S.

CABINTEELY, DUBLIN 18.

Project: CORNELSCOURT RESIDENTIAL DEVELOPMENT,

Code |Originator| Zone | Level | Type | Role | Number | Status | Revision A587 - OCSC - XX - XX - SK - E - 0003 | S4 | PO2

Date: 20.10.21 Scale: 1:500 @ A1 Drn by:B.M. Chkd by:M.M. Aprvd by:D.W.

PROPOSED SITE LIGHTING LAYOUT

Client: CORNEL LIVING LIMITED

140mn

XX 76

REF: 'X3' LUMINAIRE PUK STEP LINEAR 7, 10.5W

PRELUX VALO 50W STREET LUMINAIRE

- X2 BEGA 84120 POLE TOP LUMINAIRE, 28W 3K LED 6 METRE POLE MOUNTED



X3 PUK STEP LINEAR 7, 10.5W RECESSED WALL LUMINAIRE. X17