


EXISTING STONE BRIDGE PHOTO 01

0.4m Parapet 5.0m 0.4m 1m X 0.4m Yellow Marker Tape Wide Concrete Parapet Safety A393 steel mesh **Barrier** reinforcement Bridge Deck Red marker ST1 Concrete strips linked to galvanised steel plates Ducts laid in CBGM B (CI.822) compacted to CI.813.10 and Table 0/1m 0.1m 0.1m 0.1m 0.1m 8/4 of TII Specification 0.8m for Roadworks 0.45m Min. (15n/mm² after 7 days) Precast concrete beam Ducts to be formed into -Ducts for Cabling flat configuration with Carried in bridge deck steel plates on top 5.4m 12mm dia. pull **SECTION B-B** rope in all ducts

5.8m





If Applicable : Ordnance Survey Ireland Licence No. EN 0001220 © Ordnance Survey Ireland and Gove OSI-6186,6140, Cork-40-48-49-59-60

FEHILY Cork | Dublin | Carlow

| Rev. | Description | Арр Ву | Date |
|------|--------------------|--------|----------|
| Α | ISSUE FOR APPROVAL | JH | 15.12.21 |
| В | ISSUE FOR PLANNING | JH | 26.01.22 |
| | | | |
| | | | |
| | | | |
| | | | |

Scale 1:25

| PROJECT | CLIENT | | | | | | | | |
|--|----------------------|----------|-------------------------|---------------------------|-----|--|--|--|--|
| BALLINAGREE WIND FARM | BALLINAGREE WIND DAC | | | | | | | | |
| DALLINAGREE WIND LARRY | | | | | | | | | |
| | | | | | | | | | |
| SHEET | Date | 15.12.21 | Project number P2114 | Scale (@ A1-) AS SHOWN | | | | | |
| | Drawn by | NS | Drawing Number | | Rev | | | | |
| - WF-HF8 | Checked by | ТВ | P2114-0300-0017 B | | | | | | |
| O:\ACAD\2019\P2114\P2114-0300-0017 | | | | | | | | | |