



Hor Scale 500  
Ver Scale 50

Datum (m) -2.000

MH Name	Com MH1	Com MH2	Com MH3	Com MH4	Com MH5	Com MH6	Com MH7	Com MH8
PN	F1.000	F1.001	F1.002	F1.003	F1.004	F1.005	F1.006	
Dia (mm)	750	750	750	750	750	750	750	
Slope (1:X)	381.0	381.0	381.0	381.0	381.0	381.0	381.0	
Cover Level (m)	9.000	9.000	11.400	11.700	12.400	11.700	11.400	11.000
Invert Level (m)	7.550 7.531 7.531		7.365 7.365	7.308 7.308	7.227 7.227	7.084 7.084	7.004 7.004	6.810
Length (m)		63.255	21.714	30.995	54.653	30.491	72.524	

- Notes:**
- All levels relate to OD Malin Head and are in meters.
  - Do not scale from this drawing. If in doubt, ask.
  - This drawing should be read in conjunction with all relevant and available documentation.
  - All foul water drainage to be designed and constructed in accordance with Irish Water Code of Practice and Standard Details.
  - All pipework shall be Polypipe Polysewer and fittings, or similar approved.
  - All pipes to have a minimum cover of 900mm in non-trafficable areas and 1.2m in trafficable areas.
  - Refer to drawing 252666-ARUP-ZZ-XX-DR-C-2000 for Proposed Foul Water Layout.
  - Refer to drawing 252666-ARUP-ZZ-XX-DR-C-6000 and 6001 for drainage details.

P05	16/02/22	RM	RM	J.MacC
Issued for Planning				
P04	18/01/22	RM	RM	J.MacC
Issued for Information				
P03	20/12/21	WC	RM	J.MacC
Issued for Information				
P02	18/11/21	RM	RM	J.MacC
Issued for Information				
P01	04/11/21	ROD	RM	J.MacC
Issued for Information				
Rev	Date	By	Chkd	Appd

**ARUP**  
One Albert Quay  
Cork, Ireland  
Tel +353 (0)21 427 7670 Fax +353 (0)21 427 2345  
www.arup.com



Client  
**Creamfields Residential Development**

Drawing Title  
**Proposed Combined Sewer Longsections**

Scale at A1: As Shown  
Role: Site Infrastructure  
Suitability: S2 - Suitable for Information  
Anup Job No: **252666-00** Rev: **P05**  
Name: **252666-ARUP-ZZ-XX-DR-C-2100**