









© COPYRIGHT OF THIS DRAWING IS RESERVED BY DBFL CONSULTING ENGINEERS. NO PART SHALL BE REPRODUCED OR TRANSMITTED WITHOUT THEIR WRITTEN PERMISSION.




NO CHANGES OF WHATSOEVER NATURE ARE TO BE MADE TO ANY DETAILS SET OUT OR CONTAINED IN ANY DBFL SPECIFICATIONS OR DRAWINGS UNLESS THE EXPRESS CONSENT HAS BEEN OBTAINED IN ADVANCE, IN WRITING, FROM DBFL.

- NOTES:
- ALL REINFORCED CONCRETE ON THIS DRAWING SHALL BE U.N.O.: 35/20 COVER = 50mm MIN.
 - SURFACE FINISHES FOR CONCRETE:
 - CLASS F1 FOR ALL CONCRETE 100mm OR MORE BELOW GROUND LEVEL.
 - CLASS F3 FOR ALL EXPOSED CONCRETE ABOVE 100mm BELOW GROUND LEVEL.
 - ALL EXPOSED CORNERS ON CONCRETE SHALL BE CHAMFERED WITH 25mm x 25mm CHAMFERS.
 - ALL STRUCTURAL CONCRETE (HEADWALLS, RC MANHOLES, PETROL INTERCEPTOR SLABS) TO RECEIVE MC DUR 1680 (OR SIMILAR APPROVED TAR MODIFIED EPOXY RESIN) TO ALL BURIED SURFACES, TO FINISH 100mm BELOW GROUND LEVEL.
 - ALL SEWERS SHALL BE PRESSURE TESTED PRIOR TO BACKFILLING.
 - TYPE 1 GRANULAR MATERIAL - BROKEN STONE OR GRAVEL TO PASS 10mm SIEVE AND BE RETAINED ON 5mm SIEVE.
 - TYPE 2 GRANULAR MATERIAL - BROKEN STONE OR GRAVEL TO PASS 10mm - 25mm SIEVE, ACCORDING TO PIPE SIZE, (SEE TABLE) AND BE RETAINED ON 5mm SIEVE.
 - TYPE 3 SELECTED FILL - UNIFORM READILY COMPACTED MATERIAL FREE FROM TREE ROOTS, VEGETABLE MATTER, BUILDING DEBRIS, AND FROZEN SOIL AND EXCLUDING CLAY LUMPS RETAINED ON A 75mm SIEVE AND STONES RETAINED ON A 37.5mm SIEVE.
 - RIGID PIPES SHALL MEAN CAST OR SPUN IRON, CONCRETE, ASBESTOS CEMENT OR CLAY.



IRISH WATER STANDARD DETAILS FOR WATER NETWORKS BROUGHT INTO CONTRACT BY REFERENCE

Drawing Ref	Title
STD-W-01	Water Service Connection Responsibility
STD-W-03	Customer Connection and Boundary Box (25mm OD Pipe)
STD-W-04	General pipe connections (sheet 1 of 7)
STD-W-05	General pipe connections (sheet 2 of 7)
STD-W-06	General pipe connections (sheet 3 of 7)
STD-W-07	General pipe connections (sheet 4 of 7)
STD-W-08	General pipe connections (sheet 5 of 7)
STD-W-09	General pipe connections (sheet 6 of 7)
STD-W-10	General pipe connections (sheet 7 of 7)
STD-W-11	Typical service layout indicating separation distances
STD-W-12	Restrictions on trees / shrubs planting adjacent to watermains
STD-W-13	Trench backfill & bedding
STD-W-14	Sluice valve for ductile iron (D.I.) pipe (<350mm dia.) (sheet 1 of 2)
STD-W-15	Sluice valve for polyethylene (P.E.) pipe (<350mm dia.) (sheet 2 of 2)
STD-W-18	On-line hydrant for polyethylene (P.E.) pipe (sheet 3 of 4)
STD-W-19	Off-line hydrant for polyethylene (P.E.) pipe (sheet 4 of 4)
STD-W-26	Meter chamber (≤300mm dia.)
STD-W-27	Marker posts / plates
STD-W-28	Water main thrust & support blocks
STD-W-35	Pipe Repair to Existing Mains
STD-W-36	Telemetry and Wet Kiosk



DRAINAGE / DUCT TRENCH AND REINSTATEMENT IN EXISTING ROADS

SCALE 1:25

ROAD REINSTATEMENT CONSTRUCTION

40mm HRA SURFACE COURSE HRA 30/14 F SURF 40/60 TO EN13108.4 & (20mm COATED CHIPPINGS TO CL915 TO WITHIN 300mm OF KERB) - TO MATCH EXISTING ON

60mm DBM BINDER COURSE AC-20 DENSE BIN 40/60 REC TO CL900.3 - TO MATCH EXISTING LAD IN 2 LAYERS ON

80mm DBM BASE COURSE AC-32 DENSE BAS 40/60 REC TO CL900.3 - TO MATCH EXISTING

CONCRETE BED TO BE C20 GRADE ST4 TO BS EN 206


2 x 12mm SOFTBOARD AT ALL JOINTS

COMPRESSIBLE MATERIAL

SUPPORT BLOCK

TABLE 1

DIAMETER OF LARGEST PIPE IN MANHOLE (mm)	CHAMBER SECTION DIAMETER (mm)
LESS THAN 375	1200
375 - 450	1350
450 - 700	1500
750 - 900	1800
> 750	PIPE SIZE + 1.3m



rev	date	description	PJC	NGC
P01	13/06/22	STAGE 3 SHD		

DBFL Consulting Engineers
Civil, Structural & Transportation Engineering
www.dbfl.ie

DUBLIN OFFICE: Ormond House, Upper Ormond Quay, Dublin 7, D07 W704
PHONE: +353 1 404 4000

CORK OFFICE: 14 South Mall, Cork, T12 CT91
PHONE: +353 21 2024538

WATERFORD OFFICE: Suite 10 The Atrium, Maritime Gate, Canada Street, Waterford, X91 W028
PHONE: +353 51 309 500

client: CAIRN HOMES PROPERTIES LTD

project ref: NEWCASTLE SOUTH

drawing title: TYPICAL DRAINAGE DETAILS SHEET 1

designed by: NCG
author: IC
scale: AS SHOWN
sheet size: A1

drawing no: 210026-DBFL-CS-SP-DR-C-5301
revision: P01