



DRAWING IS PRODUCED USING THE IRISH TRANSVERSE MERCATOR (ITM) GEOGRAPHIC COORDINATE SYSTEM

A1

ART DATA CENTRES



LEGEND:

SITE BOUNDARY	
EXISTING OH LINES TO BE REMOVED	
PROPOSED 110kV, 2x125mmØ SDR17.6 AND 3x160mmØ SDR21 HDPE DOUBLE CIRCUIT	
PROPOSED SUBSTATION COMPOUND	
EXISTING 110 kV ENNIS SUBSTATION	
PROPOSED JOINT BAY LOCATION	
PROPOSED TELECOM DUCT	
EXISTING HP GASMAIN	

P01	FOR PLANNING	PS	RG	03/06/22
Rev	Description	Drawn	Checked	Date

Clifton Scannell Emerson Associates Limited
Consulting Engineers,
3rd Floor, The Highline,
Bakers Point, Pottery Road,
Dun Laoghaire, Co. Dublin,
Ireland, A96 KW29

T: +353 1 288 5006
F: +353 1 283 3466
E: info@csea.ie
W: www.csea.ie

Client: ART DATA CENTRES
 Project: ART DATA CENTRES ENNIS
 Project: CAMPUS - 110KV GIS SUBSTATION
 Dwg. Title: PROPOSED 110 KV GRID CONNECTION LAYOUT - OVERALL

Drawn By: PS Checked By: RG Date: JUN 2022

Project Code	Originator	Zonal/Phase	Level	Type	Role	Dwg. No.
20_110A	CSE	GEN	XX	DR	C	2700

S2	PLANNING	Scale @ A1 1:2500
P01	PLANNING	20_110A
Revision	Project Status	CSEA Job No.