



GENERAL NOTES

1. ALL DIMENSIONS ARE GIVEN IN MILLIMETERS UNLESS OTHERWISE INDICATED.
2. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH THE SCOPE OF WORKS. ANY DISCREPANCIES ARE TO BE BROUGHT TO THE ATTENTION OF KELLIHERS FOR CLARIFICATION PRIOR TO ANY WORK COMMENCING.
3. CONTRACTOR TO FIELD VERIFY ALL DIMENSIONS, DISCREPANCIES ARE TO BE NOTIFIED TO THE CONTRACTOR AND DESIGN FOR RESOLUTION.
4. ALL WORKS TO COMPLY WITH PREVIOUSLY AGREED AND ISSUED SPECIFICATIONS

LEGEND

<p>Estate 1 Results - Horizontal Illuminance (lux) Eav= 8.89 Emin= 1.79 Emax= 24.80 Emin/Emax= 0.07 Emin/Eav= 0.20 Emax/Eav= 2.80</p>	<p>Spine road 2 Results - Horizontal Illuminance (lux) Eav= 11.91 Emin= 3.88 Emax= 24.85 Emin/Emax= 0.16 Emin/Eav= 0.33 Emax/Eav= 2.08</p>
<p>Estate 2 Results - Horizontal Illuminance (lux) Eav= 8.97 Emin= 1.74 Emax= 25.08 Emin/Emax= 0.07 Emin/Eav= 0.20 Emax/Eav= 2.82</p>	<p>Spine road 4 Results - Horizontal Illuminance (lux) Eav= 10.95 Emin= 4.27 Emax= 23.72 Emin/Emax= 0.18 Emin/Eav= 0.39 Emax/Eav= 2.16</p>
<p>Spine road 6 Results - Horizontal Illuminance (lux) Eav= 10.64 Emin= 2.33 Emax= 23.28 Emin/Emax= 0.10 Emin/Eav= 0.22 Emax/Eav= 2.19</p>	<p>Spine road 5 Results - Horizontal Illuminance (lux) Eav= 15.11 Emin= 6.55 Emax= 26.59 Emin/Emax= 0.25 Emin/Eav= 0.43 Emax/Eav= 1.76</p>
<p>Old Whitechurch road 2 Results - Horizontal Illuminance (lux) Eav= 12.01 Emin= 3.66 Emax= 22.77 Emin/Emax= 0.16 Emin/Eav= 0.30 Emax/Eav= 1.86</p>	<p>Spine road 3 Results - Horizontal Illuminance (lux) Eav= 11.28 Emin= 5.23 Emax= 23.10 Emin/Emax= 0.23 Emin/Eav= 0.46 Emax/Eav= 2.05</p>
<p>Old Whitechurch road 1 Results - Horizontal Illuminance (lux) Eav= 13.16 Emin= 3.66 Emax= 25.07 Emin/Emax= 0.15 Emin/Eav= 0.29 Emax/Eav= 1.91</p>	<p>Main entrance Results - Horizontal Illuminance (lux) Eav= 15.73 Emin= 6.22 Emax= 24.85 Emin/Emax= 0.28 Emin/Eav= 0.44 Emax/Eav= 1.58</p>
<p>Spine road 1 Results - Horizontal Illuminance (lux) Eav= 11.07 Emin= 2.51 Emax= 23.76 Emin/Emax= 0.11 Emin/Eav= 0.23 Emax/Eav= 2.15</p>	<p>Crèche Results - Horizontal Illuminance (lux) Eav= 12.49 Emin= 2.87 Emax= 18.35 Emin/Emax= 0.16 Emin/Eav= 0.23 Emax/Eav= 1.47</p>
<p>Luminaire Data Luminaire A TRSA-02-150-4L3082W Luminaire B TRSA-02-300-4L3082W Luminaire C TRSA-02-075-4L3082W Luminaire D TRMA-02-15011L3085W</p>	<p>Lamp 80u4L28W3K MF 0.76 Lamp 80u4L28W3K MF 0.76 Lamp 12u6L51W3K MF 0.76 Lamp 24011L53W30K MF 0.84</p>

- Key**
- Luminaire A Column
 - Luminaire B Column
 - Luminaire C Column
 - Luminaire D Column
 - Beam Aiming Target
 - Photometric Centre
- All Dimensions in metres

ISSUED FOR COUNCIL APPROVAL		DMD	PS	PS	27JUN22														
REV. NO.	REVISION DESCRIPTION	DESIGN	CHECKED	APPROVED	DATE														
<p>THIS DRAWING CONTAINS INFORMATION WHICH IS THE PROPERTY OF KELLIHERS LTD. THIS DRAWING IS ISSUED IN CONFIDENCE AND ITS CONTENTS MAY NOT BE DISCLOSED WITHOUT THE PRIOR WRITTEN CONSENT OF KELLIHERS LIMITED.</p>																			
PROJECT: KILBARRY		<p>KELLIHERS ELECTRICAL LTD. MSD BUSINESS PARK, BALLYMOUNT, DUBLIN 12</p>																	
<p>APPROVALS</p> <table border="1"> <tr><th>APPROVED</th><th>DATE</th></tr> <tr><td>DMD</td><td>27JUN22</td></tr> <tr><td>DMD</td><td>27JUN22</td></tr> <tr><td>PS</td><td>27JUN22</td></tr> <tr><td>PS</td><td>27JUN22</td></tr> <tr><td>PS</td><td>27JUN22</td></tr> <tr><td>PS</td><td>27JUN22</td></tr> </table>		APPROVED	DATE	DMD	27JUN22	DMD	27JUN22	PS	27JUN22	PS	27JUN22	PS	27JUN22	PS	27JUN22	<p>KILBARRY RESIDENTIAL CORK CITY LIGHTING LAYOUT SHEET 1 OF 2 CREE LED</p>			
APPROVED	DATE																		
DMD	27JUN22																		
DMD	27JUN22																		
PS	27JUN22																		
PS	27JUN22																		
PS	27JUN22																		
PS	27JUN22																		
REV. NO.	FILE NAME	DESIGNER	DATE	<p>KE/KBC/01 0</p>															
REV. NO.	REV. DATE	REV. BY	REV. REASON	<p>TO FIT 1/500@A0 1 - 2</p>															