



FOR CONTINUATION SEE SHEET 1

FOR CONTINUATION SEE SHEET 1

GENERAL NOTES

1. ALL DIMENSIONS ARE GIVEN IN MILLIMETERS UNLESS OTHERWISE INDICATED.
2. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH THE SCOPE OF WORKS. ANY DISCREPANCIES ARE TO BE BROUGHT TO THE ATTENTION OF KELLIHERS FOR CLARIFICATION PRIOR TO ANY WORK COMMENCING.
3. CONTRACTOR TO FIELD VERIFY ALL DIMENSIONS, DISCREPANCIES ARE TO BE NOTIFIED TO THE CONTRACTOR AND DESIGN FOR RESOLUTION.
4. ALL WORKS TO COMPLY WITH PREVIOUSLY AGREED AND ISSUED SPECIFICATIONS

LEGEND

<p>Estate 1 Results - Horizontal Illuminance (lux) Eavg= 8.89 Emin= 1.79 Emax= 24.80 Emin/Eavg= 0.07 Emin/Eavg= 0.20 Emin/Eavg= 2.80</p>	<p>Spine road 2 Results - Horizontal Illuminance (lux) Eavg= 11.91 Emin= 3.38 Emax= 24.85 Emin/Eavg= 0.16 Emin/Eavg= 0.33 Emin/Eavg= 2.08</p>
<p>Estate 2 Results - Horizontal Illuminance (lux) Eavg= 6.97 Emin= 1.74 Emax= 25.08 Emin/Eavg= 0.07 Emin/Eavg= 0.20 Emin/Eavg= 2.82</p>	<p>Spine road 4 Results - Horizontal Illuminance (lux) Eavg= 4.27 Emin= 23.72 Emin/Eavg= 0.18 Emin/Eavg= 0.39 Emin/Eavg= 2.16</p>
<p>Spine road 6 Results - Horizontal Illuminance (lux) Eavg= 10.64 Emin= 2.33 Emax= 23.28 Emin/Eavg= 0.10 Emin/Eavg= 0.22 Emin/Eavg= 2.19</p>	<p>Spine road 5 Results - Horizontal Illuminance (lux) Eavg= 15.11 Emin= 6.25 Emin/Eavg= 0.25 Emin/Eavg= 0.43 Emin/Eavg= 1.76</p>
<p>Old Whitechurch road 2 Results - Horizontal Illuminance (lux) Eavg= 12.21 Emin= 3.66 Emin/Eavg= 0.16 Emin/Eavg= 0.30 Emin/Eavg= 1.86</p>	<p>Spine road 3 Results - Horizontal Illuminance (lux) Eavg= 11.28 Emin= 5.23 Emin/Eavg= 0.23 Emin/Eavg= 0.46 Emin/Eavg= 2.05</p>
<p>Old Whitechurch road 1 Results - Horizontal Illuminance (lux) Eavg= 13.16 Emin= 3.99 Emin/Eavg= 0.15 Emin/Eavg= 0.29 Emin/Eavg= 1.91</p>	<p>Main entrance Results - Horizontal Illuminance (lux) Eavg= 15.73 Emin= 6.29 Emin/Eavg= 0.28 Emin/Eavg= 0.44 Emin/Eavg= 1.58</p>
<p>Spine road 1 Results - Horizontal Illuminance (lux) Eavg= 11.07 Emin= 2.51 Emin/Eavg= 0.11 Emin/Eavg= 0.23 Emin/Eavg= 2.15</p>	<p>Crèche Results - Horizontal Illuminance (lux) Eavg= 12.47 Emin= 2.87 Emin/Eavg= 0.16 Emin/Eavg= 0.33 Emin/Eavg= 1.47</p>

<p>Luminaire Data Luminaire A TRSA-02-150-4L30828W Luminaire B TRSA-02-300-4L30828W Luminaire C TRSA-02-075-4L30828W Luminaire D TRMA-02-15011L30853W</p>	<p>Lamp 80u4L28W3K MF 0.76 Lamp 80u4L28W3K MF 0.76 Lamp 12u4L21W3K MF 0.76 Lamp 24D11L53W30K MF 0.84</p>
--	--

Key

- Luminaire A Column
- Luminaire B Column
- Luminaire C Column
- Luminaire D Column
- Beam Aiming Target
- Photometric Centre

All Dimensions in metres

ISSUED FOR COUNCIL APPROVAL		DMD	PS	PS	27JUN22
REV	NO	REVISION DESCRIPTION	DESIGN	CHECKED	APPROVED DATE
<p>THIS DRAWING CONTAINS INFORMATION WHICH IS THE PROPERTY OF KELLIHERS LTD. THIS DRAWING IS RELEASED IN CONFIDENCE AND ITS CONTENTS MAY NOT BE DISCLOSED WITHOUT THE PRIOR WRITTEN CONSENT OF KELLIHERS LIMITED.</p>					
PROJECT:		KILBARRY			
		KELLIHERS ELECTRICAL LTD. MSD BUSINESS PARK, BALLYMOUNT, DUBLIN 12			
APPROVALS		DATE			
DESIGNED	DMD	27JUN22			
REVIEWED	DMD	27JUN22			
QUANTITY	PS	27JUN22			
CHECKED	PS	27JUN22			
APPROVED	PS	27JUN22			
DATE	PS	27JUN22			
REV	NO	REVISION DESCRIPTION	DESIGN	CHECKED	APPROVED DATE
01	01	ISSUED FOR COUNCIL APPROVAL	DMD	PS	27JUN22

PROJECT:		KILBARRY			
		KELLIHERS ELECTRICAL LTD. MSD BUSINESS PARK, BALLYMOUNT, DUBLIN 12			
APPROVALS		DATE			
DESIGNED	DMD	27JUN22			
REVIEWED	DMD	27JUN22			
QUANTITY	PS	27JUN22			
CHECKED	PS	27JUN22			
APPROVED	PS	27JUN22			
DATE	PS	27JUN22			
REV	NO	REVISION DESCRIPTION	DESIGN	CHECKED	APPROVED DATE
01	01	ISSUED FOR COUNCIL APPROVAL	DMD	PS	27JUN22