

Option E - Clear Span - 110kV

Finished Surface capped Yellow Marker Warning tape across full width of trench with clause 804 material. ESBN red cable marker Clause 804 material to be used and compacted in accordance with NRA Galvanised steel plate auidelines in layers not arrangement A393 Steel mesh for width of trench 150 -100 Complete with 12mm Diameter draw ropes. 125mm Comm Ducts CBGMB Clause 822 .. material Existing Ground Level Competent Stratum

Option E - Clear Span - 110kV
SCALE 1:50

Option E - Clear Span - 110kV PROJECT TITLE Knocknamork Grid Connection Infrastructure, An Bord Pleanala DRAWING BY: Joseph O Brien PROJECT NO... 210732 PROJECT NO... 210732 PROJECT NO... 210732 DRAWING NO... 210732 - 24 SCALE: 1:50 @ A3 DATE: 26.07.2022

