



LP-05-PP

- Luminaire A Column
- Luminaire B Column
- Luminaire C Column
- Luminaire D Column
- 6 SQ.MM NYCY CABLE IN 100MM RED DUCT
- UNMETERED LIGHTING SUPPLY PILLAR

LUMINAIRE DATA

LUMINAIRE A 59W 10.5KLM
PHILIPS LUMA MINI NEUTRAL WHITE
BGP703 DW50 CLD POST TOP
MOUNTED Ø7/Ø10M WITH 7-PIN
VESTIRE OR EQUIVALENT
PHOTOCCELL

LUMINAIRE B 16W 2.8KLM
PHILIPS LUMA NANO 2200K BGP701
DW10 CLD MOUNTED Ø6M WITH
7-PIN VESTIRE OR EQUIVALENT
PHOTOCCELL

LUMINAIRE C 9W 2.0KLM
PHILIPS LUMA NANO WARM WHITE
BGP701 DW10 CLD MOUNTED Ø5M
WITH 7-PIN VESTIRE OR
EQUIVALENT PHOTOCCELL

LUMINAIRE D 14W 2.4KLM
PHILIPS LUMA NANO 2200K BGP701
DW10 CLD MOUNTED Ø5M WITH
7-PIN VESTIRE OR EQUIVALENT
PHOTOCCELL



REVISION	INFORMATION 4
1	22/08/2022
2	1:1000-A1
3	James Molloy Jnr
4	James Molloy Sr

MOLLOY CONSULTING ENGINEERS
Cahercalla Road,
Ennis,
Co.Clare.
Tel: 065-6891950. Mob: 086-3152764. Email: james@mollyconsulting.ie

Public Lighting Layout 3	Glenveagh Properties PLC.	Proposed Development, Circular Rd, Ennis, Co. Clare.	PL2189-E-102-14
--------------------------	---------------------------	--	-----------------