



**A1**



- Luminaire A Column
  - Luminaire B Column
  - Luminaire C Column
  - Luminaire D Column
  - 6 SQ.MM NYCY CABLE IN 100MM RED DUCT
  - UNMETERED LIGHTING SUPPLY PILLAR
- LUMINAIRE DATA**
- LUMINAIRE A** 59W 10.5KLM  
PHILIPS LUMA MINI NEUTRAL WHITE  
BGP703 DW50 CLD POST TOP  
MOUNTED @7.8/10M WITH 7-PIN  
WESTIRE OR EQUIVALENT  
PHOTOCCELL
- LUMINAIRE B** 16W 2.8KLM  
PHILIPS LUMA NANO 2200K BGP701  
DW10 CLD MOUNTED @6M WITH  
7-PIN WESTIRE OR EQUIVALENT  
PHOTOCCELL
- LUMINAIRE C** 9W 2.0KLM  
PHILIPS LUMA NANO WARM WHITE  
BGP701 DW10 CLD MOUNTED @5M  
WITH 7-PIN WESTIRE OR  
EQUIVALENT PHOTOCCELL
- LUMINAIRE D** 14W 2.4KLM  
PHILIPS LUMA NANO 2200K BGP701  
DW10 CLD MOUNTED @5M WITH  
7-PIN WESTIRE OR EQUIVALENT  
PHOTOCCELL



REVISION	INFORMATION 4
DATE	22/08/2022
SCALE	1:1000---A1
DRAWN	James Molloy Jnr
CHECKED	James Molloy Sr

**MOLLOY CONSULTING ENGINEERS**  
Cahercalla Road,  
Ennis,  
Co.Clare.  
Tel: 065-6891950. Mob: 086-3152764. Email: james@mollyconsulting.ie

PROJECT	CLIENT	DATE	DRAWN BY
Public Lighting Layout 4	Glenveagh Properties PLC.	22/08/2022	James Molloy Jnr
Proposed Development, Circular Rd, Ennis, Co. Clare.		PL2189-E-103-14	