

DONORE PROJECT, DONORE AVENUE, DUBLIN 8

CLIENT


THE LAND DEVELOPMENT AGENCY

CONSULTANT

AECOM 4th Floor Adelphi Plaza, George's Street Upper, Dun Laoghaire, Co Dublin Tel:+353 (0)1 696-6220 www.aecom.com

THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL OTHER RELEVANT ARCHITECTURAL AND ENGINEERING DRAWINGS, ANY DISCREPANCIES, ERRORS OR OMISSIONS TO BE BROUGHT TO THE ATTENTION OF THE DESIGNER.

- ALL DIMENSIONS TO BE CHECKED BY THE CONTRACTOR ON SITE PRIOR TO COMMENCEMENT OF WORKS.
- AECOM LIMITED TO BE INFORMED BY THE CONTRACTOR OF ANY DISCREPANCIES PRIOR TO THE COMMENCEMENT OF WORKS ON SITE.
- DIMENSIONS OF ALL BOUNDARIES AND ADJOINING ROADS TO BE CHECKED ON SITE PRIOR TO COMMENCEMENT OF
- DO NOT SCALE. ALL MEASUREMENTS AND CO-ORDINATES TO BE CHECKED ON SITE.
- CONTRACTOR TO REQUEST EXISTING RECORD DRAWINGS PRIOR TO COMMENCEMENT OF WORKS.
- REFER TO IRISH WATER STANDARD DETAILS STD-W-12A AND STD-WW-06A FOR GUIDANCE ON PLANTING IN PROXIMITY TO WATERMAIN SERVICES.
- THE LOCATION & DEPTH OF SERVICES TO BE CHECKED ON SITE PRIOR TO COMMENCING ANY WORKS.
- THE DEVELOPMENT SHALL HAVE A BULK WATER METER (EXACT LOCATION TO BE AGREED WITH IRISH WATER) IN ACCORDANCE WITH IRISH WATER CODE OF PRACTICE SECTION 3.15.4.
- 10. ALL PROPOSED WATERMAIN PIPEWORK TO BE HDPE WITH MINIMUM PE80 RATING IN ACCORDANCE WITH IRISH WATER CODE OF PRACTICE FOR WATER INFRASTRUCTURE.
- 11. THE MINIMUM PIPE DIAMETER PROPOSED IS 100mm.
- 12. ALL WATERMAINS WILL HAVE A MINIMUM COVER OF 900mm. ALL SERVICE PIPES CONNECTING PROPERTIES WILL HAVE MINIMUM COVER OF 750mm.
- HYDRANTS SHALL BE DOUBLE FLANGED DRILLED TO PN16 AND SHALL COMPLY WITH BS EN 14339. IS EN 1074 PART 6 AND 135 750. REFER TO IRISH WATER CODE OF PRACTICE FOR WATER INFRASTRUCTURE SECTION 3.16.5.
- 14. SLUICE VALVES HAVE BEEN PROVIDED SO THAT INDIVIDUAL SECTIONS CAN BE ISOLATED & WILL COMPLY TO BS 5163. THE DEPTH OF THE SLUICE VALVE SPINDLE CAP BELOW FINISHED GROUND WILL NOT EXCEED 300mm
- 15. ALL WATERMAIN DETAILS TO BE IN ACCORDANCE WITH THE IRISH WATER CODE OF PRACTICE FOR WATER INFRASTRUCTURE.
- 16. HYDRANTS LOCATION & THE HYDRANT TYPE IS TO BE DETERMINED IN ACCORDANCE WITH DUBLIN CITY COUNCIL, IRISH WATER & THE CHIEF FIRE OFFICER'S REQUIREMENTS.
- 17. PROPOSED TREES WITHIN LANDSCAPED AREA TO BE PROVIDED WITH ROOT PROTECTION SYSTEM WITH NA
- APPROXIMATE DEPTH OF 1m. B. THIS DESIGN DRAWING HAS BEEN DEVELOPED USING THE FOLLOWING TOPOGRAPHICAL SURVEYS; LDA SURVEY





0	18.11.2022	ISSUED FOR PLANNING
I/R	DATE	DESCRIPTION

PROJECT NUMBER

SHEET TITLE

PROPOSED WATER SUPPLY LAYOUT

SHEET NUMBER

STG-AEC-S1b-00-00-DR-C-0002701