



APPENDIX 11-5

*NOISE LEVELS AT NOISE SENSITIVE
LOCATIONS*

House ID	Description	Predicted Noise Level dB LA90 at Standardised Wind Speed at 10m _{A.G.L.}						
		3	4	5	6	7	8	≥9
H1	Dwelling	22.0	24.7	28.4	31.8	33.2	33.2	33.2
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H2	Dwelling	21.5	24.8	29.1	32.8	34.1	34.1	34.1
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H3	Dwelling	23.6	26.9	31.2	34.9	36.2	36.2	36.2
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H4	Dwelling	25.3	28.6	33.0	36.7	37.9	37.9	37.9
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H5	Dwelling	23.2	26.5	30.8	34.5	35.8	35.8	35.8
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0

House ID	Description	Predicted Noise Level dB LA90 at Standardised Wind Speed at 10m _{A.G.L.}						
		3	4	5	6	7	8	≥9
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H6	Dwelling	19.7	22.9	27.2	30.9	32.2	32.2	32.2
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H7	Dwelling	17.9	21.2	25.5	29.1	30.4	30.4	30.4
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H8	Dwelling	17.6	20.9	25.1	28.8	30.1	30.1	30.1
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H9	Dwelling	18.7	22.0	26.3	30.0	31.3	31.3	31.3
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0

House ID	Description	Predicted Noise Level dB LA90 at Standardised Wind Speed at 10m _{A.G.L.}						
		3	4	5	6	7	8	≥9
	Potential Night time Exceedance	--	--	--	--	--	--	--
H10	Dwelling	19.2	22.4	26.7	30.4	31.7	31.7	31.7
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H11	Dwelling	22.0	25.3	29.7	33.3	34.6	34.6	34.6
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H12	Dwelling	23.0	26.3	30.7	34.3	35.6	35.6	35.6
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H13	Dwelling	26.8	30.1	34.5	38.1	39.4	39.4	39.4
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--

House ID	Description	Predicted Noise Level dB LA90 at Standardised Wind Speed at 10m _{A.G.L.}						
		3	4	5	6	7	8	≥9
H14	Dwelling	27.2	30.5	34.8	38.5	39.8	39.8	39.8
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H15	Dwelling	21.0	24.3	28.6	32.3	33.5	33.6	33.6
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H16	Dwelling	21.0	24.2	28.5	32.1	33.4	33.4	33.4
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H17	Dwelling	24.5	27.8	32.0	35.7	37.0	37.0	37.0
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H18	Dwelling	24.5	27.7	32.0	35.6	36.9	36.9	36.9
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0

House ID	Description	Predicted Noise Level dB LA90 at Standardised Wind Speed at 10m _{A.G.L.}						
		3	4	5	6	7	8	≥9
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H19	Dwelling	24.4	27.7	32.0	35.6	36.9	36.9	36.9
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H20	Dwelling	24.3	27.6	31.9	35.6	36.9	36.9	36.9
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H21	Dwelling	23.8	27.1	31.3	35.0	36.3	36.3	36.3
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H22	Dwelling	23.1	26.4	30.7	34.4	35.7	35.7	35.7
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0

House ID	Description	Predicted Noise Level dB LA90 at Standardised Wind Speed at 10m _{A.G.L.}						
		3	4	5	6	7	8	≥9
	Potential Night time Exceedance	--	--	--	--	--	--	--
H23	Dwelling	22.5	25.8	30.1	33.8	35.1	35.1	35.1
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H24	Dwelling	22.5	25.8	30.1	33.7	35.0	35.0	35.0
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H25	Dwelling	21.1	24.4	28.7	32.3	33.6	33.7	33.7
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H26	Dwelling	20.5	23.7	28.0	31.7	33.0	33.0	33.0
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--

House ID	Description	Predicted Noise Level dB LA90 at Standardised Wind Speed at 10m _{A.G.L.}						
		3	4	5	6	7	8	≥9
H27	Dwelling	23.0	26.3	30.6	34.2	35.5	35.5	35.5
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H28	Dwelling	21.7	25.0	29.3	32.9	34.2	34.3	34.3
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H29	Dwelling	20.4	23.6	27.9	31.5	32.8	32.9	32.9
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H30	Dwelling	21.9	25.1	29.4	33.1	34.4	34.4	34.4
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H31	Dwelling	21.6	24.9	29.2	32.8	34.1	34.1	34.1
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0

House ID	Description	Predicted Noise Level dB LA90 at Standardised Wind Speed at 10m _{A.G.L.}						
		3	4	5	6	7	8	≥9
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H32	Dwelling	20.8	24.1	28.3	32.0	33.3	33.3	33.3
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H33	Dwelling	21.2	24.3	28.5	32.2	33.5	33.5	33.5
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H34	Dwelling	20.6	23.9	28.1	31.8	33.1	33.1	33.1
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H35	Dwelling	20.2	23.4	27.7	31.3	32.6	32.7	32.7
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0

House ID	Description	Predicted Noise Level dB LA90 at Standardised Wind Speed at 10m _{A.G.L.}						
		3	4	5	6	7	8	≥9
	Potential Night time Exceedance	--	--	--	--	--	--	--
H36	Dwelling	19.0	22.3	26.5	30.2	31.5	31.5	31.5
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H37	Dwelling	18.9	22.1	26.3	30.0	31.3	31.3	31.3
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H38	Dwelling	18.1	21.0	24.8	28.5	29.9	30.0	30.0
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H39	Dwelling	18.0	20.5	23.8	27.6	29.0	29.3	29.3
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--

House ID	Description	Predicted Noise Level dB LA90 at Standardised Wind Speed at 10m _{A.G.L.}						
		3	4	5	6	7	8	≥9
H40	Dwelling	16.6	19.5	23.4	27.1	28.4	28.5	28.5
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H41	Dwelling	17.9	20.3	23.5	27.2	28.7	29.1	29.1
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H42	Dwelling	17.5	20.1	23.6	27.3	28.8	29.0	29.0
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H43	Dwelling	16.3	19.1	22.9	26.5	27.9	28.1	28.1
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H44	Dwelling	16.2	19.2	23.2	26.8	28.2	28.3	28.3
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0

House ID	Description	Predicted Noise Level dB LA90 at Standardised Wind Speed at 10m _{A.G.L.}						
		3	4	5	6	7	8	≥9
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H45	Dwelling	17.4	20.6	24.8	28.5	29.8	29.8	29.8
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H46	Dwelling	17.5	20.7	24.8	28.5	29.8	29.9	29.9
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H47	Dwelling	17.8	20.9	25.1	28.7	30.1	30.1	30.1
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H48	Dwelling	16.9	19.9	23.9	27.6	29.0	29.1	29.1
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0

House ID	Description	Predicted Noise Level dB LA90 at Standardised Wind Speed at 10m _{A.G.L.}						
		3	4	5	6	7	8	≥9
	Potential Night time Exceedance	--	--	--	--	--	--	--
H49	Dwelling	16.8	19.7	23.6	27.3	28.6	28.8	28.8
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H50	Dwelling	16.4	19.1	22.8	26.5	27.9	28.2	28.2
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H51	Dwelling	14.9	17.8	21.8	25.4	26.8	26.9	26.9
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H52	Dwelling	14.1	17.0	20.9	24.6	25.9	26.0	26.0
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--

House ID	Description	Predicted Noise Level dB LA90 at Standardised Wind Speed at 10m _{A.G.L.}						
		3	4	5	6	7	8	≥9
H53	Dwelling	13.2	16.3	20.3	24.0	25.3	25.4	25.4
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H54	Dwelling	13.6	16.7	20.7	24.4	25.7	25.8	25.8
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H55	Dwelling	14.7	17.5	21.3	25.0	26.3	26.5	26.5
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H56	Dwelling	13.2	16.4	20.5	24.2	25.5	25.5	25.5
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H57	Dwelling	19.9	22.4	25.6	28.8	30.3	30.3	30.3
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0

House ID	Description	Predicted Noise Level dB LA90 at Standardised Wind Speed at 10m _{A.G.L.}						
		3	4	5	6	7	8	≥9
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H58	Dwelling	20.0	22.6	25.8	29.0	30.5	30.6	30.6
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H59	Dwelling	21.7	23.9	26.6	29.4	31.1	31.1	31.1
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H60	Dwelling	19.4	22.2	25.7	29.1	30.5	30.5	30.5
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H61	Dwelling	19.9	22.4	25.6	28.7	30.2	30.3	30.3
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0

House ID	Description	Predicted Noise Level dB LA90 at Standardised Wind Speed at 10m _{A.G.L.}						
		3	4	5	6	7	8	≥9
	Potential Night time Exceedance	--	--	--	--	--	--	--
H62	Dwelling	20.4	22.7	25.8	28.9	30.5	30.5	30.5
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H63	Dwelling	19.8	22.1	25.0	28.0	29.6	29.6	29.6
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H64	Dwelling	19.8	22.2	25.3	28.3	29.9	29.9	29.9
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H65	Dwelling	19.8	22.2	25.3	28.4	30.0	30.0	30.0
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--

House ID	Description	Predicted Noise Level dB LA90 at Standardised Wind Speed at 10m _{A.G.L.}						
		3	4	5	6	7	8	≥9
H66	Dwelling	19.7	22.1	25.2	28.2	29.8	29.8	29.8
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H67	Dwelling	19.8	22.3	25.5	28.6	30.1	30.1	30.1
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H68	Dwelling	19.6	22.0	25.0	28.0	29.6	29.6	29.6
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H69	Dwelling	19.5	21.8	24.7	27.7	29.3	29.4	29.4
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H70	Dwelling	19.4	21.8	24.7	27.7	29.3	29.3	29.3
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0

House ID	Description	Predicted Noise Level dB LA90 at Standardised Wind Speed at 10m _{A.G.L.}						
		3	4	5	6	7	8	≥9
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H71	Dwelling	19.5	21.8	24.7	27.7	29.3	29.4	29.4
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H72	Dwelling	19.4	21.7	24.6	27.6	29.2	29.3	29.3
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H73	Dwelling	19.6	21.8	24.7	27.6	29.2	29.3	29.3
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H74	Dwelling	19.6	21.9	24.8	27.8	29.4	29.4	29.4
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0

House ID	Description	Predicted Noise Level dB LA90 at Standardised Wind Speed at 10m _{A.G.L.}						
		3	4	5	6	7	8	≥9
	Potential Night time Exceedance	--	--	--	--	--	--	--
H75	Dwelling	19.4	21.7	24.5	27.5	29.1	29.2	29.2
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H76	Dwelling	19.4	21.6	24.5	27.5	29.1	29.2	29.2
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H77	Dwelling	23.2	25.3	27.7	30.3	32.0	32.1	32.1
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H78	Dwelling	23.1	25.2	27.6	30.2	32.0	32.0	32.0
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--

House ID	Description	Predicted Noise Level dB LA90 at Standardised Wind Speed at 10m _{A.G.L.}						
		3	4	5	6	7	8	≥9
H79	Dwelling	23.1	25.2	27.7	30.3	32.0	32.1	32.1
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H80	Dwelling	23.1	25.2	27.7	30.3	32.0	32.0	32.0
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H81	Dwelling	17.6	19.9	22.8	25.9	27.4	27.5	27.5
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H82	Dwelling	17.7	20.2	23.4	26.6	28.1	28.1	28.1
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--
H83	Dwelling	16.7	18.9	21.9	25.6	27.1	27.6	27.6
	Daytime Limits	45.0	45.0	45.0	45.0	45.0	45.0	45.0

House ID	Description	Predicted Noise Level dB LA90 at Standardised Wind Speed at 10m _{A.G.L.}						
		3	4	5	6	7	8	≥9
	Potential Daytime Exceedance	--	--	--	--	--	--	--
	Night Limits	43.0	43.0	43.0	43.0	43.0	43.0	43.0
	Potential Night time Exceedance	--	--	--	--	--	--	--