




**DISCLAIMER:**  
 TODD Architects confirms that recipient can rely only on approved controlled documents for construction projects. Controlled documents for use include original hard copy drawings issued by TODD Architects, or unprinted PDF/IMG images of drawings received from TODD Architects.  
 TODD Architects cannot ensure the accuracy of drawings, used in an uncontrolled document format which may be altered or reproduced as a result of human error on the part of the recipient, or as a result of the incompatibility of computer systems when opening or printing computer-aided drawings. Uncontrolled documents format include, computer-aided design files, prints which have been issued by the recipient from non-controlled files, photographs of original hard copy drawings from TODD Architects, or drawings supplied to TODD Architects for information purposes only.  
 TODD Architects accept no responsibility for any loss or damage arising as a result of reliance by the recipient on any third party uncontrolled document format, reliance upon which will be entirely at the risk of the recipient.  
 Contractors are responsible for the verification of all dimensions on site and the customer is to take account of any discrepancy.  
 Do not scale from this drawing.  
 Use figured dimensions only.



- LEGEND:**
- SITE BOUNDARY
  - TOTAL AREA 13.630Acre (55162.0925sqm)**
  - OVERHEAD LINES
  - EXISTING GAS LINE
  - BLUE LINE BOUNDARY FOR EXISTING OCGT APPLICATION ABP APPEAL REF: 313538-22
  - AGI & SUBSTATION - Subject To Detailed Design And Consent By Others
  - PROPOSED FENCING TO MATCH EXISTING
  - - - LOCATION OF PROPOSED ACCESS GATE

- PROPOSED FUEL OIL SUPPLY
- PROPOSED FUEL TREATMENT
- PROPOSED FUEL OIL STORAGE
- PROPOSED GAS SUPPLY FROM AGI TO OCGT
- PROPOSED FUEL UNLOADING
- AGI AND ADDITIONAL SUBSTATION BAY - SUBJECT TO DETAILED DESIGN AND CONSENT BY OTHERS
- PROPOSED DELMIN TANK
- PROPOSED FIREWATER TANK & PUMPHOUSE
- EXISTING SUBSURFACE GAS LINE
- ABP Appeal Ref: 313538-22

- PROPOSED OVERHEAD LINES
- PROPOSED PUMP OUT KIOSK
- PROPOSED GAS SKID
- PROPOSED PROPANE STORE
- PROPOSED FENCE TO MATCH EXISTING
- PROPOSED ACOUSTIC BARRIER 10m HIGH
- PROPOSED CO2 FIRE FIGHTING SKID
- PROPOSED STACK
- ACOUSTIC BARRIER 7m HIGH
- PROPOSED DISTILLATE FUEL SKID
- PROPOSED FIN FAN COOLERS
- PROPOSED GT ENCLOSURE
- PROPOSED LUBE OIL SKID
- PROPOSED GANTRY
- PROPOSED HARDSTANDING MAINTENANCE AREA
- PROPOSED AIR INTAKE
- PROPOSED ELECTRICAL ROOMS
- PROPOSED MAIN TRANSFORMER
- PROPOSED CIRCUIT BREAKER
- PROPOSED SWITCHYARD
- PROPOSED ANCILLARY TRANSFORMERS
- PROPOSED ACOUSTIC BARRIER 8m HIGH
- PROPOSED AUX TRANSFORMER

**1 Proposed Site Plan Tynagh OCGT**  
 1: 500