



A = 125mm: Outer Diameter HDPE ESB Approved Duct, SDR=17.6
 B = 160mm : Outer Diameter HDPE ESB Approved Duct, SDR= 21
 C = 63mm: ECC Earth Continuity Conductor

110kV Ducting in Access Track (with ECC duct)

SCALE 1:10

ALL REINSTATEMENT WORKS ARE TO BE IN ACCORDANCE WITH LANDOWNER REQUIREMENTS

Reinstatement details based on Guidelines for Managing Openings in Public Roads - SD14

Note:

- This drawing is subject to ESB design approval and should not be used for construction.
- This drawing is to be read in conjunction with relevant drawings, specifications and reports.
- Dimensions are in millimeters, unless noted otherwise.
- Drawings are not to be scaled use figured dimensions only.



Head Office
 Beenreigh,
 Abbeydorney,
 Tralee, Co. Kerry
 Ireland
 Tel: 00353 66 7135710



CLIENT
 PROJECT
 110kV Baldonnell Substation

PROJECT NUMBER
 05-868

SHEET NUMBER
 05868-DR-006

SHEET TITLE
 110kV Ducting in Access Track
 With ECC Duct

DRAWING STATUS
 For Planning

ISSUE/REVISION		
I/R	DATE	DESCRIPTION
P3	19.05.23	Issued for Planning
P2	15.03.23	Issued for Planning
P1	24.02.23	Issued for Planning