

A = 125mm: Outer Diameter HDPE ESB Approved Duct, SDR=17.6 (Power) [ESB Code: 9317552]  
 B = 125mm: Outer Diameter HDPE ESB Approved Duct, SDR=17.6 (Comms) [ESB Code: 9317552]



**Note:**

- This drawing is subject to ESB design approval and should not be used for construction.
- This drawing is to be read in conjunction with relevant drawings, specifications and reports
- Dimensions are in millimeters, unless noted otherwise
- Drawings are not to be scaled use figured dimensions only

**ALL REINSTATEMENT WORKS ARE TO BE IN ACCORDANCE WITH LANDOWNER REQUIREMENTS**

Reinstatement details based on Guidelines for Managing Openings in Public Roads - SD14

**Typical Section Through Access Track**  
**SCALE 1:10**

 <p>Head Office                  Beenreigh,                  Abbeydorney,                  Tralee, Co. Kerry                  Ireland                  Tel: 00353 66 7135710</p>	<p>CLIENT</p> 	<p>PROJECT</p> <p><b>Coumragappul Wind Farm</b></p> <p>110kV Grid Connection</p>	<p>SHEET TITLE</p> <p><b>110kV Ducting Through Access Track</b></p>	<p>ISSUE/REVISION</p>								
		<p>PROJECT NUMBER</p> <p><b>05-828</b></p>	<p>SHEET NUMBER</p> <p><b>05828-DR-151</b></p>	<p>DRAWING STATUS</p> <p><b>For Planning</b></p>	<table border="1"> <tr> <td></td> <td></td> <td></td> </tr> <tr> <td>P1</td> <td>13.01.2023</td> <td>Issued For Planning</td> </tr> <tr> <td>I/R</td> <td>DATE</td> <td>DESCRIPTION</td> </tr> </table>				P1	13.01.2023	Issued For Planning	I/R
P1	13.01.2023	Issued For Planning										
I/R	DATE	DESCRIPTION										