



A = 125mm: Outer Diameter HDPE ESB Approved Duct, SDR=17.6 (Power) [ESB Code: 9317552]
 B = 125mm: Outer Diameter HDPE ESB Approved Duct, SDR=17.6 (Comms) [ESB Code: 9317552]
 C = 63mm: ECC Earth Continuity Conductor [ESB Code: 9317552]

Note:

- This drawing is subject to ESB design approval and should not be used for construction.
- This drawing is to be read in conjunction with relevant drawings, specifications and reports.
- Dimensions are in millimeters, unless noted otherwise.
- Drawings are not to be scaled use figured dimensions only.

ALL REINSTATEMENT WORKS ARE TO BE IN ACCORDANCE WITH LANDOWNER REQUIREMENTS

Reinstatement details based on Guidelines for Managing Openings in Public Roads - SD14

110kV Ducting in Access Track (with ECC duct)
SCALE 1:10

ISSUE/REVISION		
I/R	DATE	DESCRIPTION
P2	30.08.2023	For Planning
P1	13.01.2023	For Planning