



A = 160mm: Outer Diameter HDPE ESB Approved Duct, SDR=21 (Power) [ESB Code: 9317552]  
 B = 125mm: Outer Diameter HDPE ESB Approved Duct, SDR=17.6 (Comms) [ESB Code: 9317552]  
 C = 63mm: ECC Earth Continuity Conductor [ESB Code: 9317552]

### Section Through Off Road Sections

SCALE 1:10

**Note:**

- This drawing is to be read in conjunction with relevant drawings, specifications and reports
- Dimensions are in millimeters, unless noted otherwise
- Drawings are not to be scaled use figured dimensions only

**ALL REINSTATEMENT WORKS ARE TO BE IN ACCORDANCE WITH LANDOWNER REQUIREMENTS**

Reinstatement details based on Guidelines for Managing Openings in Public Roads - SD14



Head Office  
 Beenreigh,  
 Abbeydorney,  
 Tralee, Co. Kerry  
 Ireland  
 Tel: 00353 66 7135710

CLIENT



PROJECT

Carrownagowan Wind Farm  
 110kV Grid Connection

PROJECT NUMBER  
 05-641

SHEET NUMBER  
 05641-221

SHEET TITLE

Ducting through Off Road Sections

DRAWING STATUS  
 For Planning

ISSUE/REVISION

I/R	DATE	DESCRIPTION
P4	01.06.23	Issued for Planning
P3	02.12.22	Issued for Planning
P2	19.05.20	Issued for Planning
P1	29.11.19	Issued for Planning