

4 x 400mm wide ESBN yellow warning tape across full width of trench [ESB Code: 2955092]

C25/30 concrete to be in accordance with Specification for Road Works Series 1000. 20mm Max Size of Aggregate, with minimum duct spacing of 75mm.

A = 125mm: Outer Diameter HDPE ESB Approved Duct, SDR=17.6
B= 160mm: Outer Diameter HDPE ESB Approved Duct, SDR=21.0

C = 63mm: ECC Earth Continuity Conductor

Section Through Ducting in Flat Formation

SCALE 1:10

Note:

- This drawing is to be read in conjunction with relevant drawings, specifications and reports
- Dimensions are in millimeters, unless noted otherwise
- Drawings are not to be scaled use figured dimensions only

ALL REINSTATEMENT WORKS ARE TO BE IN ACCORDANCE WITH LOCAL AREA ENGINEERS LANDOWNERS REQUIREMENTS AND GUIDELINES FOR MANAGING OPENINGS IN PUBLIC ROADS



Head Office Beenreigh, Abbeydorney, Tralee, Co. Kerry Ireland Tel: 00353 66 7135710 CLIENT

Futur=nergy

Carrownagowan Wind Farm
I 10kV Grid Connection

PROJECT NUMBER SHEET NUMBER 05-641 05641-228

SHEET TITLE

Section Through Ducting in Flat Formation

DRAWING STATUS

For Information

ISSUE/REVISION		
P4	01.06.23	Issued for Planning
P3	02.12.22	Issued for Planning
P2	19.05.20	Issued for Planning
P1	29.11.19	Issued for Planning
I/R	DATE	DESCRIPTION