

LOCATION OF SITE NOTICE 44 30 31/32 38 © 2022 Microsoft Notes Where multiple cable route options exist, a distinction between the preferred and alternative(s) is made as indicated by the legend. Where possible all alternative routes are presented on a single sheet. However, where space does not permit this, alternative route(s) are presented on multiple sheets. The location of the cable infrastructure indicated may change within the proposed development boundary. The Proposed Development boundary remains in the curtilage of the public road / carriageway, unless an agreement with the landowner has been entered into for an off-line section. Refer to drawing 281240-ARP-ONS-CR-DR-PL-3009 for typical layout of Horizontal Directional Drilling (HDD) compounds. Refer to Water Crossing Schedule on drawing 281240-ARP-ONS-XX-DR-PL-3003. Refer to drawings 281240-ARP-OFS-OA-DR-PL-1010 and 281240-ARP-OFS-OA-DR-PL-1011 for details of proposed Offshore Export Cable. The Onshore Cable consists of two (2) trefoil formations laid side by side, refer to drawings 281240-ARP-ONS-XX-DR-PL-3000 to 281240-ARP-ONS-XX-DR-PL-3013 for details. Spacing between berge or cables to be provided at HDD leastings in accordance with HDD 2 Spacing between bores or cables to be provided at HDD locations in accordance with HDD requirements. 8 Exact Location of cable / joint bays (incl. numbers) in the road curtilage to be subject to ESB / Eirgrid specifications and agreement with Fingal County Council. LOCATION OF SITE NOTICE Scale at A1 1:1000 @ A1, 1:2000 @ A3 Drawing Title Role Civil Proposed Cable Route Map Suitability A2 - Approved for Planning Sheet 39 of 64 Arup Job No Rev 281240 C01 Name 281240-ARP-ONS-CR-DR-PL-1139 © Arup