

Statutory Particulars

Shannon Technology and Energy Park (STEP)
220kV Grid Connection

July 2024




Shannon Technology and Energy Park (STEP) 220kV Grid Connection

Contents of Statutory Particulars

1	SID Application Form
2	Copy of Site Notice
3	Copy of Newspaper Notices
4	ABP SID Pre-application Determination Notice (including the Board's Direction)
5	Prescribed Bodies Schedule & Notification Letters
6	EIA Portal Confirmation
7	Schedule of Drawings





An
Bord
Pleanála

Application Form for Permission / Approval in respect of a Strategic Infrastructure Development

1.

Please specify the statutory provision under which your application is being made:	Section 182A of the Planning and Development Act, 2000 (as amended)
--	---

2. **Applicant:**

Name of Applicant:	Shannon LNG Limited
Address:	Listowel Business Centre 27 Market Street, Listowel, Co. Kerry, V31 Y436 Ireland
Telephone No:	068-53427
Email Address (if any):	mahern@newfortressenergy.com

3. **Where Applicant is a company (registered under the Companies Acts):**

Name(s) of company director(s):	Paddy Power Christopher S. Guinta (USA) John A. R. Finlay (USA)
Registered Address (of company)	32 Molesworth Street Dublin 2 D02 Y512 Ireland
Company Registration No.	368236
Telephone No.	068-53427
Email Address (if any)	info@shannonlng.ie

4. Person / Agent acting on behalf of the Applicant (if any):

Name:	Dr. Elaine A Bennet (Agent)
Address:	Mott MacDonald Ireland Limited 5 Eastgate Avenue Eastgate Little Island Co Cork T45 EE72 Ireland
Telephone No.	00353 212336985
Mobile No. (if any)	N/A
Email address (if any)	elaine.a.bennett@mottmac.com

Should all correspondence be sent to the above address? (Please tick appropriate box)

(Please note that if the answer is "No", all correspondence will be sent to the Applicant's address)

Yes: [☒] No: [☐]

Contact Name and Contact Details (Phone number) for arranging entry on site if required / appropriate:

Martin Ahern (Shannon LNG Limited): 068-53427

5. Person responsible for preparation of Drawings and Plans:

Name:	Conor Cunningham
Firm / Company:	Mott MacDonald Ireland Limited
Address:	Mott MacDonald South Block Rockfield Dundrum Dublin D16 R6V0 Ireland
Telephone No:	00353 12993416
Mobile No:	N/A
Email Address (if any):	conor.cunningham@mottmac.com
Please refer to the separate schedule submitted with this application form.	

6. Site:

Site Address / Location of the Proposed Development (as may best identify the land or structure in question)	Townlands of Carhoona, Carhoonakilla, Carhoonakineely, Cockhill, Coolnagoonagh, Farranawana, Kilcolgan Lower, Kilcolgan Upper, Kilpaddoge and Ralappane, County Kerry
Ordnance Survey Map Ref No. (and the Grid Reference where available)	OSI Map references: OS0814, OS1014 ITM Grid References: 502164E, 648441N (substation compound in Ralappane); 505763E, 648291N (connection to existing Line Cable Interface Mast in Kilpaddoge)
Where available, please provide the application site boundary, as shown in the submitted plans / drawings, as an ESRI shapefile in the Irish Transverse Mercator (ITM IRENET95) co-ordinate reference system. Alternatively, a CAD file in .dwg format, with all geometry referenced to ITM, may be provided.	
Area of site to which the application relates in hectares	31.6 hectares
Site zoning in current Development Plan for the area:	Kerry County Development Plan 2022-2028: Strategic Development Location (within Tarbert-Ballylongford Landbank) - for its potential as an Energy Hub and for industrial development at a regional and national level.
Existing use of the site & proposed use of the site:	Existing Use: Agriculture and Roads Proposed use: Industry – energy
Name of the Planning Authority(s) in whose functional area the site is situated:	Kerry County Council

7. Legal Interest of Applicant in respect of the site the subject of the application:

Please tick appropriate box to show applicant's legal interest in the land or structure:	Owner ✓	Occupier
	Other ✓	
Where legal interest is "Other", please expand further on your interest in the land or structure.		
The Applicant holds the consents necessary for the making of this application.		
If you are not the legal owner , please state the name and address of the owner and supply a letter from the owner of consent to make the application as listed in the accompanying documentation.		
See above.		
Does the applicant own or have a beneficial interest in adjoining, abutting or adjacent lands? If so, identify the lands and state the interest.		
Yes – these include the lands which are currently subject of the Shannon Technology Energy Park (STEP) Power Plant, Battery Energy Storage System and Above Ground Installation Strategic Infrastructure Development application to An Bord Pleanála (case reference. PA08.319566).		

8. Site History:

Details regarding site history (if known):

Has the site in question ever, to your knowledge, been flooded?

Yes: [☐] No: [☒]

If yes, please give details e.g. year, extent: N/A

Are you aware of previous uses of the site e.g. dumping or quarrying?

Yes: [☐] No: [☒]

If yes, please give details: N/A

Are you aware of any valid planning applications previously made in respect of this land / structure?

Yes: [✓] No: []

If yes, please state planning register reference number(s) of same if known and details of applications

Reg. Ref. No:	Nature of Proposed Development	Nature of Final Decision of Application Grant of Refusal by Planning Authority / An Bord Pleanála
ABP-319566-24	STEP Power Plant: 600MW Powerplant, 120MW Battery Energy Storage System, Above Ground Installation and associated ancillary works.	Not decided - Case is due to be decided by 21/10/2024
ABP-311233-21	Ten-year permission for proposed Shannon Technology and Energy Park consisting of power plant, battery energy storage system, floating storage and regasification unit, jetty, onshore receiving facilities, above ground installation and all ancillary structures/works.	Refuse permission 13/09/2023 Currently subject to judicial review proceedings.
20438 / ABP-308643-20	Revision of previously granted grid connection for a permitted wind farm via 12.1km underground cable connecting to 38KVA/110KVA substation at Kilpaddoge, Tarbert.	Grant permission with conditions 21/06/2021
ABP-307798-20	Proposed 400kV electricity transmission cables, extension to the existing Kilpaddoge Electrical Substation and associated works, between the existing Moneypoint 400kV Electrical Substation in the townland of Carrowdoita South County Clare and existing Kilpaddoge 220/110kV Electrical Substation in the townland of Kilpaddoge County Kerry.	Approve with conditions 04/06/2021
PL08.PM0014	Amendment to the duration of the permission for the permitted LNG Terminal (condition no. 2) from 10 years to 15 years – subsequently quashed by the High Court in 2020	Grant permission with conditions 13/07/2018
PL08. PA0028	Ten year permission for a combined Heat and Power (CHP) Plant	Grant permission with conditions 09/07/2013
PM08.PM0002	Alter condition 3 of 08.PA0002 - allow for the option of constructing one tank initially in lieu of the requirement to construct two.	Alter decision (Not a material alteration) 04/03/2013
GA08.GA0003	Gas pipeline to connect Shannon LNG Terminal at Ralappane, Co. Kerry to existing natural gas network at Leahys, Co. Limerick	Approve with conditions 17/02/2009
DA08.DA0003	Application for an acquisition order (associated with PL08.GA0003) for the Shannon LNG Terminal at Tarbert, Co. Kerry to the Bord Gáis Eireann Network at Foynes, County Limerick	Make Acquisition Order without Amendments 17/12/2009
PA08B.PA0002	Liquefied Natural Gas (LNG) Regasification Terminal	Grant consent with modification 31/03/2008
Part 8 application	L1010 road improvements (road widening)	2008

If a valid planning application has been made in respect of this land or structure in the 6 months prior to the submission of this application, then any required site notice must be on a yellow background in accordance with Article 19(4) of the Planning and Development regulations 2001 as amended.

Is the site of the proposal subject to a current appeal to An Bord Pleanála in respect of a similar development?

Yes: [] No: [☒]

If yes please specify

An Bord Pleanála Reference No. _____

9. Description of the Proposed Development:

Brief description of nature and extent of development	<p>The proposed development, the subject of the application for approval, will comprise of the following:</p> <ul style="list-style-type: none"> a) An EirGrid plc operated Gas Insulated Switchgear (GIS) substation compound (Glansillagh 220kV substation) measuring a total footprint of approximately 3,666.4 sqm, enclosed with a 2.6m high security fence and 1.4m high post and rail fence in the townland of Ralappane, and comprising of the following: <ul style="list-style-type: none"> • 1no. 906.5 sqm. two storey GIS 220kV building measuring 17m in height, • 1no. Reactor compound (19m L x 18m W) enclosed with 2.6m high security fencing and containing 3no. shunt reactors (3.4m diameter x 10m H), • Associated Air Insulated Switchgear electrical equipment including cable sealing ends (6.2m H), surge arrestors and associated steelwork (6.2m H), post insulators (6.2m H) and 2no. lightning masts (18.5m high); b) A Customer operated Gas Insulated Switchgear (GIS) substation compound (Knockfinglas 220kV substation) measuring a total footprint of approximately 3,166 sqm. enclosed with a 2.6m high security fence in the townland of Ralappane and including 1no. two storey 220kV GIS building measuring 925sqm. and 17m in height; with associated 11.4m high Gas Insulated Busbar (GIB); c) 5km 220kV underground cables and fibre optic cable, 2.8km for which cable ducting and cables will be provided off-road, and 2.2km of cable will be pulled through existing cable ducting within the L1010, and associated cable joint bays, communication chambers and link boxes along the cable route; and d) All associated ancillary site development works to facilitate the proposed development including, surface water drainage, lighting arrangements, temporary construction compounds and laydown areas, hardstanding, access tracks, vegetation clearance and decommissioning of an existing 220kV underground cable.
---	--

10. In the case of mixed development (e.g. residential, commercial, industrial, etc), please provide breakdown of the different classes of development and a breakdown of the gross floor area of each class of development:

Class of Development:	Gross Floor Area in m ²
N/A	N/A

11. Where the application relates to a building or buildings:

Gross floor space of any existing buildings(s) in m ²	N/A
Gross floor space of proposed works in m ²	3138 m ²
Gross floor space of work to be retained in m ² (if appropriate)	N/A
Gross floor space of any demolition in m ² (if appropriate)	N/A

12. In the case of residential development please provide breakdown of residential mix:

Number of	Studio	1 Bed	2 Bed	3 Bed	4 Bed	4 + Bed	Total
Houses	N/A						N/A
Apartments	N/A						N/A
Number of car-parking spaces to be provided		Existing: N/A	Proposed: N/A			Total: N/A	

13. Social Housing:

Please tick appropriate box:	Yes	No
<i>Is the application an application for permission for development to which Part V of the Planning and Development Act 2000 applies?</i>		✓
<p>If the answer to the above question is “yes” and the development is not exempt (see below), you must provide, as part of your application, details as to how you propose to comply with section 96 of Part V of the Act.</p> <p>If the answer to the above question is “yes” but you consider the development to be exempt by virtue of section 97 of the Planning and Development Act 2000, a copy of the Certificate of Exemption under section 97 must be submitted (or, where an application for a certificate of exemption has been made but has not yet been decided, a copy of the application should be submitted).</p> <p>If the answer to the above question is “no” by virtue of section 96 (13) of the Planning and Development Act 2000, details indicating the basis on which section 96 (13) is considered to apply to the development should be submitted.</p>		

14. Where the application refers to a material change of use of any land or structure or the retention of such a material change of use:

Existing use (or previous use where retention permission is sought)
Agricultural
Proposed use (or use it is proposed to retain)
Industry - Energy
Nature and extent of any such proposed use (or use it is proposed to retain).
Energy transmission and associated substations

15. Development Details:

Please tick appropriate box:	If answer is yes please give details	YES	NO
Does the proposed development involve the demolition of a Protected Structure(s), in whole or in part?			✓
Does the proposed development consist of work to a protected structure and / or its curtilage or proposed protected structure and / or its curtilage?			✓
Does the proposed development consist of work to the exterior of a structure which is located within an architectural conservation area (ACA)?			✓
Does the application relate to development which affects or is close to a monument or place recorded under section 12 of the National Monuments (Amendment) Act, 1994.			✓
Does the application relate to work within or close to a European Site or a Natural Heritage Area?	✓ Adjacent to Lower River Shannon Special Area of Conservation (002165) and River Shannon and River Fergus Estuaries Special Protection Area (004077)		
Does the development require the preparation of a Natura Impact Statement?	✓		
Does the proposed development require the preparation of an Environmental Impact Assessment Report?	✓		
Do you consider that the proposed development is likely to have significant effects on the environment in a transboundary state?			✓
Does the application relate to a development which comprises or is for the purpose of an activity requiring an integrated pollution prevention and control license	✓		
Does the application relate to a development which comprises or is for the purpose of an activity requiring a waste license?			✓
Do the Major Accident Regulations apply to the proposed development?			✓

Does the application relate to a development in a Strategic Development Zone?		✓
Does the proposed development involve the demolition of any habitable house?		✓

16. Services:

Proposed Source of Water Supply:

Existing connection: ☐ New Connection: ☒

Public Mains: ☒ Group Water Scheme: ☐ Private Well: ☐

Other (please specify):

Name of Group Water Scheme (where applicable):

Proposed Wastewater Management / Treatment:

Existing: ☐ New: ☒

Public Sewer: ☐ Conventional septic tank system: ☒

Other on site treatment system: ☐ Please Specify:

Proposed Surface Water Disposal:

Public Sewer / Drain: ☐ Soakpit: ☐

Watercourse: ☐ Other: ☒ Please specify: The surface water drainage will connect to drainage infrastructure to be constructed as part of the proposed STEP Power Plant project (ABP case reference: PA08.319566), which will then discharge to the Shannon Estuary.

17. Notices:

Details of public newspaper notice – paper(s) and date of publication
Kerryman – 17 July 2024 Kerry's Eye – 18 July 2024 Irish Examiner – 18 July 2024 Copy of page(s) of relevant newspaper enclosed Yes: <input checked="" type="checkbox"/> No: <input type="checkbox"/>
Details of site notice, if any, - location and date of erection
Site notices erected on 19 July 2024 Copy of site notice enclosed Yes: <input checked="" type="checkbox"/> No: <input type="checkbox"/>
Details of other forms of public notification, if appropriate e.g. website
The application may be viewed/downloaded via the following website: www.STEP220kVConnection.com

18. Pre-application Consultation:

Date(s) of statutory pre-application consultations with An Bord Pleanála
<p>A pre-application consultation was held with the Board on 01 December 2023 (ABP case reference ABP-318119-23). The focus of this meeting was to introduce the Board to the proposed development. The pre-application consultation process was closed by the Applicant via a letter dated 29 April 2024.</p> <p>Written correspondence from ABP, dated 16 May 2024, confirmed that the proposed development was considered to be strategic infrastructure development (SID). This correspondence is included within the application documents.</p> <p>Schedule of any other pre application consultations – name of person / body and date of consultation to be provided as appropriate and also details of any general public consultations i.e. methods, dates, venues etc. This can be submitted as a separate schedule with the application form.</p> <p>Enclosed:</p> <p>Yes: <input checked="" type="checkbox"/> No: <input type="checkbox"/></p> <p>Schedule of prescribed bodies to whom notification of the making of the application has been sent and a sample copy of such notification.</p> <p>Enclosed:</p> <p>Yes: <input checked="" type="checkbox"/> No: <input type="checkbox"/></p>


19. Confirmation Notice:

Copy of Confirmation Notice	
EIA Portal Confirmation Notice Portal ID 2024126 was received on 17 July 2024, the confirmation email is contained within the statutory particulars.	

20. Application Fee:

Fee Payable	€100,000
	This payment was made to An Bord Pleanála on 25 July 2024
	Payment reference: 163WIRE000081

I hereby declare that, to the best of my knowledge and belief, the information given in this form is correct and accurate and that the application documents being deposited at the planning authority offices, and any other location specified by the Board in pre application consultations, including a website (if any) will be identical to the application documents being deposited with the Board.

Signed: (Applicant or Agent as appropriate)	 Agent: Elaine Bennett of Mott MacDonald Ireland Limited
Date:	30 July 2024

General Guidance Note:

The range and format of material required to be compiled / submitted with any application in respect of a proposed strategic infrastructure development shall generally accord with the requirements for a planning application as set out in the Planning and Development Regulations, 2001 to 2018 and those Regulations should therefore be consulted prior to submission of any application.

September 2018

Application fee payment confirmation – 25 July 2024



33461755Transactions

1 records printed out of 5 records.

Search Criteria :						
From Date : 07/20/2024						
To Date : 10/17/2024						
Value Date	Statement Date	Currency	Amount	Beneficiary/ Remitter	Customer Reference	Type
07/25/2024	07/25/2024	EUR	-100,000.00	AN BORD PLEANALA	163WIRE000081	FT-Funds Transfer

SITE NOTICE

Planning and Development Act 2000, as amended

Notice of Direct Planning Application to An Bord Pleanála in respect of a Strategic Infrastructure Development

KERRY COUNTY COUNCIL

In accordance with Section 182A of the Planning and Development Act 2000 (as amended), Shannon LNG Limited gives notice of its intention to make an application for approval to An Bord Pleanála for the proposed 220kV Grid Connection and 2 no. 220kV Gas Insulated Switchgear substations, herein referred to as the 'proposed development'. The proposed development, the subject of this application for approval, will be located in the townlands of Carhoona, Carhoonakilla, Carhoonakineely, Cockhill, Coolnagoonagh, Farranawana, Kilcolgan Lower, Kilcolgan Upper, Kilpaddoge and Ralappane, County Kerry. The application seeks approval for a 10 year planning permission.

The proposed development will comprise of the following:

- a) An EirGrid plc operated Gas Insulated Switchgear (GIS) substation compound (Glansillagh 220kV substation) measuring a total footprint of approximately 3,666.4 sqm, enclosed with a 2.6m high security fence and 1.4m high post and rail fence in the townland of Ralappane, and comprising of the following:
 - 1no. 906.5 sqm. two storey GIS 220kV building measuring 17m in height,
 - 1no. Reactor compound (19m L x 18m W) enclosed with 2.6m high security fencing and containing 3no. shunt reactors (3.4m diameter x 10m H),
 - Associated Air Insulated Switchgear electrical equipment including cable sealing ends (6.2m H), surge arrestors and associated steelwork (6.2m H), post insulators (6.2m H) and 2no. lightning masts (18.5m high);
- b) A Customer operated Gas Insulated Switchgear (GIS) substation compound (Knockfinglas 220kV substation) measuring a total footprint of approximately 3,166 sqm. enclosed with a 2.6m high security fence in the townland of Ralappane and including 1no. two storey 220kV GIS building measuring 925sqm. and 17m in height; with associated 11.4m high Gas Insulated Busbar (GIB);
- c) 5km 220kV underground cables and fibre optic cable, 2.8km for which cable ducting and cables will be provided off-road, and 2.2km of cable will be pulled through existing cable ducting within the L1010, and associated cable joint bays, communication chambers and link boxes along the cable route; and
- d) All associated ancillary site development works to facilitate the proposed development including, surface water drainage, lighting arrangements, temporary construction compounds and laydown areas, hardstanding, access tracks, vegetation clearance and decommissioning of an existing 220kV underground cable.

Both an Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) have been prepared in respect of the proposed development and accompany this application for approval.

The proposed development relates to development which comprises an activity required to be licenced by the Environmental Protection Agency (EPA) under an Industrial Emission Licence.

The planning application, Environmental Impact Assessment Report and Natura Impact Statement may be inspected free of charge or purchased on payment of a specified fee (which fee shall not exceed the reasonable cost of making such copy) during public opening hours for a period of seven weeks commencing on the 07 August 2024 at the following locations:

- The offices of **An Bord Pleanála**, 64 Marlborough Street, Dublin, D01 V902
- The offices of **Kerry County Council**, Planning Department, County Buildings, Rathass, Tralee, Co. Kerry, V92 H7VT

The application may also be viewed/downloaded on the following website from 07 August 2024 – www.STEP220kVConnection.com

Submissions or observations **may be made only** to An Bord Pleanála ('the Board'), 64 Marlborough Street, Dublin, D01 V902 or via the Board's website <https://pleanala.ie/en-ie/observations>, during the above-mentioned period of seven weeks relating to –

- (i) The implications of the proposed development for proper planning and sustainable development, and
- (ii) The likely effects on the environment of the proposed development, and
- (iii) The likely significant effects of the proposed development on a European site, if carried out.

Any submissions/observations must be accompanied by a fee of €50 (except for certain prescribed bodies) and must be received by the Board in writing or online at www.pleanala.ie **not later than 5:30pm on 25 September 2024**. Such submissions/observations must also include the following information:

- The name of the person making the submission or observation, the name of the person acting on his or her behalf, if any, and the address to which any correspondence relating to the application should be sent,
- The subject matter of the submission or observation, and
- The reasons, considerations and arguments on which the submission or observation is based in full.

Any submissions or observations which do not comply with the above requirements cannot be considered by the Board.

The Board may at its absolute discretion hold an oral hearing on the application (for further details see "A Guide to Public Participation in Strategic Infrastructure Development" at www.pleanala.ie).


The Board may in respect of an application for permission decide to –

- i. approve the proposed development, or
- ii. make such modifications to the proposed development as it specifies in its decision and approve the proposed development as so modified, or
- iii. approve, in part only, the proposed development (with or without specified modifications of it of the foregoing kind), or
- iv. refuse to approve the proposed development,

and may attach to an approval under paragraph (i), (ii) or (iii) such conditions as it considers appropriate.

Any enquiries relating to the application process should be directed to the Strategic Infrastructure Development Section of An Bord Pleanála (Tel. 01-8588100).

A person may question the validity of any such decision of the Board by way of an application for judicial review, under Order 84 of the Rule of the Superior Courts (S.I. No. 15 of 1986, as amended), in accordance with Section 50 of the Planning and Development Act 2000, as amended. Practical information on the review mechanism can be accessed under the heading 'Legal Notices – Judicial Review Notice' on the Board's website www.pleanala.ie or on the Citizen's Information website www.citizensinformation.ie.

Signed	 Agent's address: Gráinne Reid of Mott MacDonald Ireland Limited, South Block, Rockfield, Dundrum, Dublin, D16 R6V0
Date of erection of site notice	19 July 2024

FAMILY NOTICES

IN MEMORIAM

BRENNAN

5TH Anniversary



In loving memory of Eileen (Nellie) Brennan, Rea, Kilflynn. Who died 20th July 2019

*We miss you from your fireside chair
Your loving smile and gentle air
Your vacant place no one can fill
We miss you Nellie and always will*

Loved and missed everyday by your family and friends xxxxx

Nellie's Anniversary Mass will take place in St Mary's Church, Kilflynn, Saturday 20th of July at 6 o'clock

DEVANE

5th Anniversary




In loving memory of a wife, mother and grandmother Anne Devane (née Walsh) of Annagh, Tralee who died on 17th July 2019.

Remembered with love and fondest memories today and everyday. Sadly missed by your loving family

FITZPATRICK

23rd Anniversary



Patrick Fitzpatrick, Baslickane, Waterville, July 18th, 2001.

*Will those who think of him today,
A special prayer to Jesus say.*


Sadly missed by his wife Eileen, son John, daughters Siobhan and Neasa, daughter-in-law Hayley, son-in-law John, brother Denis, sister Mary and grandchildren Nonie, Cora, Pádraig and Lewis.

Anniversary Mass will be celebrated in Lohar Church at 6pm on Saturday July 27th.

IN MEMORIAM

GRIFFIN

29th Anniversary



In loving memory of Patrick Griffin, Couneraugh, Glenbeigh, who died on July 20th, 1995. R.I.P.

Sadly missed along life's way. Quietly remembered everyday No longer in our life to share But in our heart's you're always always there.

Always remembered by his loving Family.

MOORE

6th Anniversary




In Loving Memory of Nora Moore (nee Flaherty) Kilmorna Listowel Co Kerry who died on the 21st July 2018

*Though her smile is gone forever,
And her hand we cannot touch
We have lovely memories,
Of a Mother, Nana, Aunt and friend
we loved so much*

Lovingly remembered by her sons Mike, Ned, Tom and James Daughters Kathleen and Margaret, Daughters in Law, Sons in Law, adored grandchildren and great grandchildren, nieces and nephews.

MCENERY

11th Anniversary



Treasured memories today and everyday of a loving Husband, Dad and Grandad John McEnery late of Cahirdown, Listowel who died on July 17th, 2013.

Remembered with love by Helen and children Martha, Edel, Eoghan and Muireann, also his adored grandchildren.

*His absence a silent grief
His life a beautiful memory*

Beatha na Naomh go dtuillfidh sé
Anniversary Mass on Saturday 20th July at 6:15pm in St Mary's Church, Listowel.

IN MEMORIAM

HOGAN

6th Anniversary




In loving memory of Margaret Hogan of New Road, Killarney, Co Kerry

*In life we loved you dearly
In death we love you still
In our hearts you hold a place
That no one could ever fill*

Loved and always remembered by the Hogan family

HOULIHAN

26th Anniversary




In loving memory of my mam Catherine Kath late of Ahabeg and Clogher Lixnaw who's anniversary is now.

Too dearly loved to be forgotten

Missed by Kitty James Martina and families and all the family in England and Ireland.

WALSH

18th Anniversary



In loving memory of Oliver Walsh, Caherbarna, Waterville who died on 17th July, 2006. R.I.P.

*So many people knew you,
And that's what makes us proud,
You were that special person,
Who stood out in the crowd.*

*And for us who loved
and lost you,
And whose parting
brought such pain.
We will cherish your
memory forever,
In a world that is
never the same.*

Sadly missed by your loving family.

Mass in St Finian's Church, Friday 19th July at 7.30pm.

CLASSIFIEDS

PLANNING

PLANNING

PLANNING

PLANNING AND DEVELOPMENT ACT 2000, AS AMENDED

Notice of Application for Approval to An Bord Pleanála in respect of a proposed Strategic Infrastructure Development

KERRY COUNTY COUNCIL

In accordance with Section 182A of the Planning and Development Act 2000 (as amended), Shannon LNG Limited gives notice of its intention to make an application for approval to An Bord Pleanála for the proposed 220kV Grid Connection and 2 no. 220kV Gas Insulated Switchgear substations, herein referred to as the 'proposed development'. The proposed development, the subject of this application for approval, will be located in the townlands of Carhoona, Carhoonakilla, Carhoonakeely, Cockhill, Coolnanoonagh, Farranawana, Kilcolgan Lower, Kilcolgan Upper, Kilpaddoge and Ralappane, County Kerry. The application seeks approval for a 10 year planning permission.

The proposed development will comprise of the following:

a) An EirGrid plc operated Gas Insulated Switchgear (GIS) substation compound (Glansillagh 220kV substation) measuring a total footprint of approximately 3,666.4 sqm, enclosed with a 2.6m high security fence and 1.4m high post and rail fence in the townland of Ralappane, and comprising of the following:

- 1no. 906.5 sqm. two storey GIS 220kV building measuring 17m in height,
- 1no. Reactor compound (19m L x 18m W) enclosed with 2.6m high security fencing and containing 3no. shunt reactors (3.4m diameter x 10m H),
- Associated Air Insulated Switchgear electrical equipment including cable sealing ends (6.2m H), surge arrestors and associated steelwork (6.2m H), post insulators (6.2m H) and 2no. lightning masts (18.5m high);

b) A Customer operated Gas Insulated Switchgear (GIS) substation compound (Knockfinglas 220kV substation) measuring a total footprint of approximately 3,166 sqm. enclosed with a 2.6m high security fence in the townland of Ralappane and including 1no. two storey 220kV GIS building measuring 925 sqm. and 17m in height; with associated 11.4m high Gas Insulated Busbar (GIB);

c) 5km 220kV underground cables and fibre optic cable, 2.8km for which cable ducting and cables will be provided off-road, and 2.2km of cable will be pulled through existing cable ducting within the L1010, and associated cable joint bays, communication chambers and link boxes along the cable route; and

d) All associated ancillary site development works to facilitate the proposed development including, surface water drainage, lighting arrangements, temporary construction compounds and laydown areas, hardstanding, access tracks, vegetation clearance and decommissioning of an existing 220kV underground cable.

Both an Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) have been prepared in respect of the proposed development and accompany this application for approval.

The proposed development relates to development which comprises an activity required to be licenced by the Environmental Protection Agency (EPA) under an Industrial Emission Licence.

The planning application, Environmental Impact Assessment Report and Natura Impact Statement may be inspected free of charge or purchased on payment of a specified fee (which fee shall not exceed the reasonable cost of making such copy) during public opening hours for a period of seven weeks commencing on the 07 August 2024 at the following locations:

- The offices of **An Bord Pleanála**, 64 Marlborough Street, Dublin, D01 V902
- The offices of **Kerry County Council**, Planning Department, County Buildings, Rathass, Tralee, Co. Kerry, V92 H7VT

The application may also be viewed/downloaded on the following website from 07 August 2024 - **www.STEP220kVConnection.com**

Submissions or observations **may be made only** to An Bord Pleanála ('the Board'), 64 Marlborough Street, Dublin, D01 V902, or via the Board's website <https://pleanala.ie/en-ie/observations>, during the above-mentioned period relating to –

(i) The implications of the proposed development for proper planning and sustainable development in the area or areas concerned, and

(ii) The likely effects on the environment of the proposed development, and

(iii) The likely significant effects of the proposed development on a European site as the case may be, if carried out.

Any submissions/observations must be accompanied by a fee of €50 (except for certain prescribed bodies) and must be received by the Board in writing or online at www.pleanala.ie, **not later than 5:30pm on 25 September 2024**. Such submissions/observations must also include the following information:

- The name of the person making the submission or observation, the name of the person acting on his or her behalf, if any, and the address to which any correspondence relating to the application should be sent,
- The subject matter of the submission or observation, and
- The reasons, considerations and arguments on which the submission or observation is based in full.

Any submissions or observations which do not comply with the above requirements cannot be considered by the Board.

The Board may at its absolute discretion hold an oral hearing on the application (for further details see "A Guide to Public Participation in Strategic Infrastructure Development" at www.pleanala.ie).

The Board may in respect of an application for permission decide to –

- approve the proposed development, or
- make such modifications to the proposed development as it specifies in its decision and approve the proposed development as so modified, or
- approve, in part only, the proposed development (with or without specified modifications of it of the foregoing kind), or
- refuse to approve the proposed development.

and may attach to an approval under paragraph (i), (ii) or (iii) such conditions as it considers appropriate.

Any enquiries relating to the application process should be directed to the Strategic Infrastructure Development Section of An Bord Pleanála (Tel. 01 8588100).

A person may question the validity of any such decision by the Board by way of an application for judicial review, under Order 84 of the Rules of the Superior Courts (S.I. No. 15 of 1986, as amended), in accordance with Section 50 of the Planning and Development Act 2000, as amended.

Practical information on the review mechanism can be accessed on the Board's website (www.pleanala.ie) under the heading 'Judicial Review Notice'. This information is also available on the Citizens Information Service website at www.citizensinformation.ie.

NOTICES

COMHAIRLE CONTAE CHIARRAÍ KERRY COUNTY COUNCIL



BÓITHRE A nDÚNADH GO SEALADACH TEMPORARY CLOSING OF ROADS ALT 75 d'ACHT NA mBÓITHRE 1993 SECTION 75 OF ROADS ACT 1993

Notice is hereby given that, pursuant to Section 75 of the Roads Act 1993, and the Temporary Closing of Roads Regulations 1994, Kerry County Council **has decided** to close to public traffic the following road:

Road Closed: L-10028 Aghanagan Road from its junction with the R-552 Ballylongford Road.

Road Closing Times: from 9.00 a.m. on Thursday, 25th July to 5.00 p.m. on Friday, 23rd August 2024.

The purpose of the road closure is to facilitate the installation of the underground cable grid connection from Ballylongford Wind Farm.

Local Access will be provided for emergency services and local residents.

Pádraig Corkery
Senior Executive Officer, Corporate Affairs

COMHAIRLE CONTAE CHIARRAÍ KERRY COUNTY COUNCIL



BÓITHRE A nDÚNADH GO SEALADACH TEMPORARY CLOSING OF ROADS ALT 75 d'ACHT NA mBÓITHRE 1993 SECTION 75 OF ROADS ACT 1993

Notice is hereby given that, pursuant to Section 75 of the Roads Act 1993, and the Temporary Closing of Roads Regulations 1994, Kerry County Council **is proposing** to close to public traffic the road described hereunder to facilitate road improvement works.

Road Closed: R-551 Causeway Village, at its junction with the L-1034 in Causeway Village to Dromkeen East Cross at its junction with L-6078 at Dromkeen East.

Road closing Dates and Times: from 7.00 a.m. on Tuesday, 6th of August to 7.00 p.m. on Tuesday, 13th August 2024.

Alternative routes will be clearly signposted:

Traffic traveling from Ballyduff to Causeway Village & Ballyheigue:

Traffic will turn left off the R-551 at Dromkeen East Cross and travel along the L-6078 to its junction with the L-1031 (known locally as the Line Road). Take a right at the junction of the L-6078 and the L-1031 Line Road and continue along the L-1031 Line Road to its intersection with the L-1034 Dromkeen West Road. Take a right at the junction of the L-1031 Line Road and the L-1034 Dromkeen West Road and continue along the L-1034 road for Causeway Village. Follow signs for Ballyheigue. Diversions will clearly be signposted.

Traffic travelling from Ballyheigue to Ballyduff and Ballybunion:

Traffic will turn right at the village cross in Causeway Village and travel along the L-1034 Dromkeen West Road. Continue along the L-1034 Dromkeen West Road and take a left at the junction of the L-1034 Dromkeen West Road and L-1031 Line road. Continue along the L-1031 Line Road and take a left at the junction of the L-1031 Line Road and the L-6078. Continue along the L-6078 to its junction with R-551. Follow signs for Ballyduff and Ballybunion. Diversions will be clearly sign posted.

Access will be provided for emergency services, local residents and businesses if required.

Any person having an objection to the above proposal should lodge same, in writing, marked **Road Closure**, with the Administrative Officer, Roads and Transportation Department, County Buildings, Tralee, County Kerry or by e-mail to roads@kerrycoco.ie not later than **4.00 p.m. on Monday, 22nd July 2024**.

To enable the processing of submissions/ objections Kerry County Council can legally process this information, as necessary, to comply with its statutory/legal obligations. Such information will be processed in line with the Council's privacy statement which is available at www.kerrycoco.ie.

Pádraig Corkery
Senior Executive Officer, Corporate Affairs

PUBLIC NOTICES

PLANNING AND DEVELOPMENT ACT 2000, AS AMENDED

Notice of Application for Approval to An Bord Pleanála in respect of a proposed Strategic Infrastructure Development

KERRY COUNTY COUNCIL

In accordance with Section 182A of the Planning and Development Act 2000 (as amended), Shannon LNG Limited gives notice of its intention to make an application for approval to An Bord Pleanála for the proposed 220kV Grid Connection and 2 no. 220kV Gas Insulated Switchgear substations, herein referred to as the 'proposed development'. The proposed development, the subject of this application for approval, will be located in the townlands of Carhoona, Carhoonakilla, Carhoonakeely, Cockhill, Coolnanonagh, Farranawana, Kilcolgan Lower, Kilcolgan Upper, Kilpadoge and Ralappane, County Kerry. The application seeks approval for a 10 year planning permission.

The proposed development will comprise of the following:

- An EirGrid plc operated Gas Insulated Switchgear (GIS) substation compound (Glansillagh 220kV substation) measuring a total footprint of approximately 3,666.4 sqm, enclosed with a 2.6m high security fence and 1.4m high post and rail fence in the townland of Ralappane, and comprising of the following:
 - 1no. 906.5 sqm. two storey GIS 220kV building measuring 17m in height,
 - 1no. Reactor compound (19m L x 18m W) enclosed with 2.6m high security fencing and containing 3no. shunt reactors (3.4m diameter x 10m H),
 - Associated Air Insulated Switchgear electrical equipment including cable sealing ends (6.2m H), surge arrestors and associated steelwork (6.2m H), post insulators (6.2m H) and 2no. lightning masts (18.5m high);
- A Customer operated Gas Insulated Switchgear (GIS) substation compound (Knockfinglas 220kV substation) measuring a total footprint of approximately 3,166 sqm. enclosed with a 2.6m high security fence in the townland of Ralappane and including 1no. two storey 220kV GIS building measuring 925 sqm. and 17m in height; with associated 11.4m high Gas Insulated Busbar (GIB);
- 5km 220kV underground cables and fibre optic cable, 2.8km for which cable ducting and cables will be provided off-road, and 2.2km of cable will be pulled through existing cable ducting within the L1010, and associated cable joint bays, communication chambers and link boxes along the cable route; and
- All associated ancillary site development works to facilitate the proposed development including, surface water drainage, lighting arrangements, temporary construction compounds and laydown areas, hardstanding, access tracks, vegetation clearance and decommissioning of an existing 220kV underground cable.

Both an Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) have been prepared in respect of the proposed development and accompany this application for approval.

The proposed development relates to development which comprises an activity required to be licenced by the Environmental Protection Agency (EPA) under an Industrial Emission Licence.

The planning application, Environmental Impact Assessment Report and Natura Impact Statement may be inspected free of charge or purchased on payment of a specified fee (which fee shall not exceed the reasonable cost of making such copy) during public opening hours for a period of seven weeks commencing on the 07 August 2024 at the following locations:

- The offices of **An Bord Pleanála**, 64 Marlborough Street, Dublin, D01 V902
- The offices of **Kerry County Council**, Planning Department, County Buildings, Rathass, Tralee, Co. Kerry, V92 H7VT

The application may also be viewed/downloaded on the following website from 07 August 2024 - www.STEP220kV-Connection.com

Submissions or observations may be made only to An Bord Pleanála ('the Board'), 64 Marlborough Street, Dublin, D01 V902, or via the Board's website <https://pleanala.ie/en-ie/observations>, during the above-mentioned period relating to –

- The implications of the proposed development for proper planning and sustainable development in the area or areas concerned, and
- The likely effects on the environment of the proposed development, and
- The likely significant effects of the proposed development on a European site as the case may be, if carried out.

Any submissions/observations must be accompanied by a fee of €50 (except for certain prescribed bodies) and must be received by the Board in writing or online at www.pleanala.ie, **not later than 5:30pm on 25 September 2024**. Such submissions/observations must also include the following information:

- The name of the person making the submission or observation, the name of the person acting on his or her behalf, if any, and the address to which any correspondence relating to the application should be sent,
- The subject matter of the submission or observation, and
- The reasons, considerations and arguments on which the submission or observation is based in full.

Any submissions or observations which do not comply with the above requirements cannot be considered by the Board.

The Board may at its absolute discretion hold an oral hearing on the application (for further details see "A Guide to Public Participation in Strategic Infrastructure Development" at www.pleanala.ie).

The Board may in respect of an application for permission decide to –

- approve the proposed development, or
- make such modifications to the proposed development as it specifies in its decision and approve the proposed development as so modified, or
- approve, in part only, the proposed development (with or without specified modifications of it of the foregoing kind), or
- refuse to approve the proposed development.

and may attach to an approval under paragraph (i), (ii) or (iii) such conditions as it considers appropriate.

Any enquiries relating to the application process should be directed to the Strategic Infrastructure Development Section of An Bord Pleanála (Tel. 01 8588100).

A person may question the validity of any such decision by the Board by way of an application for judicial review, under Order 84 of the Rules of the Superior Courts (S.I. No. 15 of 1986, as amended), in accordance with Section 50 of the Planning and Development Act 2000, as amended.

Practical information on the review mechanism can be accessed on the Board's website (www.pleanala.ie) under the heading 'Judicial Review Notice'. This information is also available on the Citizens Information Service website at www.citizensinformation.ie.

COMHAIRLE CONTAE CHIARRAÍ KERRY COUNTY COUNCIL



BÓITHRE A nDÚNADH GO SEALADACH TEMPORARY CLOSING OF ROADS ALT 75 d'ACHT NA mBÓITHRE 1993 SECTION 75 OF ROADS ACT 1993

Notice is hereby given that, pursuant to Section 75 of the Roads Act 1993, and the Temporary Closing of Roads Regulations 1994, Kerry County Council **is proposing** to close to public traffic the following road:

Road Closed: R553 Charles Street, Listowel

Road Closing Times: From 7.00 a.m. on Monday, 12th August to 7.00 p.m. on Thursday 15th August 2024

The purpose of this road closure is to facilitate road resurfacing works.

Diversions will be as follows and will be clearly signposted:

Traffic travelling along Lower William Street/ Upper William Street/ Market Street towards Church Street.	Continue along the N-69 Upper William Street to Cliveragh Junction, turn right onto N-69 John B Keane road, Continue along the N-69 John B Keane Road to Tim Kennelly Roundabout, at the Tim Kennelly Roundabout take the 3rd exit onto the N-69 Upper Church Street, Continue along the N-69 Upper Church street.
---	--

Local Access will be provided for Emergency Services and local residents.

Any person having an objection to the above proposal should lodge same, in writing, marked **Road Closure**, with the Administrative Officer, Roads and Transportation Department, County Buildings, Tralee, County Kerry or by e-mail to roads@kerrycoco.ie not later than **4.00 p.m. on Monday, 22nd July 2024**.

Pádraig Corkery
Senior Executive Officer, Corporate Affairs

COMHAIRLE CONTAE CHIARRAÍ KERRY COUNTY COUNCIL



BÓITHRE A nDÚNADH GO SEALADACH TEMPORARY CLOSING OF ROADS ALT 75 d'ACHT NA mBÓITHRE 1993 SECTION 75 OF ROADS ACT 1993

Notice is hereby given that in compliance with the Roads Act, 1993, Section 75 and the Temporary Closing of Roads Regulations, 1994, Kerry County Council **is proposing** to close the streets as detailed below in order to facilitate the holding of the **Puck Fair Festival 2024 in Killorglin**.

From 6.00 p.m. on August 9th - 1.00 a.m. on August 10th, 2024

Market Street, Lower Bridge Street from Bianconi Inn to the Square (Traffic Island)

From 6.00 a.m. on August 10th - 1.00 a.m. on August 11th, 2024

From 6.00 a.m. on August 11th - 1.00 a.m. on August 12th, 2024

From 6.00 a.m. on August 12th - 1.00 a.m. on August 13th, 2024

Upper Bridge Street, The Square (To Macks Corner), Lower Bridge Street, (To Bianconi Inn), Market Street

From 6.00 a.m. on August 10th - 1.00 a.m. on August 11th, 2024

From 6.00 a.m. on August 11th - 1.00 a.m. on August 12th, 2024

Langford Street (from Macks Corner to the entrance to the Paddocks)

From 6.00 p.m. on August 9th - 1.00 a.m. on August 13th, 2024

The Mill Car Park

From 9.00 a.m. on August 9th – 9.00 a.m. on August 13th, 2024

Junction Railway Road / Aldi Carpark to Junction Railway Road / School Road (the newly opened road that links Iveragh Road to School Road).

A traffic diversion system will operate on the main approaches to the town.


Any person having an objection to the above proposal should lodge same, in writing, marked **Road Closure**, to the Administrative Officer, Roads and Transportation Department, County Buildings, Tralee, County Kerry or by e-mail to roads@kerrycoco.ie not later than **4.00 p.m. on Monday, 22nd July 2024**.

To enable the processing of submissions/ objections Kerry County Council can legally process this information, as necessary, to comply with its statutory / legal obligations. Such information will be processed in line with the Council's privacy statement which is available at www.kerrycoco.ie.

Pádraig Corkery
Senior Executive Officer, Corporate Affairs



Listen



From news and current affairs to culture and lifestyle, to expert sporting analysis and debate, press play on an Irish Examiner podcast today.

Available wherever you get your podcasts



or listen on

irishexaminer.com/podcasts

Irish Examiner

Situations Vacant

Full time Healthcare Assistants are currently required by Ireland's Largest Nursing Home Group, emeis Ireland, with with a salary of €27,000, 39 hours per week and in respect of which the minimum hourly rate of remuneration is €13.31. Candidates should have as a minimum QQI Level 5 in healthcare or above, experience in care of the Older Person is highly desirable.

MILLBRAE LODGE NURSING HOME Shower Newport Co. Tipperary
MILL LANE MANOR NURSING HOME Salinas Road Naas Co. Kildare
ASHLEY LODGE NURSING HOME Tully East Kildare Co. Kildare
KILMINTY LODGE NURSING HOME The Crescent Portlaoise Co. Laois
MAYNOOTH LODGE NURSING HOME Crinstown, Rathcoffey Road Maynooth Co. Kildare ,
TLC Maynooth NURSING HOME Straffan Road Maynooth Co. Kildare
ATHLUNKARD NURSING HOME Westbury Corbally Co. Clare ,
BELMONT CARE LTD Galloping Green Stillorgan Co. Dublin
BENEAVIN HOUSE Beneavin Road Glasnevin Dublin 11
BENEAVIN LODGE Beneavin Road Glasnevin Dublin 11
BLAINROE LODGE Blainroe Co. Wicklow
EARLSBROOK HOUSE NURSING HOME 41 Meath Road Bray Co. Wicklow
KILBREW NURSING HOME Kilbree Ashbourne Co. Meath
MOUNT PLEASANT LODGE Clane Road, Portlerrigan Kilcock. Co. Kildare
TLC CARA CARE Northwood Park Santry Dublin 9
TLC CARTON Tonleeg Road Raheny Dublin 5
TLC Citywest Cooldown Commons Fortunetown Lane Citywest Dublin 24
TLC Santry Northwood Park Santry Dublin 9
The Residence, Portlaoise, The Maltings, Harpurs Lane, Portlaoise, Co. Laois
The Residence, Kilkenny, Gallowhill, Kilkenny
The Residence, Portlaoise, Lime Tree Ave, Portlaoise, Co. Laois
JOB DESCRIPTION
To deliver hands on nursing care to residents in a caring respectful and person-centred manner ensuring wherever possible the resident's wishes are observed.

MAIN DUTIES & RESPONSIBILITIES

- To be accountable for high standards of care in the Nursing home
- To take full responsibility for the care assigned in the Nursing home
- To keep accurate and quality records as required under the HIAA standards
- To carry out all aspects of care according to the person's needs, as per his/her agreed care plan
- To ensure that the Nursing Home is secure and safe at all times and that fire and emergency policies and procedures are strictly adhered to
- To inform your Home Manager of any deficiencies, anomalies or concerns immediately
- To be familiar with all statutory instruments of legislation concerning nursing homes and to be familiar with all nursing policies and procedures within the Nursing Home
- To treat all information and data in a secure and confidential manner
- To carry out such other duties appropriate to the post as directed by management
- To ensure that all residents receive person-centred care as directed in their care plans
- To carry out care for our residents with dignity, respect and facilitate their optimum independence as much as possible
- To assist residents with their personal hygiene needs
- To assist with resident's toileting needs
- To assist residents to mobilise safely
- To ensure residents receive assistance with eating and drinking as necessary
- To ensure residents are clothed in seasonally suitable clothing of their choice
- To participate in the delivery of therapy and any other alternative therapies as arranged / prescribed by the Social Care Leader, Home Manager, ADON/CNM or Nurse on duty
- To observe, listen and engage with the residents and, report any concerns to the Nursing staff
- To communicate with all staff, residents, relatives and visitors to the Home in a manner that will ensure good positive clear outcomes
- To attend training as directed by the Company
- To work as part of a care team referring to the allocation sheet and roster
- To follow the procedures as set out in Company policy
- To use medical nursing equipment carefully and as instructed in training
- To respond promptly to the Nurse Call bells
- To show respect for resident's belongings
- To ensure that resident's needs are met with dignity and respect and where appropriate to attend to these needs.
- To promote resident's independence and empowerment at all times.

please apply to recruitment-Ireland@emeis.com

Situations Vacant

Situations Vacant

HEIGHTS Hospitality Operations Ltd, Hellfire, 7 Westmoreland St, Temple Bar, Dublin, D02 XF76 requires two Chef de Partie for our restaurant. The chef must have at least two years, min experience in preparing & cooking quality cuisine and must be hardworking & capable of producing high quality foods. Salary €34,000 pa, 39 hours p/w. CV to Kate kate@heightshq.com

HGV driver wanted for milk collection around Cork City. 5/6 days. No Sundays. 55 hours a week. €60,000 annual pay. Ph. Richie 086-0654354

JUST Desserts Factory Limited T/A Eatokyo Noodle's & Sushi Bar require (2) Chef de Partie for their popular Japanese Restaurant in Dublin 2 area. Minimum 2 years' experience as a chef and have a knowledge of Japanese cuisine and dishes. Chefs must be capable of creating new and exciting recipes on an on-going basis. Contact: Jie, Location: Eatokyo 51 Wellington Quay, Dublin 2. Salary €34,000 per annum, Hours: 39 Hrs per week. CV to: info@eatokyo.ie

TANNER Tyres Sales & Repairs Limited of Raheen Newcestown Co. Cork is seeking an experienced HGV Mechanic to join its team. The ideal candidate will have at least two years' experience in tyre fitting, repair of HGV diesel cars, maintenance & testing of heavy vehicles. The annual salary is €34,000. This is a permanent role and requires 39 hours per week. Apply with your CV to the Company address.

THE King Sitric Ltd T/A King Sitric Fish Restaurant & Accommodation, 6 East Pier, Howth Co. Dublin require two Chef de Partie for their restaurant. Each chef requires 2 Years min experience in preparing & cooking quality cuisine and must be hardworking & capable of producing high quality foods for both department & internal standards. Salary €34,000 pa, 39 hours p/w CV to Sue at sue@kingsitric.ie

WE are currently recruiting for an experienced Head Chef to join our dynamic team at Fota Island Resort, Fota Island, Co. Cork.

The successful applicant will be required to assist and support the Executive Head Chef in all areas of the department.

Description/Responsibilities

- Five years previous experience as an Executive Sous chef or department head
- Culinary certification or degree
- HACCP Level 2 or higher
- Assist with the day to day running of all restaurant outlets including large banquets, wedding and events
- Assist with ensuring optimum stocking levels and ordering is conducted to achieve food G.P.s and K.P.I's
- To maintain all kitchen Outlets, still rooms, storage rooms, delivery areas and staff dining rooms in line with HACCP and legislative standards

- Deputise in the absence of the Executive Head Chef
- Designing and planning of menus based on seasonal products
- Work across all services including Breakfast, lunch and dinner
- Assist with staff recruitment, onboarding, and integration by analysing candidates' skills and competencies Identify any potential candidates for promotion within the brigade

Salary €54k per annum
Hours of work: 39 hours per week
Apply with CV to hr@fotacollection.ie

WUSHENG Xie, T/A Dragon Phoenix Restaurant Dragon, 1st Floor, 2 St Nessans Road, Dooradoyle, Limerick, require a Head Chef, with at least 5 years' experience in preparing and cooking oriental dishes to a very high standard for a busy restaurant. Must be hard working and capable of producing high quality foods for both department and internal standards. The chef must be innovative in introducing new and exciting dishes on an on-going basis. Salary is €34,000 pa, 39 hrs pw. CV details to the o Jason E: xiewusheng88@gmail.com

Car Hire

Great Island Car Rentals
Contact Ph 021-4811609

Planning Notices

PLANNING AND DEVELOPMENT ACT 2000, AS AMENDED
Notice of Application for Approval to An Bord Pleanála in respect of a proposed Strategic Infrastructure Development
KERRY COUNTY COUNCIL In accordance with Section 182A of the Planning and Development Act 2000 (as amended), Shannon LNG Limited gives notice of its intention to make an application for approval to An Bord Pleanála for the proposed 220kV Grid Connection and 2 no. 220kV Gas Insulated Switchgear substations, herein referred to as the 'proposed development'. The proposed development, the subject of this application for approval, will be located in the townlands of Carhoona, Carhoonakilla, Carhoonakineely, Cockhill, Coolnanonagh, Farranawana, Kilcolgan Lower, Kilcolgan Upper, Kilpaddoge and Ralappane, County Kerry. The application seeks approval for a 10 year planning permission.
The proposed development will comprise of the following:
a) An EirGrid plc operated Gas Insulated Switchgear (GIS) substation compound (Glanlillagh 220kV substation) measuring a total footprint of approximately 3,666.4 sqm, enclosed with a 2.6m high security fence and 1.4m high post and rail fence in the townland of Ralappane, and comprising of the following:
• 1no. 906.5 sqm. two storey GIS 220kV building measuring 17m in height,
• 1no. Reactor compound (19m L x 18m W) enclosed with 2.6m high security fencing and containing 3no. shunt reactors (3.4m diameter x 10m H),
• Associated Air Insulated Switchgear electrical equipment including cable sealing ends (6.2m H), surge arrestors and associated steelwork (6.2m H), post insulators (6.2m H) and 2no. lightning masts (18.5m high);
b) A Customer operated Gas Insulated Switchgear (GIS) substation compound (Knocklingas 220kV substation) measuring a total footprint of approximately 3,166 sqm, enclosed with a 2.6m high security fence in the townland of Ralappane and including 1no. two storey 220kV GIS building measuring 925 sqm, and 17m in height; with associated 11.4m high Gas Insulated Busbar (GIB);
c) 5km 220kV underground cables and fibre optic cable, 2.8km for which cable ducting and cables will be provided off-road, and 2.2km of cable will be pulled through existing cable ducting within the L1010, and associated cable joint bays, communication chambers and link boxes along the cable route; and
d) All associated ancillary site development works to facilitate the proposed development including, surface water drainage, lighting arrangements, temporary construction compounds and laydown areas, handstanding, access tracks, vegetation clearance and decommissioning of an existing 220kV underground cable.
Both an Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) have been prepared in respect of the proposed development and accompany this application for approval.
The proposed development relates to development which comprises an activity required to be licensed by the Environmental Protection Agency (EPA) under an Industrial Emission Licence.
The planning application, Environmental Impact Assessment Report and Natura Impact Statement may be inspected free of charge or purchased on payment of a specified fee (which fee shall not exceed the reasonable cost of making such copy) during public opening hours for a period of seven weeks commencing on the 07 August 2024 at the following locations:
• The offices of **An Bord Pleanála**, 64 Marlborough Street, Dublin, D01 V902
• The offices of **Kerry County Council**, Planning Department, County Buildings, Rathass, Tralee, Co. Kerry, V92 H7VT
The application may also be viewed/downloaded on the following website from 07 August 2024 - www.STEP220kVConnection.com
Submissions or observations may be made only to An Bord Pleanála ('the Board'), 64 Marlborough Street, Dublin, D01 V902, or via the Board's website <https://planala.ie/en-ie/observations>, during the above-mentioned period relating to –
(i) The implications of the proposed development for proper planning and sustainable development in the area or areas concerned, and
(ii) The likely effects on the environment of the proposed development, and
(iii) The likely significant effects of the proposed development on a European site as the case may be, if carried out.
Any submissions/observations must be accompanied by a fee of €50 (except for certain prescribed bodies) and must be received by the Board in writing or online at www.planala.ie, **not later than 5:30pm on 25 September 2024**. Such submissions/observations must also include the following information:
• The name of the person making the submission or observation, the name of the person acting on his or her behalf, if any, and the address to which any correspondence relating to the application should be sent,
• The subject matter of the submission or observation, and
• The reasons, considerations and arguments on which the submission or observation is based in full.
Any submissions or observations which do not comply with the above requirements cannot be considered by the Board.
The Board may at its absolute discretion hold an oral hearing on the application (for further details see "A Guide to Public Participation in Strategic Infrastructure Development" at www.planala.ie).
The Board may in respect of an application for permission decide to –
i. approve the proposed development, or
ii. make such modifications to the proposed development as it specifies in its decision and approve the proposed development as so modified, or
iii. approve, in part only, the proposed development (with or without specified modifications of it of the foregoing kind), or
iv. refuse to approve the proposed development, and may attach to an approval under paragraph (i), (ii) or (iii) such conditions as it considers appropriate.
Any enquiries relating to the application process should be directed to the Strategic Infrastructure Development Section of An Bord Pleanála (Tel. 01 8588100).
A person may question the validity of any such decision by the Board by way of an application for judicial review, under Order 84 of the Rules of the Superior Courts (S.I. No. 15 of 1986, as amended), in accordance with Section 50 of the Planning and Development Act 2000, as amended.

Practical information on the review mechanism can be accessed on the Board's website (www.planala.ie) under the heading 'Judicial Review Notice'. This information is also available on the Citizens Information Service website at www.citizensinformation.ie.

Planning Notices

TIPPERARY COUNTY COUNCIL WE Trifol Resources Limited, intend to apply for Permission for Retention of an existing ESB substation & distribution room building and all associated site works at Trifol Resources Ltd., Killeens, Ballymonty, Thurles, Co. Tipperary. The planning application may be inspected, or purchased at a fee not exceeding the reasonable cost of making a copy, at the offices of the Planning Authority during its public opening hours (9.30am to 1pm and 2pm to 4pm). A submission or observation in relation to the application may be made in writing to the planning authority on payment of the prescribed fee (€20) within the period of 5 weeks beginning on the date of receipt by the authority of the application.

Legal & Public Notices
CONTACT OUR SALES TEAM TODAY
T. 021 427 44 55
E. notices@examiner.ie
Irish Examiner
Know what's really happening.

Planning Notices

Death Notices



BUCKLEY (Grange, Ovens and late of Curraheen): On July 16, 2024, peacefully, at Cork University Hospital, MARY (née Forde), in her 98th year, beloved wife of the late Connie and dear mother of Seán, Declan, Maura, Brian, Ursula, Cormac, Raymond, Kenneth, Austin, Eithne and the late Thomas, Fionula, Kieran, Rosaleen and Neilus. Deeply regretted by her loving family, sons-in-law, daughters-in-law, grandchildren, great-grandchildren, brother Tommy, nephews, nieces, grandnephews, grandnieces, relatives, kind neighbours and friends. Rest in peace. Lying in repose at her home in Grange (Eircode P31 H299) today (Thursday) from 6.30pm to 8.30pm, followed by prayers. Requiem Mass at 12 noon tomorrow (Friday) in the Church of St John the Baptist, Ovens which will be live streamed on: <https://www.churchservices.tv/ovens>.
Funeral afterwards to the adjoining cemetery.
A garden is where the soul finds solace, And the heart finds peace.

In Memoriam

Hurley
24TH ANNIVERSARY
In loving memory of MICHAEL, The Mall, Youghal, Co. Cork, whose anniversary occurs today. (Sadly missed by Tony, Mary, Pauline, Annette, family and friends)

Legal Notices

THE HIGH COURT
Record Number 2024/157 COS
IN THE MATTER OF SK FISHING LIMITED
AND
IN THE MATTER OF THE COMPANIES ACT 2014
NOTICE is given that a petition for the winding-up of the above named company by the High Court was on the 28th day of June 2024 presented to the High Court by Maria O'Donovan Joyce, of Laharn, Dunderrow, Kinsale, County Cork, in main proceedings, (in accordance with Article 3(1) of Regulation (EU) No. 2015/848) and that the said petition is directed to be heard before the High Court, Four Courts, Dublin 7 on the 29th day of July 2024 at 11.00am or as soon as possible thereafter, and that any creditor or contributory of the said company who wishes to support or oppose the making of an order on the said petition may appear at the time of hearing by himself or his counsel for that purpose and a copy of the petition will be furnished to any creditor or contributory of the said company who requires it by the undersigned on payment of the regulated charge for the same.
Signed:
RDJ LLP
Solicitors for the Petitioner
85 South Mall
Cork.
(ref: DNT/17762/00001)
Note: Any person who intends to appear at the hearing of the said petition must serve on or send by post to the above named Petitioner or its solicitors, notice in writing of his intention to do so. The notice must state the name and address of the person or if a firm the name and address of the firm and must be signed by the person or firm or his or her solicitor (if any) and must be served or, if posted, must be sent by post in sufficient time to reach the above named solicitor or the Petitioner not later than 5 o'clock in the afternoon of 26 July 2024.

Family Notices

CONTACT OUR SALES TEAM TODAY
T. 021 427 44 55
E. familynotices@examiner.ie
Irish Examiner

Notice to Advertisers/Readers
It is a condition of acceptance of advertisement orders that the The Examiner Echo Group Limited do not accept liability for any loss or damage caused by an error or inaccuracy in the printing of any advertisement, whether by virtue of an inaccuracy, error or otherwise caused by an error or inaccuracy in the printing of one corrected insertion. No reprinting shall occur where the error is of a minor or typographical nature only.
In the event of the publication of an advertisement, or a series of advertisements, containing an inaccuracy or error caused by The Examiner Echo Group Limited, its servants or agents, the limit of liability of The Examiner Echo Group Limited shall extend only to the printing of one corrected insertion. No reprinting shall occur where the error is of a minor or typographical nature only.
The Examiner Echo Group Limited reserve the right to cancel, at any time, an advertisement or a series of advertisements planned for publication and, in such circumstances, The Examiner Echo Group Limited shall only repay to the advertiser such portion of monies as is attributable to the unpublished advertisements and nothing further.
Irish Examiner

Death Notices



KELLY (Ballincollig): On July 16, 2024, SARAH, loving and loved daughter of Letitia and Michael Kelly, passed away, unexpectedly, after a short illness, surrounded by her loving family, in the wonderful care of the staff of Cork University Hospital. Sadly missed by her heartbroken family, her loving parents Letitia and Michael, her sister Mary and brothers David and Michael, brother-in-law Aidan, sisters-in-law Helen and Miriam, nephews and godsons Aodhan and Tomás, nieces Eabha, Doireann, Aislinn and Hannah, together with her extended family, large circle of friends and her colleagues at Glanmire Community College. Rest in peace. Lying in repose at Crowley's Funeral Home, Ballincollig (P31 W982) on today (Thursday) from 5pm to 7pm. Requiem Mass at 11.00am on tomorrow (Friday) in the Church of St Mary and St John, Ballincollig (P31 EF97), which can be viewed on: <https://www.churchservices.ie/stmjballincollig>.
Funeral afterwards in St Oliver's Cemetery. Family flowers only. Donations, if desired, to the Irish Cancer Society: <https://www.cancer.ie/ways-to-help>.
House private.

O'DRISCOLL ("Aisling Heights", Glogheen, Clonakilly): On July 15, 2024, suddenly, at home, MICHAEL (MICKIEY), beloved husband and best friend of the recently deceased Angela (nee O'Sullivan), devoted father of Michelle and the late infant Michael, cherished grandfather to Megan, brother of the late Ned, Lally, Joan and Denis. Sadly missed by his loving daughter, granddaughter, brother Tony, Ann Mortimer, Michelle's partner Noel Young, brothers-in-law, sisters-in-law, nephews, nieces, relatives, kind neighbours and friends. Requiem Mass in the Church of the Immaculate Conception, Clonakilly on today (Thursday) at 2pm. Funeral afterwards to St Mary's Cemetery, Clonakilly.
Rest in peace.


O'MAHONY (Dunmanway and Dublin): On July 14, 2024, TIMMY, peacefully, in the care of the staff of St Vincent's Hospital, Dublin, formerly of Belmont Nursing Home, The Clevis, Leopards-town and 17 Pearse Square, Dublin 2, brother of the late Donal, John Joe, Maureen and David. Sadly missed by his relatives and his friends in Dublin. Rest in peace. Reposing in O'Neill's Funeral Home, Dunmanway. Funeral Mass on today (Thursday) at 12.00 noon in St Patrick's Church, Dunmanway. Burial afterwards to St Joseph's Cemetery, Dunmanway.

TWOHIG (Casement Park, Clonakilly and formerly of Dungourney and Ilford, Essex): On July 16, 2024, unexpectedly but peacefully, at home, KATHLEEN (nee Walsh), beloved wife of the late William, dear sister of Margaret (O'Regan), Dick, Eileen (Cronin), Vera (O'Donovan) and the late Timmy, Bridie, Maureen and Tony. Sadly missed by her loving brother, sisters, brother-in-law, sisters-in-law, nephews, nieces, grandnephews, grandnieces, relatives, kind neighbours and friends. Reposing in O'Sullivan's Funeral Home, Clonakilly on today (Thursday) from 7pm to 8pm, followed by Prayers. Requiem Mass on tomorrow (Friday) at 12 noon in the Church of the Immaculate Conception, Clonakilly. Funeral afterwards to St Mary's Cemetery, Clonakilly.
Rest in peace.

Notice to Advertisers/Readers
It is a condition of acceptance of advertisement orders that the The Examiner Echo Group Limited do not accept liability for any loss or damage caused by an error or inaccuracy in the printing of any advertisement, whether by virtue of an inaccuracy, error or otherwise caused by an error or inaccuracy in the printing of one corrected insertion. No reprinting shall occur where the error is of a minor or typographical nature only.
In the event of the publication of an advertisement, or a series of advertisements, containing an inaccuracy or error caused by The Examiner Echo Group Limited, its servants or agents, the limit of liability of The Examiner Echo Group Limited shall extend only to the printing of one corrected insertion. No reprinting shall occur where the error is of a minor or typographical nature only.
The Examiner Echo Group Limited reserve the right to cancel, at any time, an advertisement or a series of advertisements planned for publication and, in such circumstances, The Examiner Echo Group Limited shall only repay to the advertiser such portion of monies as is attributable to the unpublished advertisements and nothing further.
Irish Examiner

Our Case Number: ABP-318119-23

Your Reference: Shannon LNG Limited T/A Shannon LNG



An
Bord
Pleanála

Mott MacDonald
5 Eastgate Avenue
Eastgate
Little Island
Eastgate
Co. Cork

Date: 16 May 2024

Re: Proposed 220kV Grid Connection and 2no 220kV GIS substations.

In the townlands of Ralappane, Kilcolgan Lower, Carhoonakineely, Carhoonakilla, Cockhill, Coolnagoonagh, Carhoona, Farranawana and Kilpaddoge, Tarbert, Co. Kerry

Dear Sir / Madam,

Please be advised that following consultations under section 182E of the Planning and Development Act 2000, as amended, the Board hereby serves notice that it is of the opinion that the proposed development falls within the scope of section 182A of the Planning and Development Act 2000, as amended. Accordingly, the Board has decided that the proposed development would be strategic infrastructure within the meaning of section 182A of the Planning and Development Act 2000, as amended. Any application for approval for the proposed development must therefore be made directly to An Bord Pleanála under section 182A(1) of the Act.

Please also be informed that the Board considers that the pre-application consultation process in respect of this proposed development is now closed.

The following is a list of prescribed bodies to be notified of the application for the proposed development.

1. Department of Planning and Local Government and Heritage.
2. Minister of Environment and Climate & Communications.
3. Kerry County Council.
4. Clare County Council.
5. Transport Infrastructure Ireland/ National Transport Authority.
6. An Chomhairle Ealaíon (Arts Council).
7. The Heritage Council.
8. Fáilte Ireland.
9. An Taisce.
10. Southern Regional Assembly.
11. Irish Water.
12. Inland Fisheries.
13. Waterways Ireland.

Tel	Tel	(01) 858 8100
Glao Áitiúil	LoCall	1800 275 175
Facs	Fax	(01) 872 2684
Láithreán Gréasáin	Website	www.pleanala.ie
Ríomhphost	Email	bord@pleanala.ie

64 Sráid Maoilbhríde	64 Marlborough Street
Baile Átha Cliath 1	Dublin 1
D01 V902	D01 V902

14. Department of Agriculture, Food & Marine.
15. Department of Tourism, Culture, Arts, Gaeltacht, Sports and Media.
16. HSE.
17. Health and Safety Authority.
18. The Commission for Energy Regulation.
19. Office of Public Works.
20. ESB.
21. EirGrid.

Further notifications should also be made where deemed appropriate.

In accordance with section 146(5) of the Planning and Development Act 2000, as amended, the Board will make available for inspection and purchase at its offices the documents relating to the decision within 3 working days following its decision. This information is normally made available on the list of decided cases on the website on the Wednesday following the week in which the decision is made.

The following contains information in relation to challenges to the validity of a decision of An Bord Pleanála under the provisions of the Planning and Development Act 2000, as amended.

Judicial review of An Bord Pleanála decisions under the provisions of the Planning and Development Acts (as amended).

A person wishing to challenge the validity of a Board decision may do so by way of judicial review only. Sections 50, 50A and 50B of the Planning and Development Act 2000 (as substituted by section 13 of the Planning and Development (Strategic Infrastructure) Act 2006, as amended/substituted by sections 32 and 33 of the Planning and Development (Amendment) Act 2010 and as amended by sections 20 and 21 of the Environment (Miscellaneous Provisions) Act 2011) contain provisions in relation to challenges to the validity of a decision of the Board.

The validity of a decision taken by the Board may only be questioned by making an application for judicial review under Order 84 of The Rules of the Superior Courts (S.I. No. 15 of 1986). Sub-section 50(7) of the Planning and Development Act 2000 requires that subject to any extension to the time period which may be allowed by the High Court in accordance with subsection 50(8), any application for judicial review must be made within 8 weeks of the decision of the Board. It should be noted that any challenge taken under section 50 may question only the validity of the decision and the Courts do not adjudicate on the merits of the development from the perspectives of the proper planning and sustainable development of the area and/or effects on the environment. Section 50A states that leave for judicial review shall not be granted unless the Court is satisfied that there are substantial grounds for contending that the decision is invalid or ought to be quashed and that the applicant has a sufficient interest in the matter which is the subject of the application or in cases involving environmental impact assessment is a body complying with specified criteria.

Section 50B contains provisions in relation to the cost of judicial review proceedings in the High Court relating to specified types of development (including proceedings relating to decisions or actions pursuant to a law of the state that gives effect to the public participation and access to justice provisions of Council Directive 85/337/EEC i.e. the EIA Directive and to the provisions of Directive 2001/12/EC i.e. Directive on the assessment of the effects on the environment of certain plans and programmes). The general provision contained in section 50B is that in such cases each party shall bear its own costs. The Court however may award costs against any party in specified circumstances. There is also provision for the Court to award the costs of proceedings or a portion of such costs to an applicant against a respondent or notice party where relief is obtained to the extent that the action or omission of the respondent or notice party contributed to the relief being obtained.

Teil	Tel	(01) 858 8100
Glaao Áitiúil	LoCall	1800 275 175
Facs	Fax	(01) 872 2684
Láithreán Gréasáin	Website	www.pleanala.ie
Ríomhphost	Email	bord@pleanala.ie

64 Sráid Maoilbhríde	64 Marlborough Street
Baile Átha Cliath 1	Dublin 1
D01 V902	D01 V902

General information on judicial review procedures is contained on the following website,
www.citizensinformation.ie.

Disclaimer: The above is intended for information purposes. It does not purport to be a legally binding interpretation of the relevant provisions and it would be advisable for persons contemplating legal action to seek legal advice.

If you have any queries in the meantime, please contact the undersigned officer of the Board or email sids@pleanala.ie quoting the above mentioned An Bord Pleanála reference number in any correspondence with the Board.

Yours faithfully,



Ashling Doherty
Executive Officer
Direct Line: 01-8737160

VC11


Teil
Glao Áitiúil
Facs
Láithreán Gréasáin
Ríomhphost

Tel
LoCall
Fax
Website
Email

(01) 858 8100
1800 275 175
(01) 872 2684
www.pleanala.ie
bord@pleanala.ie

64 Sráid Maoilbhríde
Baile Átha Cliath 1
D01 V902

64 Marlborough Street
Dublin 1
D01 V902



An
Bord
Pleanála

Board Direction
BD-016312-24
ABP-318119-23

The submissions on file and the inspector's report were considered at a Board Meeting held on 15/05/2024.


The Board decided that the proposed development falls consisting of two no. sub-stations and 220kV grid connection in the townlands of Ralappane, Kilcolgan Lower, Carhoonakineely, Carhoonakilla, Cockhill, Coolnagoonagh, Carhoona, Farranawana and Kilpaddoge, Tarbet, Co. Kerry, as described in the documents received by the Board on the 28th September 2023, 13th December 2023 and 29th April 2024 fall within the scope of section 182A of the Planning and Development Act, 2000, as amended, and that a planning application should be made directly to the Board.

The applicant shall be informed that the application documentation should be forwarded to the following prescribed bodies for the purposes of Section 182A(4)(b) of the Act:

- Department of Planning and Local Government and Heritage.
- Minister of Environment and Climate & Communications.
- Kerry County Council.
- Clare County Council.
- Transport Infrastructure Ireland/ National Transport Authority.
- An Chomhairle Ealaíon (Arts Council).
- The Heritage Council.
- Fáilte Ireland.
- An Taisce.
- Southern Regional Assembly.
- Irish Water.
- Inland Fisheries.

- Waterways Ireland.
- Department of Agriculture, Food & Marine.
- Department of Tourism, Culture, Arts, Gaeltacht, Sports and Media.
- HSE.
- Health and Safety Authority.
- The Commission for Energy Regulation.
- Office of Public Works.
- ESB.
- EirGrid.

Board Member



Peter Mullan

Date: 15/05/2024

Schedule of Prescribed Bodies

Shannon LNG Limited (the Applicant) notified the following prescribed bodies, in writing and via email, of the making of this planning application.

No.	Name of Prescribed Body
1	Department of Planning and Local Government and Heritage
2	Minister of Environment and Climate & Communications
3	Kerry County Council *
4	Clare County Council
5	Transport Infrastructure Ireland
6	An Chomhairle Ealaíon
7	The Heritage Council
8	Faite Ireland
9	An Taisce
10	Southern Regional Assembly
11	Uisce Eireann (formerly Irish Water)
12	Inland Fisheries
13	Waterways Ireland
14	Department of Agriculture, Food & Marine
15	Department of Tourism, Culture, Arts, Gaeltacht, Sports and Media
16	Health Service Executive (HSE)
17	Health and Safety Authority
18	The Commission for Energy Regulation
19	Office of Public Works
20	ESB
21	EirGrid
22	Environmental Protection Agency (EPA) **

* Notification was sent to both the Chief Executive and Senior Planner of Kerry County Council.

** The Environmental Protection Agency was not designated as a prescribed body but have been notified due to the nature of the proposed development.

Minister Darragh O'Brien
Department of Housing, Local Government and
Heritage
Custom House
Custom House Quay
Dublin
D01 W6X0

Your Reference
Shannon LNG Grid
Connection

Our Reference
229100682

Mott MacDonald
South Block
Rockfield
Dundrum
Dublin 16
D16 R6V0
Ireland

T +353 (0)1 2916 700
mottmac.com

Directors: B Williams BE (Hons) MEngSc
CEng MIEI FConsEI (Managing), R
Jefferson MSCSI MRICS BSc Dip Con
Law, J Shinkwin BE (Hons) DipMechEng
CEng MIEI, T Keane BE (Hons) CEng
MIET, J H K Harris BSc CEng (British), C
H Travers MEng CEng (British), I M
Galbraith MRICS BSc (Hons) MSc
(British), E G Roud FCA MA (Hons)
Economics (British)
Innealtóirí Comhairleach (Consulting
Engineers)
Company Secretary: E Counihan ACCA
Registered in Ireland no. 53280.
Mott MacDonald Ireland Limited is a
member of the Mott MacDonald Group

Notification of intention to seek approval in accordance with Section 182A of the Planning and Development Act, 2000, as amended, for Strategic Infrastructure Development.

30 July 2024

Dear Minister O'Brien

Please be advised that Shannon LNG Limited intends to apply to An Bord Pleanála for approval for development in the townlands of Carhoona, Carhoonakilla, Carhoonakineely, Cockhill, Coolnagoonagh, Farranawana, Kilcolgan Lower, Kilcolgan Upper, Kilpaddoge and Ralappane, County Kerry, on or after the 30 July 2024, pursuant to the provisions of Section 182A of the Planning and Development Act 2000, as amended.

An Bord Pleanála, under Article 213(1) of the Planning and Development Regulations 2001, as amended, has identified The Minister for Housing, Local Government and Heritage as a prescribed body for the purposes of this Strategic Infrastructure Development application, and is therefore provided with the application documents as per your previously indicated preference.

The planning approval, if granted, will comprise the following:

a) An EirGrid plc operated Gas Insulated Switchgear (GIS) substation compound (Glansillagh 220kV substation) measuring a total footprint of approximately 3,666.4 sqm, enclosed with a 2.6m high security fence and 1.4m high post and rail fence in the townland of Ralappane, and comprising of the following:

- 1no. 906.5 sqm. two storey GIS 220kV building measuring 17m in height,
- 1no. Reactor compound (19m L x 18m W) enclosed with 2.6m high security fencing and containing 3no. shunt reactors (3.4m diameter x 10m H),
- Associated Air Insulated Switchgear electrical equipment including cable sealing ends (6.2m H), surge arrestors and associated steelwork (6.2m H), post insulators (6.2m H) and 2no. lightning masts (18.5m high);

b) A Customer operated Gas Insulated Switchgear (GIS) substation compound (Knockfinglas 220kV substation) measuring a total footprint of approximately 3,166 sqm. enclosed with a 2.6m high security fence in the townland of

- Ralappane and including 1 no. two storey 220kV GIS building measuring 925 sqm. and 17m in height; with associated 11.4m high Gas Insulated Busbar (GIB);
- c) 5km 220kV underground cables and fibre optic cable, 2.8km for which cable ducting and cables will be provided off-road, and 2.2km of cable will be pulled through existing cable ducting within the L1010, and associated cable joint bays, communication chambers and link boxes along the cable route; and
 - d) All associated ancillary site development works to facilitate the proposed development including, surface water drainage, lighting arrangements, temporary construction compounds and laydown areas, hardstanding, access tracks, vegetation clearance and decommissioning of an existing 220kV underground cable.

Both an Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) have been prepared in respect of the proposed development and accompany this application for approval.

The proposed development relates to development which comprises an activity required to be licenced by the Environmental Protection Agency (EPA) under an Industrial Emission Licence.

The nature, extent and location of the proposed development is fully described in the application plans and particulars. A copy of this application is enclosed herewith. In addition, a copy of this application is available for viewing and downloading on the dedicated project website below: www.STEP220kVConnection.com.

Public consultation in respect to this application runs for a seven-week period commencing on 07 August 2024. Any submission / observation must be received by An Bord Pleanála **no later than 5.30p.m on 25 September 2024**. Such submissions / observations must also include the following information:

- The name of the person making the submission or observation, the name of the person acting on his or her behalf, if any, and the address to which any correspondence relating to the application should be sent,
- The subject matter of the submission or observation, and
- The reasons, considerations and arguments on which the submission or observation is based in full.

Any submissions or observations which do not comply with the above requirements cannot be considered by An Bord Pleanála.

Submissions/ observations shall relate to:

- i. The implications of the Proposed Development for proper planning and sustainable development of the area concerned, and
- ii. The likely effects on the environment of the Proposed Development, if carried out.
- iii. The likely significant effects of the Proposed Development on a European Site, if carried out.

Please note that An Bord Pleanála, following its consideration of the application can decide to:

- i. Grant the permission, or
- ii. Make such modifications to the Proposed Development as it specifies in its decision and grant permission in respect of the Proposed Development as so modified, or
- iii. Grant permission in respect of part of the Proposed Development (with or without specified modifications of it of the foregoing kind), and any of the above decisions may be subject to or without conditions, or
- iv. Refuse to grant the permission.

Any enquiries relating to the application process should be directed to the Strategic Infrastructure Development Section of An Bord Pleanála (Tel. 01-8588100 or sids@pleanala.ie).

Yours faithfully,

A handwritten signature in dark ink, appearing to read 'Grainne'.

Gráinne Reid
Senior Environmental Planner
+44 (0)28 9089 5853
grainne.reid@mottmac.com

Minister Eamon Ryan
Department of the Environment, Climate and
Communications
29-31 Adelaide Road
Dublin
D02 X285

Your Reference
Shannon LNG Grid
Connection

Our Reference
229100682

Mott MacDonald
South Block
Rockfield
Dundrum
Dublin 16
D16 R6V0
Ireland

T +353 (0)1 2916 700
mottmac.com

Directors: B Williams BE (Hons) MEngSc
CEng MIEI FConsEI (Managing), R
Jefferson MSCSI MRICS BSc Dip Con
Law, J Shinkwin BE (Hons) DipMechEng
CEng MIEI, T Keane BE (Hons) CEEng
MIET, J H K Harris BSc CEEng (British), C
H Travers MEng CEEng (British), I M
Galbraith MRICS BSc (Hons) MSc
(British), E G Roud FCA MA (Hons)
Economics (British)
Innealtóirí Comhairleach (Consulting
Engineers)
Company Secretary: E Counihan ACCA
Registered in Ireland no. 53280.
Mott MacDonald Ireland Limited is a
member of the Mott MacDonald Group

**Notification of intention to seek approval in accordance with Section
182A of the Planning and Development Act, 2000, as amended, for
Strategic Infrastructure Development.**

30 July 2024

Dear Minister Ryan

Please be advised that Shannon LNG Limited intends to apply to An Bord Pleanála for permission for development in the townlands of Carhoona, Carhoonakilla, Carhoonakineely, Cockhill, Coolnagoonagh, Farranawana, Kilcolgan Lower, Kilcolgan Upper, Kilpaddoge and Ralappane, County Kerry, on or after the 30 July 2024, pursuant to the provisions of Section 182A of the Planning and Development Act 2000, as amended.

An Bord Pleanála, under Article 213(1) of the Planning and Development Regulations 2001, as amended, has identified The Minister for Environment, Climate and Communications as a prescribed body for the purposes of this Strategic Infrastructure Development application, and is therefore provided with the application documents.

The permission, if granted, will comprise the following:

a) An EirGrid plc operated Gas Insulated Switchgear (GIS) substation compound (Glansillagh 220kV substation) measuring a total footprint of approximately 3,666.4 sqm, enclosed with a 2.6m high security fence and 1.4m high post and rail fence in the townland of Ralappane, and comprising of the following:

- 1no. 906.5 sqm. two storey GIS 220kV building measuring 17m in height,
- 1no. Reactor compound (19m L x 18m W) enclosed with 2.6m high security fencing and containing 3no. shunt reactors (3.4m diameter x 10m H),
- Associated Air Insulated Switchgear electrical equipment including cable sealing ends (6.2m H), surge arrestors and associated steelwork (6.2m H), post insulators (6.2m H) and 2no. lightning masts (18.5m high);

b) A Customer operated Gas Insulated Switchgear (GIS) substation compound (Knockfinglas 220kV substation) measuring a total footprint of approximately 3,166 sqm. enclosed with a 2.6m high security fence in the townland of

- Ralappane and including 1 no. two storey 220kV GIS building measuring 925 sqm. and 17m in height; with associated 11.4m high Gas Insulated Busbar (GIB);
- c) 5km 220kV underground cables and fibre optic cable, 2.8km for which cable ducting and cables will be provided off-road, and 2.2km of cable will be pulled through existing cable ducting within the L1010, and associated cable joint bays, communication chambers and link boxes along the cable route; and
 - d) All associated ancillary site development works to facilitate the proposed development including, surface water drainage, lighting arrangements, temporary construction compounds and laydown areas, hardstanding, access tracks, vegetation clearance and decommissioning of an existing 220kV underground cable.

Both an Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) have been prepared in respect of the proposed development and accompany this application for approval.

The proposed development relates to development which comprises an activity required to be licenced by the Environmental Protection Agency (EPA) under an Industrial Emission Licence.

The nature, extent and location of the proposed development is fully described in the application plans and particulars. A copy of this application is enclosed herewith. In addition, a copy of this application is available for viewing and downloading on the dedicated project website below: www.STEP220kVConnection.com.

Public consultation in respect to this application runs for a seven-week period commencing on 07 August 2024. Any submission / observation must be received by An Bord Pleanála **no later than 5.30p.m on 25 September 2024**. Such submissions / observations must also include the following information:

- The name of the person making the submission or observation, the name of the person acting on his or her behalf, if any, and the address to which any correspondence relating to the application should be sent,
- The subject matter of the submission or observation, and
- The reasons, considerations and arguments on which the submission or observation is based in full.

Any submissions or observations which do not comply with the above requirements cannot be considered by An Bord Pleanála.

Submissions/ observations shall relate to:

- i. The implications of the Proposed Development for proper planning and sustainable development of the area concerned, and
- ii. The likely effects on the environment of the Proposed Development, if carried out.
- iii. The likely significant effects of the Proposed Development on a European Site, if carried out.

Please note that An Bord Pleanála, following its consideration of the application can decide to:

- i. Grant the permission, or
- ii. Make such modifications to the Proposed Development as it specifies in its decision and grant permission in respect of the Proposed Development as so modified, or
- iii. Grant permission in respect of part of the Proposed Development (with or without specified modifications of it of the foregoing kind), and any of the above decisions may be subject to or without conditions, or
- iv. Refuse to grant the permission.

Any enquiries relating to the application process should be directed to the Strategic Infrastructure Development Section of An Bord Pleanála (Tel. 01-8588100 or sids@pleanala.ie).

Yours faithfully,



Gráinne Reid
Senior Environmental Planner
+44 (0)28 9089 5853
grainne.reid@mottmac.com

Chief Executive
Kerry County Council
Rathass
Tralee
Co. Kerry
V92 H7VT

Your Reference
Shannon LNG Grid
Connection

Our Reference
229100682

Mott MacDonald
South Block
Rockfield
Dundrum
Dublin 16
D16 R6V0
Ireland

T +353 (0)1 2916 700
mottmac.com

Directors: B Williams BE (Hons) MEngSc
CEng MIEI FConsEI (Managing), R
Jefferson MSCSI MRICS BSc Dip Con
Law, J Shinkwin BE (Hons) DipMechEng
CEng MIEI, T Keane BE (Hons) CEng
MIET, J H K Harris BSc CEng (British), C
H Travers MEng CEng (British), I M
Galbraith MRICS BSc (Hons) MSc
(British), E G Roud FCA MA (Hons)
Economics (British)
Innealtóirí Comhairleach (Consulting
Engineers)
Company Secretary: E Counihan ACCA
Registered in Ireland no. 53280.
Mott MacDonald Ireland Limited is a
member of the Mott MacDonald Group

Notification of intention to seek approval in accordance with Section 182A of the Planning and Development Act, 2000, as amended, for Strategic Infrastructure Development.

30 July 2024

Dear Sir/Madam,

Please be advised that Shannon LNG Limited gives notice of its intention to seek approval from An Bord Pleanála for development in the townlands of Carhoona, Carhoonakilla, Carhoonakineely, Cockhill, Coolnagoonagh, Farranawana, Kilcolgan Lower, Kilcolgan Upper, Kilpaddoge and Ralappane, County Kerry, on or after the 30 July 2024, pursuant to the provisions of Section 182A of the Planning and Development Act 2000, as amended.

The proposed development comprises the following:

a) An EirGrid plc operated Gas Insulated Switchgear (GIS) substation compound (Glansillagh 220kV substation) measuring a total footprint of approximately 3,666.4 sqm, enclosed with a 2.6m high security fence and 1.4m high post and rail fence in the townland of Ralappane, and comprising of the following:

- 1no. 906.5 sqm. two storey GIS 220kV building measuring 17m in height,
- 1no. Reactor compound (19m L x 18m W) enclosed with 2.6m high security fencing and containing 3no. shunt reactors (3.4m diameter x 10m H),
- Associated Air Insulated Switchgear electrical equipment including cable sealing ends (6.2m H), surge arrestors and associated steelwork (6.2m H), post insulators (6.2m H) and 2no. lightning masts (18.5m high);

b) A Customer operated Gas Insulated Switchgear (GIS) substation compound (Knockfinglas 220kV substation) measuring a total footprint of approximately 3,166 sqm. enclosed with a 2.6m high security fence in the townland of Ralappane and including 1no. two storey 220kV GIS building measuring 925 sqm. and 17m in height; with associated 11.4m high Gas Insulated Busbar (GIB);

c) 5km 220kV underground cables and fibre optic cable, 2.8km for which cable ducting and cables will be provided off-road, and 2.2km of cable will be pulled through existing cable ducting within the L1010, and associated cable joint bays, communication chambers and link boxes along the cable route; and

- d) All associated ancillary site development works to facilitate the proposed development including, surface water drainage, lighting arrangements, temporary construction compounds and laydown areas, hardstanding, access tracks, vegetation clearance and decommissioning of an existing 220kV underground cable.

Both an Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) have been prepared in respect of the proposed development and accompany this application for approval.

The proposed development relates to development which comprises an activity required to be licenced by the Environmental Protection Agency (EPA) under an Industrial Emission Licence.

As requested by Kerry County Council six hard copies of the full application are being provided, which includes:

- A copy of the Statutory particulars (application form, site notice, newspaper notice, copies of letters to prescribed bodies)
- A copy of the Environmental Impact Assessment Report (EIAR), including the Non-Technical Summary and appendices
- A copy of the Natura Impact Statement (NIS)
- A copy of the Planning Report
- A copy of all Planning drawings

The above documents can also be accessed and downloaded from the dedicated project website from the beginning of the consultation period (starting on 07 August 2024) - www.STEP220kVConnection.com.

As per An Bord Pleanála's requirements, you are hereby requested to keep this planning application available for public inspection/ purchase in accordance with the terms of the public notice for a period of seven weeks, commencing on 07 August 2024 until at least the 25 September 2024, at the offices of Kerry County Council's Planning Department, Rathass, Tralee, Co. Kerry. It is the Board's intention that all of the application documentation will remain available for public inspection during the currency of this application.

As a prescribed body, a copy of the planning application has also been sent to Kerry County Council's Senior Planner.

Public consultation in respect to this application runs for a seven-week period commencing on 07 August 2024. Any submission / observation must be received by An Bord Pleanála **no later than 5.30p.m on 25 September 2024**. Such submissions / observations must also include the following information:

- The name of the person making the submission or observation, the name of the person acting on his or her behalf, if any, and the address to which any correspondence relating to the application should be sent,
- The subject matter of the submission or observation, and
- The reasons, considerations and arguments on which the submission or observation is based in full.

Any submissions or observations which do not comply with the above requirements cannot be considered by An Bord Pleanála.

Submissions/ observations shall relate to:

- i. The implications of the Proposed Development for proper planning and sustainable development of the area concerned, and
- ii. The likely effects on the environment of the Proposed Development, if carried out.
- iii. The likely significant effects of the Proposed Development on a European Site, if carried out.

Please note that An Bord Pleanála, following its consideration of the application can decide to:

- i. Grant the permission, or
- ii. Make such modifications to the Proposed Development as it specifies in its decision and grant permission in respect of the Proposed Development as so modified, or
- iii. Grant permission in respect of part of the Proposed Development (with or without specified modifications of it of the foregoing kind), and any of the above decisions may be subject to or without conditions, or

iv. Refuse to grant the permission.

Any enquiries relating to the application process should be directed to the Strategic Infrastructure Development Section of An Bord Pleanála (Tel. 01-8588100 or sids@pleanala.ie).

Yours faithfully,



Gráinne Reid
Senior Environmental Planner
+442890895853
grainne.reid@mottmac.com

Mr Paul Neary
Kerry County Council
Planning Department
Rathass
Tralee
Co. Kerry
V92 H7VT

Your Reference
Shannon LNG Grid
Connection

Our Reference
229100682

Mott MacDonald
South Block
Rockfield
Dundrum
Dublin 16
D16 R6V0
Ireland

T +353 (0)1 2916 700
mottmac.com

Directors: B Williams BE (Hons) MEngSc
CEng MIEI FConsEI (Managing), R
Jefferson MSCSI MRICS BSc Dip Con
Law, J Shinkwin BE (Hons) DipMechEng
CEng MIEI, T Keane BE (Hons) CEEng
MIET, J H K Harris BSc CEEng (British), C
H Travers MEng CEEng (British), I M
Galbraith MRICS BSc (Hons) MSc
(British), E G Roud FCA MA (Hons)
Economics (British)
Innealtóirí Comhairleach (Consulting
Engineers)
Company Secretary: E Counihan ACCA
Registered in Ireland no. 53280.
Mott MacDonald Ireland Limited is a
member of the Mott MacDonald Group

**Notification of intention to seek approval in accordance with Section
182A of the Planning and Development Act, 2000, as amended, for
Strategic Infrastructure Development**

30 July 2024

Dear Mr Neary,

Please be advised that Shannon LNG Limited intends to apply to An Bord Pleanála for approval for development in the townlands of Carhoona, Carhoonakilla, Carhoonakineely, Cockhill, Coolnagoonagh, Farranawana, Kilcolgan Lower, Kilcolgan Upper, Kilpaddoge and Ralappane, County Kerry, on or after the 30 July 2024, pursuant to the provisions of Section 182A of the Planning and Development Act 2000, as amended.

An Bord Pleanála, under Article 213(1) of the Planning and Development Regulations 2001, as amended, has identified Kerry County Council as a prescribed body for the purposes of this Strategic Infrastructure Development application, and is therefore provided with the application documents. The Chief Executive of Kerry County Council has been notified of the application separately.

The permission, if granted, will comprise the following:

a) An EirGrid plc operated Gas Insulated Switchgear (GIS) substation compound (Glansillagh 220kV substation) measuring a total footprint of approximately 3,666.4 sqm, enclosed with a 2.6m high security fence and 1.4m high post and rail fence in the townland of Ralappane, and comprising of the following:

- 1no. 906.5 sqm. two storey GIS 220kV building measuring 17m in height,
- 1no. Reactor compound (19m L x 18m W) enclosed with 2.6m high security fencing and containing 3no. shunt reactors (3.4m diameter x 10m H),
- Associated Air Insulated Switchgear electrical equipment including cable sealing ends (6.2m H), surge arrestors and associated steelwork (6.2m H), post insulators (6.2m H) and 2no. lightning masts (18.5m high);

b) A Customer operated Gas Insulated Switchgear (GIS) substation compound (Knockfinglas 220kV substation) measuring a total footprint of approximately 3,166 sqm. enclosed with a 2.6m high security fence in the townland of

- Ralappane and including 1 no. two storey 220kV GIS building measuring 925 sqm. and 17m in height; with associated 11.4m high Gas Insulated Busbar (GIB);
- c) 5km 220kV underground cables and fibre optic cable, 2.8km for which cable ducting and cables will be provided off-road, and 2.2km of cable will be pulled through existing cable ducting within the L1010, and associated cable joint bays, communication chambers and link boxes along the cable route; and
 - d) All associated ancillary site development works to facilitate the proposed development including, surface water drainage, lighting arrangements, temporary construction compounds and laydown areas, hardstanding, access tracks, vegetation clearance and decommissioning of an existing 220kV underground cable.

Both an Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) have been prepared in respect of the proposed development and accompany this application for approval.

The proposed development relates to development which comprises an activity required to be licenced by the Environmental Protection Agency (EPA) under an Industrial Emission Licence.

The nature, extent and location of the proposed development is fully described in the application plans and particulars. A copy of this application is enclosed herewith. In addition, a copy of this application is available for viewing and downloading on the dedicated project website below: www.STEP220kVConnection.com.

Public consultation in respect to this application runs for a seven-week period commencing on 07 August 2024. Any submission / observation must be received by An Bord Pleanála **no later than 5.30p.m on 25 September 2024**. Such submissions / observations must also include the following information:

- The name of the person making the submission or observation, the name of the person acting on his or her behalf, if any, and the address to which any correspondence relating to the application should be sent,
- The subject matter of the submission or observation, and
- The reasons, considerations and arguments on which the submission or observation is based in full.

Any submissions or observations which do not comply with the above requirements cannot be considered by An Bord Pleanála.

Submissions/ observations shall relate to:

- i. The implications of the Proposed Development for proper planning and sustainable development of the area concerned, and
- ii. The likely effects on the environment of the Proposed Development, if carried out.
- iii. The likely significant effects of the Proposed Development on a European Site, if carried out.

Please note that An Bord Pleanála, following its consideration of the application can decide to:

- i. Grant the permission, or
- ii. Make such modifications to the Proposed Development as it specifies in its decision and grant permission in respect of the Proposed Development as so modified, or
- iii. Grant permission in respect of part of the Proposed Development (with or without specified modifications of it of the foregoing kind), and any of the above decisions may be subject to or without conditions, or
- iv. Refuse to grant the permission.

Any enquiries relating to the application process should be directed to the Strategic Infrastructure Development Section of An Bord Pleanála (Tel. 01-8588100 or sids@pleanala.ie).

Yours faithfully,



Gráinne Reid
Senior Environmental Planner
+442890895853
grainne.reid@mottmac.com

Ms Helen Quinn
Clare County Council
Áras Contae an Chláir
New Road
Ennis
Co. Clare
V95 DXP2

Your Reference
Shannon LNG Grid
Connection

Our Reference
229100682

Mott MacDonald
South Block
Rockfield
Dundrum
Dublin 16
D16 R6V0
Ireland

T +353 (0)1 2916 700
mottmac.com

Directors: B Williams BE (Hons) MEngSc
CEng MIEI FConsEI (Managing), R
Jefferson MSCSI MRICS BSc Dip Con
Law, J Shinkwin BE (Hons) DipMechEng
CEng MIEI, T Keane BE (Hons) CEng
MIET, J H K Harris BSc CEng (British), C
H Travers MEng CEng (British), I M
Galbraith MRICS BSc (Hons) MSc
(British), E G Roud FCA MA (Hons)
Economics (British)
Innealtóirí Comhairleach (Consulting
Engineers)
Company Secretary: E Counihan ACCA
Registered in Ireland no. 53280.
Mott MacDonald Ireland Limited is a
member of the Mott MacDonald Group

Notification of intention to seek approval in accordance with Section 182A of the Planning and Development Act, 2000, as amended, for Strategic Infrastructure Development.

30 July 2024

Dear Ms Quinn,

Please be advised that Shannon LNG Limited intends to apply to An Bord Pleanála for approval for development in the townlands of Carhoona, Carhoonakilla, Carhoonakineely, Cockhill, Coolnagoonagh, Farranawana, Kilcolgan Lower, Kilcolgan Upper, Kilpaddoge and Ralappane, County Kerry, on or after the 30 July 2024, pursuant to the provisions of Section 182A of the Planning and Development Act 2000, as amended.

An Bord Pleanála, under Article 213(1) of the Planning and Development Regulations 2001, as amended, has identified Clare County Council as a prescribed body for the purposes of this Strategic Infrastructure Development application, and is therefore provided with the application documents.

The permission, if granted, will comprise the following:

a) An EirGrid plc operated Gas Insulated Switchgear (GIS) substation compound (Glansillagh 220kV substation) measuring a total footprint of approximately 3,666.4 sqm, enclosed with a 2.6m high security fence and 1.4m high post and rail fence in the townland of Ralappane, and comprising of the following:

- 1no. 906.5 sqm. two storey GIS 220kV building measuring 17m in height,
- 1no. Reactor compound (19m L x 18m W) enclosed with 2.6m high security fencing and containing 3no. shunt reactors (3.4m diameter x 10m H),
- Associated Air Insulated Switchgear electrical equipment including cable sealing ends (6.2m H), surge arrestors and associated steelwork (6.2m H), post insulators (6.2m H) and 2no. lightning masts (18.5m high);

b) A Customer operated Gas Insulated Switchgear (GIS) substation compound (Knockfinglas 220kV substation) measuring a total footprint of approximately 3,166 sqm. enclosed with a 2.6m high security fence in the townland of Ralappane and including 1no. two storey 220kV GIS building measuring 925 sqm. and 17m in height; with associated 11.4m high Gas Insulated Busbar (GIB);

- c) 5km 220kV underground cables and fibre optic cable, 2.8km for which cable ducting and cables will be provided off-road, and 2.2km of cable will be pulled through existing cable ducting within the L1010, and associated cable joint bays, communication chambers and link boxes along the cable route; and
- d) All associated ancillary site development works to facilitate the proposed development including, surface water drainage, lighting arrangements, temporary construction compounds and laydown areas, hardstanding, access tracks, vegetation clearance and decommissioning of an existing 220kV underground cable.

Both an Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) have been prepared in respect of the proposed development and accompany this application for approval.

The proposed development relates to development which comprises an activity required to be licenced by the Environmental Protection Agency (EPA) under an Industrial Emission Licence.

The nature, extent and location of the proposed development is fully described in the application plans and particulars. A copy of this application is enclosed herewith. In addition, a copy of this application is available for viewing and downloading on the dedicated project website below: www.STEP220kVConnection.com.

Public consultation in respect to this application runs for a seven-week period commencing on 07 August 2024. Any submission / observation must be received by An Bord Pleanála **no later than 5.30p.m on 25 September 2024**. Such submissions / observations must also include the following information:

- The name of the person making the submission or observation, the name of the person acting on his or her behalf, if any, and the address to which any correspondence relating to the application should be sent,
- The subject matter of the submission or observation, and
- The reasons, considerations and arguments on which the submission or observation is based in full.

Any submissions or observations which do not comply with the above requirements cannot be considered by An Bord Pleanála.

Submissions/ observations shall relate to:

- i. The implications of the Proposed Development for proper planning and sustainable development of the area concerned, and
- ii. The likely effects on the environment of the Proposed Development, if carried out.
- iii. The likely significant effects of the Proposed Development on a European Site, if carried out.

Please note that An Bord Pleanála, following its consideration of the application can decide to:

- i. Grant the permission, or
- ii. Make such modifications to the Proposed Development as it specifies in its decision and grant permission in respect of the Proposed Development as so modified, or
- iii. Grant permission in respect of part of the Proposed Development (with or without specified modifications of it of the foregoing kind), and any of the above decisions may be subject to or without conditions, or
- iv. Refuse to grant the permission.

Any enquiries relating to the application process should be directed to the Strategic Infrastructure Development Section of An Bord Pleanála (Tel. 01-8588100 or sids@pleanala.ie).

Yours faithfully,



Gráinne Reid
Senior Environmental Planner
+442890895853
grainne.reid@mottmac.com

Ms Olivia Morgan
Land Use Planning,
Transport Infrastructure Ireland,
Parkgate Business Centre,
Parkgate Street
Dublin 8

Your Reference
Shannon LNG Grid
Connection

Our Reference
229100682

Mott MacDonald
South Block
Rockfield
Dundrum
Dublin 16
D16 R6V0
Ireland

T +353 (0)1 2916 700
mottmac.com

Notification of intention to seek approval in accordance with Section 182A of the Planning and Development Act, 2000, as amended, for Strategic Infrastructure Development.

30 July 2024

Dear Ms Morgan,

Please be advised that Shannon LNG Limited intends to apply to An Bord Pleanála for approval for development in the townlands of Carhoona, Carhoonakilla, Carhoonakineely, Cockhill, Coolnagoonagh, Farranawana, Kilcolgan Lower, Kilcolgan Upper, Kilpaddoge and Ralappane, County Kerry, on or after the 30 July 2024, pursuant to the provisions of Section 182A of the Planning and Development Act 2000, as amended.

An Bord Pleanála, under Article 213(1) of the Planning and Development Regulations 2001, as amended, has identified Transport Infrastructure Ireland, as a prescribed body for the purposes of this Strategic Infrastructure Development application, and is therefore provided with the application documents.

The permission, if granted, will comprise the following:

a) An EirGrid plc operated Gas Insulated Switchgear (GIS) substation compound (Glansillagh 220kV substation) measuring a total footprint of approximately 3,666.4 sqm, enclosed with a 2.6m high security fence and 1.4m high post and rail fence in the townland of Ralappane, and comprising of the following:

- 1no. 906.5 sqm. two storey GIS 220kV building measuring 17m in height,
- 1no. Reactor compound (19m L x 18m W) enclosed with 2.6m high security fencing and containing 3no. shunt reactors (3.4m diameter x 10m H),
- Associated Air Insulated Switchgear electrical equipment including cable sealing ends (6.2m H), surge arrestors and associated steelwork (6.2m H), post insulators (6.2m H) and 2no. lightning masts (18.5m high);

b) A Customer operated Gas Insulated Switchgear (GIS) substation compound (Knockfinglas 220kV substation) measuring a total footprint of approximately 3,166 sqm. enclosed with a 2.6m high security fence in the townland of

- Ralappane and including 1 no. two storey 220kV GIS building measuring 925 sqm. and 17m in height; with associated 11.4m high Gas Insulated Busbar (GIB);
- c) 5km 220kV underground cables and fibre optic cable, 2.8km for which cable ducting and cables will be provided off-road, and 2.2km of cable will be pulled through existing cable ducting within the L1010, and associated cable joint bays, communication chambers and link boxes along the cable route; and
 - d) All associated ancillary site development works to facilitate the proposed development including, surface water drainage, lighting arrangements, temporary construction compounds and laydown areas, hardstanding, access tracks, vegetation clearance and decommissioning of an existing 220kV underground cable.

Both an Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) have been prepared in respect of the proposed development and accompany this application for approval.

The proposed development relates to development which comprises an activity required to be licenced by the Environmental Protection Agency (EPA) under an Industrial Emission Licence.

The nature, extent and location of the proposed development is fully described in the application plans and particulars. A copy of this application is enclosed herewith. In addition, a copy of this application is available for viewing and downloading on the dedicated project website below: www.STEP220kVConnection.com.

Public consultation in respect to this application runs for a seven-week period commencing on 07 August 2024. Any submission / observation must be received by An Bord Pleanála **no later than 5.30p.m on 25 September 2024**. Such submissions / observations must also include the following information:

- The name of the person making the submission or observation, the name of the person acting on his or her behalf, if any, and the address to which any correspondence relating to the application should be sent,
- The subject matter of the submission or observation, and
- The reasons, considerations and arguments on which the submission or observation is based in full.

Any submissions or observations which do not comply with the above requirements cannot be considered by An Bord Pleanála.

Submissions/ observations shall relate to:

- i. The implications of the Proposed Development for proper planning and sustainable development of the area concerned, and
- ii. The likely effects on the environment of the Proposed Development, if carried out.
- iii. The likely significant effects of the Proposed Development on a European Site, if carried out.

Please note that An Bord Pleanála, following its consideration of the application can decide to:

- i. Grant the permission, or
- ii. Make such modifications to the Proposed Development as it specifies in its decision and grant permission in respect of the Proposed Development as so modified, or
- iii. Grant permission in respect of part of the Proposed Development (with or without specified modifications of it of the foregoing kind), and any of the above decisions may be subject to or without conditions, or
- iv. Refuse to grant the permission.

Any enquiries relating to the application process should be directed to the Strategic Infrastructure Development Section of An Bord Pleanála (Tel. 01-8588100 or sids@pleanala.ie).

Yours faithfully,



Gráinne Reid
Senior Environmental Planner
+44 (0)28 9089 5853
grainne.reid@mottmac.com

An Chomhairle Ealaíon
The Arts Council
70 Merrion Square
Dublin
D02 NY52

Your Reference
Shannon LNG Grid
Connection

Our Reference
229100682

Mott MacDonald
South Block
Rockfield
Dundrum
Dublin 16
D16 R6V0
Ireland

T +353 (0)1 2916 700
mottmac.com

Directors: B Williams BE (Hons) MEngSc
CEng MIEI FConsEI (Managing), R
Jefferson MSCSI MRICS BSc Dip Con
Law, J Shinkwin BE (Hons) DipMechEng
CEng MIEI, T Keane BE (Hons) CEng
MIET, J H K Harris BSc CEng (British), C
H Travers MEng CEng (British), I M
Galbraith MRICS BSc (Hons) MSc
(British), E G Roud FCA MA (Hons)
Economics (British)
Innealtóirí Comhairleach (Consulting
Engineers)
Company Secretary: E Counihan ACCA
Registered in Ireland no. 53280.
Mott MacDonald Ireland Limited is a
member of the Mott MacDonald Group

Notification of intention to seek approval in accordance with Section 182A of the Planning and Development Act, 2000, as amended, for Strategic Infrastructure Development.

30 July 2024

Dear Sir/Madam,

Please be advised that Shannon LNG Limited intends to apply to An Bord Pleanála for approval for development in the townlands of Carhoona, Carhoonakilla, Carhoonakineely, Cockhill, Coolnagoonagh, Farranawana, Kilcolgan Lower, Kilcolgan Upper, Kilpaddoge and Ralappane, County Kerry, on or after the 30 July 2024, pursuant to the provisions of Section 182A of the Planning and Development Act 2000, as amended.

An Bord Pleanála, under Article 213(1) of the Planning and Development Regulations 2001, as amended, has identified the An Chomhairle Ealaíon as a prescribed body for the purposes of this Strategic Infrastructure Development application, and is therefore provided with the application documents.

The permission, if granted, will comprise the following:

a) An EirGrid plc operated Gas Insulated Switchgear (GIS) substation compound (Glansillagh 220kV substation) measuring a total footprint of approximately 3,666.4 sqm, enclosed with a 2.6m high security fence and 1.4m high post and rail fence in the townland of Ralappane, and comprising of the following:

- 1no. 906.5 sqm. two storey GIS 220kV building measuring 17m in height,
- 1no. Reactor compound (19m L x 18m W) enclosed with 2.6m high security fencing and containing 3no. shunt reactors (3.4m diameter x 10m H),
- Associated Air Insulated Switchgear electrical equipment including cable sealing ends (6.2m H), surge arrestors and associated steelwork (6.2m H), post insulators (6.2m H) and 2no. lightning masts (18.5m high);

b) A Customer operated Gas Insulated Switchgear (GIS) substation compound (Knockfinglas 220kV substation) measuring a total footprint of approximately 3,166 sqm. enclosed with a 2.6m high security fence in the townland of Ralappane and including 1no. two storey 220kV GIS building measuring 925 sqm. and 17m in height; with associated 11.4m high Gas Insulated Busbar (GIB);

- c) 5km 220kV underground cables and fibre optic cable, 2.8km for which cable ducting and cables will be provided off-road, and 2.2km of cable will be pulled through existing cable ducting within the L1010, and associated cable joint bays, communication chambers and link boxes along the cable route; and
- d) All associated ancillary site development works to facilitate the proposed development including, surface water drainage, lighting arrangements, temporary construction compounds and laydown areas, hardstanding, access tracks, vegetation clearance and decommissioning of an existing 220kV underground cable.

Both an Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) have been prepared in respect of the proposed development and accompany this application for approval.

The proposed development relates to development which comprises an activity required to be licenced by the Environmental Protection Agency (EPA) under an Industrial Emission Licence.

The nature, extent and location of the proposed development is fully described in the application plans and particulars. A copy of this application is enclosed herewith. In addition, a copy of this application is available for viewing and downloading on the dedicated project website below: www.STEP220kVConnection.com.

Public consultation in respect to this application runs for a seven-week period commencing on 07 August 2024. Any submission / observation must be received by An Bord Pleanála **no later than 5.30p.m on 25 September 2024**. Such submissions / observations must also include the following information:

- The name of the person making the submission or observation, the name of the person acting on his or her behalf, if any, and the address to which any correspondence relating to the application should be sent,
- The subject matter of the submission or observation, and
- The reasons, considerations and arguments on which the submission or observation is based in full.

Any submissions or observations which do not comply with the above requirements cannot be considered by An Bord Pleanála.

Submissions/ observations shall relate to:

- i. The implications of the Proposed Development for proper planning and sustainable development of the area concerned, and
- ii. The likely effects on the environment of the Proposed Development, if carried out.
- iii. The likely significant effects of the Proposed Development on a European Site, if carried out.

Please note that An Bord Pleanála, following its consideration of the application can decide to:

- i. Grant the permission, or
- ii. Make such modifications to the Proposed Development as it specifies in its decision and grant permission in respect of the Proposed Development as so modified, or
- iii. Grant permission in respect of part of the Proposed Development (with or without specified modifications of it of the foregoing kind), and any of the above decisions may be subject to or without conditions, or
- iv. Refuse to grant the permission.

Any enquiries relating to the application process should be directed to the Strategic Infrastructure Development Section of An Bord Pleanála (Tel. 01-8588100 or sids@pleanala.ie).

Yours faithfully,



Gráinne Reid
Senior Environmental Planner
+44 (0)28 9089 5853
grainne.reid@mottmac.com

Mr Ger Croke
The Heritage Council
Áras na hOidhreachta
Church Lane
Kilkenny
R95 X264

Your Reference
Shannon LNG Grid
Connection

Our Reference
229100682

Mott MacDonald
South Block
Rockfield
Dundrum
Dublin 16
D16 R6V0
Ireland

T +353 (0)1 2916 700
mottmac.com

Directors: B Williams BE (Hons) MEngSc
CEng MIEI FConsEI (Managing), R
Jefferson MSCSI MRICS BSc Dip Con
Law, J Shinkwin BE (Hons) DipMechEng
CEng MIEI, T Keane BE (Hons) CEng
MIET, J H K Harris BSc CEng (British), C
H Travers MEng CEng (British), I M
Galbraith MRICS BSc (Hons) MSc
(British), E G Roud FCA MA (Hons)
Economics (British)
Innealtóirí Comhairleach (Consulting
Engineers)
Company Secretary: E Counihan ACCA
Registered in Ireland no. 53280.
Mott MacDonald Ireland Limited is a
member of the Mott MacDonald Group

**Notification of intention to seek approval in accordance with Section
182A of the Planning and Development Act, 2000, as amended, for
Strategic Infrastructure Development**

30 July 2024

Dear Mr Ger Croke,

Please be advised that Shannon LNG Limited intends to apply to An Bord Pleanála for approval for development in the townlands of Carhoona, Carhoonakilla, Carhoonakineely, Cockhill, Coolnagoonagh, Farranawana, Kilcolgan Lower, Kilcolgan Upper, Kilpaddoge and Ralappane, County Kerry, on or after the 30 July 2024, pursuant to the provisions of Section 182A of the Planning and Development Act 2000, as amended.

An Bord Pleanála, under Article 213(1) of the Planning and Development Regulations 2001, as amended, has identified The Heritage Council as a prescribed body for the purposes of this Strategic Infrastructure Development application, and is therefore provided with the application documents.

The permission, if granted, will comprise the following:

a) An EirGrid plc operated Gas Insulated Switchgear (GIS) substation compound (Glansillagh 220kV substation) measuring a total footprint of approximately 3,666.4 sqm, enclosed with a 2.6m high security fence and 1.4m high post and rail fence in the townland of Ralappane, and comprising of the following:

- 1no. 906.5 sqm. two storey GIS 220kV building measuring 17m in height,
- 1no. Reactor compound (19m L x 18m W) enclosed with 2.6m high security fencing and containing 3no. shunt reactors (3.4m diameter x 10m H),
- Associated Air Insulated Switchgear electrical equipment including cable sealing ends (6.2m H), surge arrestors and associated steelwork (6.2m H), post insulators (6.2m H) and 2no. lightning masts (18.5m high);

b) A Customer operated Gas Insulated Switchgear (GIS) substation compound (Knockfinglas 220kV substation) measuring a total footprint of approximately 3,166 sqm. enclosed with a 2.6m high security fence in the townland of Ralappane and including 1no. two storey 220kV GIS building measuring 925 sqm. and 17m in height; with associated 11.4m high Gas Insulated Busbar (GIB);

- c) 5km 220kV underground cables and fibre optic cable, 2.8km for which cable ducting and cables will be provided off-road, and 2.2km of cable will be pulled through existing cable ducting within the L1010, and associated cable joint bays, communication chambers and link boxes along the cable route; and
- d) All associated ancillary site development works to facilitate the proposed development including, surface water drainage, lighting arrangements, temporary construction compounds and laydown areas, hardstanding, access tracks, vegetation clearance and decommissioning of an existing 220kV underground cable.

Both an Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) have been prepared in respect of the proposed development and accompany this application for approval.

The proposed development relates to development which comprises an activity required to be licenced by the Environmental Protection Agency (EPA) under an Industrial Emission Licence.

The nature, extent and location of the proposed development is fully described in the application plans and particulars. A copy of this application is enclosed herewith. In addition, a copy of this application is available for viewing and downloading on the dedicated project website below: www.STEP220kVConnection.com.

Public consultation in respect to this application runs for a seven-week period commencing on 07 August 2024. Any submission / observation must be received by An Bord Pleanála **no later than 5.30p.m on 25 September 2024**. Such submissions / observations must also include the following information:

- The name of the person making the submission or observation, the name of the person acting on his or her behalf, if any, and the address to which any correspondence relating to the application should be sent,
- The subject matter of the submission or observation, and
- The reasons, considerations and arguments on which the submission or observation is based in full.

Any submissions or observations which do not comply with the above requirements cannot be considered by An Bord Pleanála.

Submissions/ observations shall relate to:

- i. The implications of the Proposed Development for proper planning and sustainable development of the area concerned, and
- ii. The likely effects on the environment of the Proposed Development, if carried out.
- iii. The likely significant effects of the Proposed Development on a European Site, if carried out.

Please note that An Bord Pleanála, following its consideration of the application can decide to:

- i. Grant the permission, or
- ii. Make such modifications to the Proposed Development as it specifies in its decision and grant permission in respect of the Proposed Development as so modified, or
- iii. Grant permission in respect of part of the Proposed Development (with or without specified modifications of it of the foregoing kind), and any of the above decisions may be subject to or without conditions, or
- iv. Refuse to grant the permission.

Any enquiries relating to the application process should be directed to the Strategic Infrastructure Development Section of An Bord Pleanála (Tel. 01-8588100 or sids@pleanala.ie).

Yours faithfully,



Gráinne Reid
Senior Environmental Planner
+44 (0)28 9089 5853
grainne.reid@mottmac.com

Mr Shane Dineen
Planning and Environment
Fáilte Ireland
Áras Fáilte
88-95 Amiens Street
D01 WR86

Your Reference
Shannon LNG Grid
Connection

Our Reference
229100682

Mott MacDonald
South Block
Rockfield
Dundrum
Dublin 16
D16 R6V0
Ireland

T +353 (0)1 2916 700
mottmac.com

Directors: B Williams BE (Hons) MEngSc
CEng MIEI FConsEI (Managing), R
Jefferson MSCSI MRICS BSc Dip Con
Law, J Shinkwin BE (Hons) DipMechEng
CEng MIEI, T Keane BE (Hons) CEng
MIET, J H K Harris BSc CEng (British), C
H Travers MEng CEng (British), I M
Galbraith MRICS BSc (Hons) MSc
(British), E G Roud FCA MA (Hons)
Economics (British)
Innealtóirí Comhairleach (Consulting
Engineers)
Company Secretary: E Counihan ACCA
Registered in Ireland no. 53280.
Mott MacDonald Ireland Limited is a
member of the Mott MacDonald Group

Notification of intention to seek approval in accordance with Section 182A of the Planning and Development Act, 2000, as amended, for Strategic Infrastructure Development.

30 July 2024

Dear Mr Dineen,

Please be advised that Shannon LNG Limited intends to apply to An Bord Pleanála for approval for development in the townlands of Carhoona, Carhoonakilla, Carhoonakineely, Cockhill, Coolnagoonagh, Farranawana, Kilcolgan Lower, Kilcolgan Upper, Kilpaddoge and Ralappane, County Kerry, on or after the 30 July 2024, pursuant to the provisions of Section 182A of the Planning and Development Act 2000, as amended.

An Bord Pleanála, under Article 213(1) of the Planning and Development Regulations 2001, as amended, has identified Fáilte Ireland as a prescribed body for the purposes of this Strategic Infrastructure Development application, and is therefore provided with the application documents.

The permission, if granted, will comprise the following:

a) An EirGrid plc operated Gas Insulated Switchgear (GIS) substation compound (Glansillagh 220kV substation) measuring a total footprint of approximately 3,666.4 sqm, enclosed with a 2.6m high security fence and 1.4m high post and rail fence in the townland of Ralappane, and comprising of the following:

- 1no. 906.5 sqm. two storey GIS 220kV building measuring 17m in height,
- 1no. Reactor compound (19m L x 18m W) enclosed with 2.6m high security fencing and containing 3no. shunt reactors (3.4m diameter x 10m H),
- Associated Air Insulated Switchgear electrical equipment including cable sealing ends (6.2m H), surge arrestors and associated steelwork (6.2m H), post insulators (6.2m H) and 2no. lightning masts (18.5m high);

b) A Customer operated Gas Insulated Switchgear (GIS) substation compound (Knockfinglas 220kV substation) measuring a total footprint of approximately 3,166 sqm. enclosed with a 2.6m high security fence in the townland of Ralappane and including 1no. two storey 220kV GIS building measuring 925 sqm. and 17m in height; with associated 11.4m high Gas Insulated Busbar (GIB);

- c) 5km 220kV underground cables and fibre optic cable, 2.8km for which cable ducting and cables will be provided off-road, and 2.2km of cable will be pulled through existing cable ducting within the L1010, and associated cable joint bays, communication chambers and link boxes along the cable route; and
- d) All associated ancillary site development works to facilitate the proposed development including, surface water drainage, lighting arrangements, temporary construction compounds and laydown areas, hardstanding, access tracks, vegetation clearance and decommissioning of an existing 220kV underground cable.

Both an Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) have been prepared in respect of the proposed development and accompany this application for approval.

The proposed development relates to development which comprises an activity required to be licenced by the Environmental Protection Agency (EPA) under an Industrial Emission Licence.

The nature, extent and location of the proposed development is fully described in the application plans and particulars. A copy of this application is enclosed herewith. In addition, a copy of this application is available for viewing and downloading on the dedicated project website below: www.STEP220kVConnection.com.

Public consultation in respect to this application runs for a seven-week period commencing on 07 August 2024. Any submission / observation must be received by An Bord Pleanála **no later than 5.30p.m on 25 September 2024**. Such submissions / observations must also include the following information:

- The name of the person making the submission or observation, the name of the person acting on his or her behalf, if any, and the address to which any correspondence relating to the application should be sent,
- The subject matter of the submission or observation, and
- The reasons, considerations and arguments on which the submission or observation is based in full.

Any submissions or observations which do not comply with the above requirements cannot be considered by An Bord Pleanála.

Submissions/ observations shall relate to:

- i. The implications of the Proposed Development for proper planning and sustainable development of the area concerned, and
- ii. The likely effects on the environment of the Proposed Development, if carried out.
- iii. The likely significant effects of the Proposed Development on a European Site, if carried out.

Please note that An Bord Pleanála, following its consideration of the application can decide to:

- i. Grant the permission, or
- ii. Make such modifications to the Proposed Development as it specifies in its decision and grant permission in respect of the Proposed Development as so modified, or
- iii. Grant permission in respect of part of the Proposed Development (with or without specified modifications of it of the foregoing kind), and any of the above decisions may be subject to or without conditions, or
- iv. Refuse to grant the permission.

Any enquiries relating to the application process should be directed to the Strategic Infrastructure Development Section of An Bord Pleanála (Tel. 01-8588100 or sids@pleanala.ie).

Yours faithfully,



Gráinne Reid
Senior Environmental Planner
+44 (0)28 9089 5853
grainne.reid@mottmac.com

An Taisce
The National Trust for Ireland
Back Lane Tailors' Hall
Dublin
D08 X2A3

Your Reference
Shannon LNG Grid
Connection

Our Reference
229100682

Mott MacDonald
South Block
Rockfield
Dundrum
Dublin 16
D16 R6V0
Ireland

T +353 (0)1 2916 700
mottmac.com

Notification of intention to seek approval in accordance with Section 182A of the Planning and Development Act, 2000, as amended, for Strategic Infrastructure Development.

30 July 2024

Dear Sir/Madam,

Please be advised that Shannon LNG Limited intends to apply to An Bord Pleanála for approval for development in the townlands of Carhoona, Carhoonakilla, Carhoonakineely, Cockhill, Coolnagoonagh, Farranawana, Kilcolgan Lower, Kilcolgan Upper, Kilpaddoge and Ralappane, County Kerry, on or after the 30 July 2024, pursuant to the provisions of Section 182A of the Planning and Development Act 2000, as amended.

An Bord Pleanála, under Article 213(1) of the Planning and Development Regulations 2001, as amended, has identified An Taisce as a prescribed body for the purposes of this Strategic Infrastructure Development application, and is therefore provided with the application documents.

The permission, if granted, will comprise the following:

a) An EirGrid plc operated Gas Insulated Switchgear (GIS) substation compound (Glansillagh 220kV substation) measuring a total footprint of approximately 3,666.4 sqm, enclosed with a 2.6m high security fence and 1.4m high post and rail fence in the townland of Ralappane, and comprising of the following:

- 1no. 906.5 sqm. two storey GIS 220kV building measuring 17m in height,
- 1no. Reactor compound (19m L x 18m W) enclosed with 2.6m high security fencing and containing 3no. shunt reactors (3.4m diameter x 10m H),
- Associated Air Insulated Switchgear electrical equipment including cable sealing ends (6.2m H), surge arrestors and associated steelwork (6.2m H), post insulators (6.2m H) and 2no. lightning masts (18.5m high);

b) A Customer operated Gas Insulated Switchgear (GIS) substation compound (Knockfinglas 220kV substation) measuring a total footprint of approximately 3,166 sqm. enclosed with a 2.6m high security fence in the townland of Ralappane and including 1no. two storey 220kV GIS building measuring 925 sqm. and 17m in height; with associated 11.4m high Gas Insulated Busbar (GIB);

- c) 5km 220kV underground cables and fibre optic cable, 2.8km for which cable ducting and cables will be provided off-road, and 2.2km of cable will be pulled through existing cable ducting within the L1010, and associated cable joint bays, communication chambers and link boxes along the cable route; and
- d) All associated ancillary site development works to facilitate the proposed development including, surface water drainage, lighting arrangements, temporary construction compounds and laydown areas, hardstanding, access tracks, vegetation clearance and decommissioning of an existing 220kV underground cable.

Both an Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) have been prepared in respect of the proposed development and accompany this application for approval.

The proposed development relates to development which comprises an activity required to be licenced by the Environmental Protection Agency (EPA) under an Industrial Emission Licence.

The nature, extent and location of the proposed development is fully described in the application plans and particulars. A copy of this application is enclosed herewith. In addition, a copy of this application is available for viewing and downloading on the dedicated project website below: www.STEP220kVConnection.com.

Public consultation in respect to this application runs for a seven-week period commencing on 07 August 2024. Any submission / observation must be received by An Bord Pleanála **no later than 5.30p.m on 25 September 2024**. Such submissions / observations must also include the following information:

- The name of the person making the submission or observation, the name of the person acting on his or her behalf, if any, and the address to which any correspondence relating to the application should be sent,
- The subject matter of the submission or observation, and
- The reasons, considerations and arguments on which the submission or observation is based in full.

Any submissions or observations which do not comply with the above requirements cannot be considered by An Bord Pleanála.

Submissions/ observations shall relate to:

- i. The implications of the Proposed Development for proper planning and sustainable development of the area concerned, and
- ii. The likely effects on the environment of the Proposed Development, if carried out.
- iii. The likely significant effects of the Proposed Development on a European Site, if carried out.

Please note that An Bord Pleanála, following its consideration of the application can decide to:

- i. Grant the permission, or
- ii. Make such modifications to the Proposed Development as it specifies in its decision and grant permission in respect of the Proposed Development as so modified, or
- iii. Grant permission in respect of part of the Proposed Development (with or without specified modifications of it of the foregoing kind), and any of the above decisions may be subject to or without conditions, or
- iv. Refuse to grant the permission.

Any enquiries relating to the application process should be directed to the Strategic Infrastructure Development Section of An Bord Pleanála (Tel. 01-8588100 or sids@pleanala.ie).

Yours faithfully,



Gráinne Reid
Senior Environmental Planner
+44 (0)28 9089 5853
grainne.reid@mottmac.com

Mr Kevin Lynch
Southern Regional Assembly
Assembly House,
Waterford, Ireland
X91 F8PC

Your Reference
Shannon LNG Grid
Connection

Our Reference
229100682

Mott MacDonald
South Block
Rockfield
Dundrum
Dublin 16
D16 R6V0
Ireland

T +353 (0)1 2916 700
mottmac.com

Directors: B Williams BE (Hons) MEngSc
CEng MIEI FConsEI (Managing), R
Jefferson MSCSI MRICS BSc Dip Con
Law, J Shinkwin BE (Hons) DipMechEng
CEng MIEI, T Keane BE (Hons) CEng
MIET, J H K Harris BSc CEng (British), C
H Travers MEng CEng (British), I M
Galbraith MRICS BSc (Hons) MSc
(British), E G Roud FCA MA (Hons)
Economics (British)
Innealtóirí Comhairleach (Consulting
Engineers)
Company Secretary: E Counihan ACCA
Registered in Ireland no. 53280.
Mott MacDonald Ireland Limited is a
member of the Mott MacDonald Group

Notification of intention to seek approval in accordance with Section 182A of the Planning and Development Act, 2000, as amended, for Strategic Infrastructure Development.

30 July 2024

Dear My Lynch,

Please be advised that Shannon LNG Limited intends to apply to An Bord Pleanála for approval for development in the townlands of Carhoona, Carhoonakilla, Carhoonakineely, Cockhill, Coolnagoonagh, Farranawana, Kilcolgan Lower, Kilcolgan Upper, Kilpaddoge and Ralappane, County Kerry, on or after the 30 July 2024, pursuant to the provisions of Section 182A of the Planning and Development Act 2000, as amended.

An Bord Pleanála, under Article 213(1) of the Planning and Development Regulations 2001, as amended, has identified The Southern Regional Assembly as a prescribed body for the purposes of this Strategic Infrastructure Development application, and is therefore provided with the application documents.

The permission, if granted, will comprise the following:

a) An EirGrid plc operated Gas Insulated Switchgear (GIS) substation compound (Glansillagh 220kV substation) measuring a total footprint of approximately 3,666.4 sqm, enclosed with a 2.6m high security fence and 1.4m high post and rail fence in the townland of Ralappane, and comprising of the following:

- 1no. 906.5 sqm. two storey GIS 220kV building measuring 17m in height,
- 1no. Reactor compound (19m L x 18m W) enclosed with 2.6m high security fencing and containing 3no. shunt reactors (3.4m diameter x 10m H),
- Associated Air Insulated Switchgear electrical equipment including cable sealing ends (6.2m H), surge arrestors and associated steelwork (6.2m H), post insulators (6.2m H) and 2no. lightning masts (18.5m high);

b) A Customer operated Gas Insulated Switchgear (GIS) substation compound (Knockfinglas 220kV substation) measuring a total footprint of approximately 3,166 sqm. enclosed with a 2.6m high security fence in the townland of

- Ralappane and including 1no. two storey 220kV GIS building measuring 925 sqm. and 17m in height; with associated 11.4m high Gas Insulated Busbar (GIB);
- c) 5km 220kV underground cables and fibre optic cable, 2.8km for which cable ducting and cables will be provided off-road, and 2.2km of cable will be pulled through existing cable ducting within the L1010, and associated cable joint bays, communication chambers and link boxes along the cable route; and
 - d) All associated ancillary site development works to facilitate the proposed development including, surface water drainage, lighting arrangements, temporary construction compounds and laydown areas, hardstanding, access tracks, vegetation clearance and decommissioning of an existing 220kV underground cable.

Both an Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) have been prepared in respect of the proposed development and accompany this application for approval.

The proposed development relates to development which comprises an activity required to be licenced by the Environmental Protection Agency (EPA) under an Industrial Emission Licence.

The nature, extent and location of the proposed development is fully described in the application plans and particulars. A copy of this application is enclosed herewith. In addition, a copy of this application is available for viewing and downloading on the dedicated project website below: www.STEP220kVConnection.com.

Public consultation in respect to this application runs for a seven-week period commencing on 07 August 2024. Any submission / observation must be received by An Bord Pleanála **no later than 5.30p.m on 25 September 2024**. Such submissions / observations must also include the following information:

- The name of the person making the submission or observation, the name of the person acting on his or her behalf, if any, and the address to which any correspondence relating to the application should be sent,
- The subject matter of the submission or observation, and
- The reasons, considerations and arguments on which the submission or observation is based in full.

Any submissions or observations which do not comply with the above requirements cannot be considered by An Bord Pleanála.

Submissions/ observations shall relate to:

- i. The implications of the Proposed Development for proper planning and sustainable development of the area concerned, and
- ii. The likely effects on the environment of the Proposed Development, if carried out.
- iii. The likely significant effects of the Proposed Development on a European Site, if carried out.

Please note that An Bord Pleanála, following its consideration of the application can decide to:

- i. Grant the permission, or
- ii. Make such modifications to the Proposed Development as it specifies in its decision and grant permission in respect of the Proposed Development as so modified, or
- iii. Grant permission in respect of part of the Proposed Development (with or without specified modifications of it of the foregoing kind), and any of the above decisions may be subject to or without conditions, or
- iv. Refuse to grant the permission.

Any enquiries relating to the application process should be directed to the Strategic Infrastructure Development Section of An Bord Pleanála (Tel. 01-8588100 or sids@pleanala.ie).

Yours faithfully,



Gráinne Reid
Senior Environmental Planner
+44 (0)28 9089 5853
grainne.reid@mottmac.com

Mr Cillian Claffey
Uisce Éireann
Covill House
24-26 Talbot Street
Dublin
D01 NP86

Your Reference
Shannon LNG Grid
Connection

Our Reference
229100682

Mott MacDonald
South Block
Rockfield
Dundrum
Dublin 16
D16 R6V0
Ireland

T +353 (0)1 2916 700
mottmac.com

Directors: B Williams BE (Hons) MEngSc
CEng MIEI FConsEI (Managing), R
Jefferson MSCSI MRICS BSc Dip Con
Law, J Shinkwin BE (Hons) DipMechEng
CEng MIEI, T Keane BE (Hons) CEEng
MIET, J H K Harris BSc CEEng (British), C
H Travers MEng CEEng (British), I M
Galbraith MRICS BSc (Hons) MSc
(British), E G Roud FCA MA (Hons)
Economics (British)
Innealtóirí Comhairleach (Consulting
Engineers)
Company Secretary: E Counihan ACCA
Registered in Ireland no. 53280.
Mott MacDonald Ireland Limited is a
member of the Mott MacDonald Group

**Notification of intention to seek approval in accordance with Section
182A of the Planning and Development Act, 2000, as amended, for
Strategic Infrastructure Development**

30 July 2024

Dear Mr Claffey,

Please be advised that Shannon LNG Limited intends to apply to An Bord Pleanála for permission for development in the townlands of Carhoona, Carhoonakilla, Carhoonakineely, Cockhill, Coolnagoonagh, Farranawana, Kilcolgan Lower, Kilcolgan Upper, Kilpaddoge and Ralappane, County Kerry, on or after the 30 July 2024, pursuant to the provisions of Section 182A of the Planning and Development Act 2000, as amended.

An Bord Pleanála, under Article 213(1) of the Planning and Development Regulations 2001, as amended, has identified Uisce Éireann as a prescribed body for the purposes of this Strategic Infrastructure Development application, and is therefore provided with the application documents.

The permission, if granted, will comprise the following:

a) An EirGrid plc operated Gas Insulated Switchgear (GIS) substation compound (Glansillagh 220kV substation) measuring a total footprint of approximately 3,666.4 sqm, enclosed with a 2.6m high security fence and 1.4m high post and rail fence in the townland of Ralappane, and comprising of the following:

- 1no. 906.5 sqm. two storey GIS 220kV building measuring 17m in height,
- 1no. Reactor compound (19m L x 18m W) enclosed with 2.6m high security fencing and containing 3no. shunt reactors (3.4m diameter x 10m H),
- Associated Air Insulated Switchgear electrical equipment including cable sealing ends (6.2m H), surge arrestors and associated steelwork (6.2m H), post insulators (6.2m H) and 2no. lightning masts (18.5m high);

b) A Customer operated Gas Insulated Switchgear (GIS) substation compound (Knockfinglas 220kV substation) measuring a total footprint of approximately 3,166 sqm. enclosed with a 2.6m high security fence in the townland of Ralappane and including 1no. two storey 220kV GIS building measuring 925 sqm. and 17m in height; with associated 11.4m high Gas Insulated Busbar (GIB);

- c) 5km 220kV underground cables and fibre optic cable, 2.8km for which cable ducting and cables will be provided off-road, and 2.2km of cable will be pulled through existing cable ducting within the L1010, and associated cable joint bays, communication chambers and link boxes along the cable route; and
- d) All associated ancillary site development works to facilitate the proposed development including, surface water drainage, lighting arrangements, temporary construction compounds and laydown areas, hardstanding, access tracks, vegetation clearance and decommissioning of an existing 220kV underground cable.

Both an Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) have been prepared in respect of the proposed development and accompany this application for approval.

The proposed development relates to development which comprises an activity required to be licenced by the Environmental Protection Agency (EPA) under an Industrial Emission Licence.

The nature, extent and location of the proposed development is fully described in the application plans and particulars. A copy of this application is enclosed herewith. In addition, a copy of this application is available for viewing and downloading on the dedicated project website below: www.STEP220kVConnection.com.

Public consultation in respect to this application runs for a seven-week period commencing on 07 August 2024. Any submission / observation must be received by An Bord Pleanála **no later than 5.30p.m on 25 September 2024**. Such submissions / observations must also include the following information:

- The name of the person making the submission or observation, the name of the person acting on his or her behalf, if any, and the address to which any correspondence relating to the application should be sent,
- The subject matter of the submission or observation, and
- The reasons, considerations and arguments on which the submission or observation is based in full.

Any submissions or observations which do not comply with the above requirements cannot be considered by An Bord Pleanála.

Submissions/ observations shall relate to:

- i. The implications of the Proposed Development for proper planning and sustainable development of the area concerned, and
- ii. The likely effects on the environment of the Proposed Development, if carried out.
- iii. The likely significant effects of the Proposed Development on a European Site, if carried out.

Please note that An Bord Pleanála, following its consideration of the application can decide to:

- i. Grant the permission, or
- ii. Make such modifications to the Proposed Development as it specifies in its decision and grant permission in respect of the Proposed Development as so modified, or
- iii. Grant permission in respect of part of the Proposed Development (with or without specified modifications of it of the foregoing kind), and any of the above decisions may be subject to or without conditions, or
- iv. Refuse to grant the permission.

Any enquiries relating to the application process should be directed to the Strategic Infrastructure Development Section of An Bord Pleanála (Tel. 01-8588100 or sids@pleanala.ie).

Yours faithfully,



Gráinne Reid
Senior Environmental Planner
+44 (0)28 9089 5853
grainne.reid@mottmac.com

Ms Jane Gilleran
Inland Fisheries Ireland
Belmont
Drumsna
Carrick on Shannon,
Co. Leitrim
N41 HD78

Your Reference
Shannon LNG Grid
Connection

Our Reference
229100682

Mott MacDonald
South Block
Rockfield
Dundrum
Dublin 16
D16 R6V0
Ireland

T +353 (0)1 2916 700
mottmac.com

Directors: B Williams BE (Hons) MEngSc
CEng MIEI FConsEI (Managing), R
Jefferson MSCSI MRICS BSc Dip Con
Law, J Shinkwin BE (Hons) DipMechEng
CEng MIEI, T Keane BE (Hons) CEEng
MIET, J H K Harris BSc CEEng (British), C
H Travers MEng CEEng (British), I M
Galbraith MRICS BSc (Hons) MSc
(British), E G Roud FCA MA (Hons)
Economics (British)
Innealtóirí Comhairleach (Consulting
Engineers)
Company Secretary: E Counihan ACCA
Registered in Ireland no. 53280.
Mott MacDonald Ireland Limited is a
member of the Mott MacDonald Group

Notification of intention to seek approval in accordance with Section 182A of the Planning and Development Act, 2000, as amended, for Strategic Infrastructure Development

30 July 2024

Dear Ms Gilleran,

Please be advised that Shannon LNG Limited intends to apply to An Bord Pleanála for permission for development in the townlands of Carhoona, Carhoonakilla, Carhoonakineely, Cockhill, Coolnagoonagh, Farranawana, Kilcolgan Lower, Kilcolgan Upper, Kilpaddoge and Ralappane, County Kerry, on or after the 30 July 2024, pursuant to the provisions of Section 182A of the Planning and Development Act 2000, as amended.

An Bord Pleanála, under Article 213(1) of the Planning and Development Regulations 2001, as amended, has identified Inland Fisheries Ireland as a prescribed body for the purposes of this Strategic Infrastructure Development application, and is therefore provided with the application documents.

The permission, if granted, will comprise the following:

a) An EirGrid plc operated Gas Insulated Switchgear (GIS) substation compound (Glansillagh 220kV substation) measuring a total footprint of approximately 3,666.4 sqm, enclosed with a 2.6m high security fence and 1.4m high post and rail fence in the townland of Ralappane, and comprising of the following:

- 1no. 906.5 sqm. two storey GIS 220kV building measuring 17m in height,
- 1no. Reactor compound (19m L x 18m W) enclosed with 2.6m high security fencing and containing 3no. shunt reactors (3.4m diameter x 10m H),
- Associated Air Insulated Switchgear electrical equipment including cable sealing ends (6.2m H), surge arrestors and associated steelwork (6.2m H), post insulators (6.2m H) and 2no. lightning masts (18.5m high);

b) A Customer operated Gas Insulated Switchgear (GIS) substation compound (Knockfinglas 220kV substation) measuring a total footprint of approximately 3,166 sqm. enclosed with a 2.6m high security fence in the townland of Ralappane and including 1no. two storey 220kV GIS building measuring 925 sqm. and 17m in height; with associated 11.4m high Gas Insulated Busbar (GIB);

- c) 5km 220kV underground cables and fibre optic cable, 2.8km for which cable ducting and cables will be provided off-road, and 2.2km of cable will be pulled through existing cable ducting within the L1010, and associated cable joint bays, communication chambers and link boxes along the cable route; and
- d) All associated ancillary site development works to facilitate the proposed development including, surface water drainage, lighting arrangements, temporary construction compounds and laydown areas, hardstanding, access tracks, vegetation clearance and decommissioning of an existing 220kV underground cable.

Both an Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) have been prepared in respect of the proposed development and accompany this application for approval.

The proposed development relates to development which comprises an activity required to be licenced by the Environmental Protection Agency (EPA) under an Industrial Emission Licence.

The nature, extent and location of the proposed development is fully described in the application plans and particulars. A copy of this application is enclosed herewith. In addition, a copy of this application is available for viewing and downloading on the dedicated project website below: www.STEP220kVConnection.com.

Public consultation in respect to this application runs for a seven-week period commencing on 07 August 2024. Any submission / observation must be received by An Bord Pleanála **no later than 5.30p.m on 25 September 2024**. Such submissions / observations must also include the following information:

- The name of the person making the submission or observation, the name of the person acting on his or her behalf, if any, and the address to which any correspondence relating to the application should be sent,
- The subject matter of the submission or observation, and
- The reasons, considerations and arguments on which the submission or observation is based in full.

Any submissions or observations which do not comply with the above requirements cannot be considered by An Bord Pleanála.

Submissions/ observations shall relate to:

- i. The implications of the Proposed Development for proper planning and sustainable development of the area concerned, and
- ii. The likely effects on the environment of the Proposed Development, if carried out.
- iii. The likely significant effects of the Proposed Development on a European Site, if carried out.

Please note that An Bord Pleanála, following its consideration of the application can decide to:

- i. Grant the permission, or
- ii. Make such modifications to the Proposed Development as it specifies in its decision and grant permission in respect of the Proposed Development as so modified, or
- iii. Grant permission in respect of part of the Proposed Development (with or without specified modifications of it of the foregoing kind), and any of the above decisions may be subject to or without conditions, or
- iv. Refuse to grant the permission.

Any enquiries relating to the application process should be directed to the Strategic Infrastructure Development Section of An Bord Pleanála (Tel. 01-8588100 or sids@pleanala.ie).

Yours faithfully,



Gráinne Reid
Senior Environmental Planner
+44 (0)28 9089 5853
grainne.reid@mottmac.com

Waterways Ireland
Western Regional Office
Scarriff Harbour
Drewnsborough
Scarrif
Co. Clare

Your Reference
Shannon LNG Grid
Connection

Our Reference
229100682

Mott MacDonald
South Block
Rockfield
Dundrum
Dublin 16
D16 R6V0
Ireland

T +353 (0)1 2916 700
mottmac.com

Directors: B Williams BE (Hons) MEngSc
CEng MIEI FConsEI (Managing), R
Jefferson MSCSI MRICS BSc Dip Con
Law, J Shinkwin BE (Hons) DipMechEng
CEng MIEI, T Keane BE (Hons) CEEng
MIET, J H K Harris BSc CEEng (British), C
H Travers MEng CEEng (British), I M
Galbraith MRICS BSc (Hons) MSc
(British), E G Roud FCA MA (Hons)
Economics (British)
Innealtóirí Comhairleach (Consulting
Engineers)
Company Secretary: E Counihan ACCA
Registered in Ireland no. 53280.
Mott MacDonald Ireland Limited is a
member of the Mott MacDonald Group

Notification of intention to seek approval in accordance with Section 182A of the Planning and Development Act, 2000, as amended, for Strategic Infrastructure Development

30 July 2024

Dear Sir/Madam,

Please be advised that Shannon LNG Limited intends to apply to An Bord Pleanála for permission for development in the townlands of Carhoona, Carhoonakilla, Carhoonakineely, Cockhill, Coolnagoonagh, Farranawana, Kilcolgan Lower, Kilcolgan Upper, Kilpaddoge and Ralappane, County Kerry, on or after the 30 July 2024, pursuant to the provisions of Section 182A of the Planning and Development Act 2000, as amended.

An Bord Pleanála, under Article 213(1) of the Planning and Development Regulations 2001, as amended, has identified Waterways Ireland as a prescribed body for the purposes of this Strategic Infrastructure Development application, and is therefore provided with the application documents.

The permission, if granted, will comprise the following:

a) An EirGrid plc operated Gas Insulated Switchgear (GIS) substation compound (Glansillagh 220kV substation) measuring a total footprint of approximately 3,666.4 sqm, enclosed with a 2.6m high security fence and 1.4m high post and rail fence in the townland of Ralappane, and comprising of the following:

- 1no. 906.5 sqm. two storey GIS 220kV building measuring 17m in height,
- 1no. Reactor compound (19m L x 18m W) enclosed with 2.6m high security fencing and containing 3no. shunt reactors (3.4m diameter x 10m H),
- Associated Air Insulated Switchgear electrical equipment including cable sealing ends (6.2m H), surge arrestors and associated steelwork (6.2m H), post insulators (6.2m H) and 2no. lightning masts (18.5m high);

b) A Customer operated Gas Insulated Switchgear (GIS) substation compound (Knockfinglas 220kV substation) measuring a total footprint of approximately 3,166 sqm. enclosed with a 2.6m high security fence in the townland of Ralappane and including 1no. two storey 220kV GIS building measuring 925 sqm. and 17m in height; with associated 11.4m high Gas Insulated Busbar (GIB);

- c) 5km 220kV underground cables and fibre optic cable, 2.8km for which cable ducting and cables will be provided off-road, and 2.2km of cable will be pulled through existing cable ducting within the L1010, and associated cable joint bays, communication chambers and link boxes along the cable route; and
- d) All associated ancillary site development works to facilitate the proposed development including, surface water drainage, lighting arrangements, temporary construction compounds and laydown areas, hardstanding, access tracks, vegetation clearance and decommissioning of an existing 220kV underground cable.

Both an Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) have been prepared in respect of the proposed development and accompany this application for approval.

The proposed development relates to development which comprises an activity required to be licenced by the Environmental Protection Agency (EPA) under an Industrial Emission Licence.

The nature, extent and location of the proposed development is fully described in the application plans and particulars. A copy of this application is enclosed herewith. In addition, a copy of this application is available for viewing and downloading on the dedicated project website below: www.STEP220kVConnection.com.

Public consultation in respect to this application runs for a seven-week period commencing on 07 August 2024. Any submission / observation must be received by An Bord Pleanála **no later than 5.30p.m on 25 September 2024**. Such submissions / observations must also include the following information:

- The name of the person making the submission or observation, the name of the person acting on his or her behalf, if any, and the address to which any correspondence relating to the application should be sent,
- The subject matter of the submission or observation, and
- The reasons, considerations and arguments on which the submission or observation is based in full.

Any submissions or observations which do not comply with the above requirements cannot be considered by An Bord Pleanála.

Submissions/ observations shall relate to:

- i. The implications of the Proposed Development for proper planning and sustainable development of the area concerned, and
- ii. The likely effects on the environment of the Proposed Development, if carried out.
- iii. The likely significant effects of the Proposed Development on a European Site, if carried out.

Please note that An Bord Pleanála, following its consideration of the application can decide to:

- i. Grant the permission, or
- ii. Make such modifications to the Proposed Development as it specifies in its decision and grant permission in respect of the Proposed Development as so modified, or
- iii. Grant permission in respect of part of the Proposed Development (with or without specified modifications of it of the foregoing kind), and any of the above decisions may be subject to or without conditions, or
- iv. Refuse to grant the permission.

Any enquiries relating to the application process should be directed to the Strategic Infrastructure Development Section of An Bord Pleanála (Tel. 01-8588100 or sids@pleanala.ie).

Yours faithfully,



Gráinne Reid
Senior Environmental Planner
+44 (0)28 9089 5853
grainne.reid@mottmac.com

Minister McConalogue
Department of Agriculture Food and Marine
Agriculture House
Kildare Street
Dublin
D02 WK12

Your Reference
Shannon LNG Grid
Connection

Our Reference
229100682

Mott MacDonald
South Block
Rockfield
Dundrum
Dublin 16
D16 R6V0
Ireland

T +353 (0)1 2916 700
mottmac.com

Notification of intention to seek approval in accordance with Section 182A of the Planning and Development Act, 2000, as amended, for Strategic Infrastructure Development

30 July 2024

Dear Minister McConalogue,

Please be advised that Shannon LNG Limited intends to apply to An Bord Pleanála for permission for development in the townlands of Carhoona, Carhoonakilla, Carhoonakineely, Cockhill, Coolnagoonagh, Farranawana, Kilcolgan Lower, Kilcolgan Upper, Kilpaddoge and Ralappane in County Kerry, on or after the 30 July 2024, pursuant to the provisions of Section 182A of the Planning and Development Act 2000, as amended.

An Bord Pleanála, under Article 213(1) of the Planning and Development Regulations 2001, as amended, has identified The Minister for Agriculture Food and Marine as a prescribed body for the purposes of this Strategic Infrastructure Development application, and is therefore provided with the application documents.

The permission, if granted, will comprise the following:

a) An EirGrid plc operated Gas Insulated Switchgear (GIS) substation compound (Glansillagh 220kV substation) measuring a total footprint of approximately 3,666.4 sqm, enclosed with a 2.6m high security fence and 1.4m high post and rail fence in the townland of Ralappane, and comprising of the following:

- 1no. 906.5 sqm. two storey GIS 220kV building measuring 17m in height,
- 1no. Reactor compound (19m L x 18m W) enclosed with 2.6m high security fencing and containing 3no. shunt reactors (3.4m diameter x 10m H),
- Associated Air Insulated Switchgear electrical equipment including cable sealing ends (6.2m H), surge arrestors and associated steelwork (6.2m H), post insulators (6.2m H) and 2no. lightning masts (18.5m high);

b) A Customer operated Gas Insulated Switchgear (GIS) substation compound (Knockfinglas 220kV substation) measuring a total footprint of approximately 3,166 sqm. enclosed with a 2.6m high security fence in the townland of

Ralappane and including 1 no. two storey 220kV GIS building measuring 925 sqm. and 17m in height; with associated 11.4m high Gas Insulated Busbar (GIB);

- c) 5km 220kV underground cables and fibre optic cable, 2.8km for which cable ducting and cables will be provided off-road, and 2.2km of cable will be pulled through existing cable ducting within the L1010, and associated cable joint bays, communication chambers and link boxes along the cable route; and
- d) All associated ancillary site development works to facilitate the proposed development including, surface water drainage, lighting arrangements, temporary construction compounds and laydown areas, hardstanding, access tracks, vegetation clearance and decommissioning of an existing 220kV underground cable.

Both an Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) have been prepared in respect of the proposed development and accompany this application for approval.

The proposed development relates to development which comprises an activity required to be licenced by the Environmental Protection Agency (EPA) under an Industrial Emission Licence.

The nature, extent and location of the proposed development is fully described in the application plans and particulars. A copy of this application is enclosed herewith. In addition, a copy of this application is available for viewing and downloading on the dedicated project website below: www.STEP220kVConnection.com.

Public consultation in respect to this application runs for a seven-week period commencing on 07 August 2024. Any submission / observation must be received by An Bord Pleanála **no later than 5.30p.m on 25 September 2024**. Such submissions / observations must also include the following information:

- The name of the person making the submission or observation, the name of the person acting on his or her behalf, if any, and the address to which any correspondence relating to the application should be sent,
- The subject matter of the submission or observation, and
- The reasons, considerations and arguments on which the submission or observation is based in full.

Any submissions or observations which do not comply with the above requirements cannot be considered by An Bord Pleanála.

Submissions/ observations shall relate to:

- i. The implications of the Proposed Development for proper planning and sustainable development of the area concerned, and
- ii. The likely effects on the environment of the Proposed Development, if carried out.
- iii. The likely significant effects of the Proposed Development on a European Site, if carried out.

Please note that An Bord Pleanála, following its consideration of the application can decide to:

- i. Grant the permission, or
- ii. Make such modifications to the Proposed Development as it specifies in its decision and grant permission in respect of the Proposed Development as so modified, or
- iii. Grant permission in respect of part of the Proposed Development (with or without specified modifications of it of the foregoing kind), and any of the above decisions may be subject to or without conditions, or
- iv. Refuse to grant the permission.

Any enquiries relating to the application process should be directed to the Strategic Infrastructure Development Section of An Bord Pleanála (Tel. 01-8588100 or sids@pleanala.ie).

Mott MacDonald

Yours faithfully,

A handwritten signature in dark ink, appearing to read 'Grainne Reid', written in a cursive style.

Gráinne Reid
Senior Environmental Planner
+442890895853
grainne.reid@mottmac.com

Minister Catherine Martin
Department of Tourism, Culture, Arts,
Gaeltacht, Sports and Media
23 Kildare Street
Dublin
D02 TD30

Your Reference
Shannon LNG Grid
Connection

Our Reference
229100682

Mott MacDonald
South Block
Rockfield
Dundrum
Dublin 16
D16 R6V0
Ireland

T +353 (0)1 2916 700
mottmac.com

Notification of intention to seek approval in accordance with Section 182A of the Planning and Development Act, 2000, as amended, for Strategic Infrastructure Development

30 July 2024

Dear Minister Martin

Please be advised that Shannon LNG Limited intends to apply to An Bord Pleanála for permission for development in the townlands of Carhoona, Carhoonakilla, Carhoonakineely, Cockhill, Coolnagoonagh, Farranawana, Kilcolgan Lower, Kilcolgan Upper, Kilpaddoge and Ralappane, County Kerry, on or after the 30 July 2024, pursuant to the provisions of Section 182A of the Planning and Development Act 2000, as amended.

An Bord Pleanála, under Article 213(1) of the Planning and Development Regulations 2001, as amended, has identified The Minister for Tourism, Culture, Arts, Sports and Media as a prescribed body for the purposes of this Strategic Infrastructure Development application, and is therefore provided with the application documents.

The permission, if granted, will comprise the following:

a) An EirGrid plc operated Gas Insulated Switchgear (GIS) substation compound (Glansillagh 220kV substation) measuring a total footprint of approximately 3,666.4 sqm, enclosed with a 2.6m high security fence and 1.4m high post and rail fence in the townland of Ralappane, and comprising of the following:

- 1no. 906.5 sqm. two storey GIS 220kV building measuring 17m in height,
- 1no. Reactor compound (19m L x 18m W) enclosed with 2.6m high security fencing and containing 3no. shunt reactors (3.4m diameter x 10m H),
- Associated Air Insulated Switchgear electrical equipment including cable sealing ends (6.2m H), surge arrestors and associated steelwork (6.2m H), post insulators (6.2m H) and 2no. lightning masts (18.5m high);

b) A Customer operated Gas Insulated Switchgear (GIS) substation compound (Knockfinglas 220kV substation) measuring a total footprint of approximately 3,166 sqm. enclosed with a 2.6m high security fence in the townland of

- Ralappane and including 1no. two storey 220kV GIS building measuring 925 sqm. and 17m in height; with associated 11.4m high Gas Insulated Busbar (GIB);
- c) 5km 220kV underground cables and fibre optic cable, 2.8km for which cable ducting and cables will be provided off-road, and 2.2km of cable will be pulled through existing cable ducting within the L1010, and associated cable joint bays, communication chambers and link boxes along the cable route; and
 - d) All associated ancillary site development works to facilitate the proposed development including, surface water drainage, lighting arrangements, temporary construction compounds and laydown areas, hardstanding, access tracks, vegetation clearance and decommissioning of an existing 220kV underground cable.

Both an Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) have been prepared in respect of the proposed development and accompany this application for approval.

The proposed development relates to development which comprises an activity required to be licenced by the Environmental Protection Agency (EPA) under an Industrial Emission Licence.

The nature, extent and location of the proposed development is fully described in the application plans and particulars. A copy of this application is enclosed herewith. In addition, a copy of this application is available for viewing and downloading on the dedicated project website below: www.STEP220kVConnection.com.

Public consultation in respect to this application runs for a seven-week period commencing on 07 August 2024. Any submission / observation must be received by An Bord Pleanála **no later than 5.30p.m on 25 September 2024**. Such submissions / observations must also include the following information:

- The name of the person making the submission or observation, the name of the person acting on his or her behalf, if any, and the address to which any correspondence relating to the application should be sent,
- The subject matter of the submission or observation, and
- The reasons, considerations and arguments on which the submission or observation is based in full.

Any submissions or observations which do not comply with the above requirements cannot be considered by An Bord Pleanála.

Submissions/ observations shall relate to:

- i. The implications of the Proposed Development for proper planning and sustainable development of the area concerned, and
- ii. The likely effects on the environment of the Proposed Development, if carried out.
- iii. The likely significant effects of the Proposed Development on a European Site, if carried out.

Please note that An Bord Pleanála, following its consideration of the application can decide to:

- i. Grant the permission, or
- ii. Make such modifications to the Proposed Development as it specifies in its decision and grant permission in respect of the Proposed Development as so modified, or
- iii. Grant permission in respect of part of the Proposed Development (with or without specified modifications of it of the foregoing kind), and any of the above decisions may be subject to or without conditions, or
- iv. Refuse to grant the permission.

Any enquiries relating to the application process should be directed to the Strategic Infrastructure Development Section of An Bord Pleanála (Tel. 01-8588100 or sids@pleanala.ie).

Yours faithfully,



Gráinne Reid
Senior Environmental Planner
+44 (0)28 9089 5853
grainne.reid@mottmac.com

Mr Kevin O'Connor
Health Service Executive
HSE South Estates
Block 2, St. Finbarr's Hospital
Douglas Road
Cork
T12 XH60

Your Reference
Shannon LNG Grid
Connection

Our Reference
229100682

Mott MacDonald
South Block
Rockfield
Dundrum
Dublin 16
D16 R6V0
Ireland

T +353 (0)1 2916 700
mottmac.com

Notification of intention to seek approval in accordance with Section 182A of the Planning and Development Act, 2000, as amended, for Strategic Infrastructure Development

30 July 2024

Dear Mr O'Connor,

Please be advised that Shannon LNG Limited intends to apply to An Bord Pleanála for permission for development in the townlands of Carhoona, Carhoonakilla, Carhoonakineely, Cockhill, Coolnagoonagh, Farranawana, Kilcolgan Lower, Kilcolgan Upper, Kilpaddoge and Ralappane, County Kerry, on or after the 30 July 2024, pursuant to the provisions of Section 182A of the Planning and Development Act 2000, as amended.

An Bord Pleanála, under Article 213(1) of the Planning and Development Regulations 2001, as amended, has identified the HSE as a prescribed body for the purposes of this Strategic Infrastructure Development application, and is therefore provided with the application documents.

The permission, if granted, will comprise the following:

a) An EirGrid plc operated Gas Insulated Switchgear (GIS) substation compound (Glansillagh 220kV substation) measuring a total footprint of approximately 3,666.4 sqm, enclosed with a 2.6m high security fence and 1.4m high post and rail fence in the townland of Ralappane, and comprising of the following:

- 1no. 906.5 sqm. two storey GIS 220kV building measuring 17m in height,
- 1no. Reactor compound (19m L x 18m W) enclosed with 2.6m high security fencing and containing 3no. shunt reactors (3.4m diameter x 10m H),
- Associated Air Insulated Switchgear electrical equipment including cable sealing ends (6.2m H), surge arrestors and associated steelwork (6.2m H), post insulators (6.2m H) and 2no. lightning masts (18.5m high);

b) A Customer operated Gas Insulated Switchgear (GIS) substation compound (Knockfinglas 220kV substation) measuring a total footprint of approximately 3,166 sqm. enclosed with a 2.6m high security fence in the townland of Ralappane and including 1no. two storey 220kV GIS building measuring 925 sqm. and 17m in height; with associated 11.4m high Gas Insulated Busbar (GIB);

- c) 5km 220kV underground cables and fibre optic cable, 2.8km for which cable ducting and cables will be provided off-road, and 2.2km of cable will be pulled through existing cable ducting within the L1010, and associated cable joint bays, communication chambers and link boxes along the cable route; and
- d) All associated ancillary site development works to facilitate the proposed development including, surface water drainage, lighting arrangements, temporary construction compounds and laydown areas, hardstanding, access tracks, vegetation clearance and decommissioning of an existing 220kV underground cable.

Both an Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) have been prepared in respect of the proposed development and accompany this application for approval.

The proposed development relates to development which comprises an activity required to be licenced by the Environmental Protection Agency (EPA) under an Industrial Emission Licence.

The nature, extent and location of the proposed development is fully described in the application plans and particulars. A copy of this application is enclosed herewith. In addition, a copy of this application is available for viewing and downloading on the dedicated project website below: www.STEP220kVConnection.com.

Public consultation in respect to this application runs for a seven-week period commencing on 07 August 2024. Any submission / observation must be received by An Bord Pleanála **no later than 5.30p.m on 25 September 2024**. Such submissions / observations must also include the following information:

- The name of the person making the submission or observation, the name of the person acting on his or her behalf, if any, and the address to which any correspondence relating to the application should be sent,
- The subject matter of the submission or observation, and
- The reasons, considerations and arguments on which the submission or observation is based in full.

Any submissions or observations which do not comply with the above requirements cannot be considered by An Bord Pleanála.

Submissions/ observations shall relate to:

- i. The implications of the Proposed Development for proper planning and sustainable development of the area concerned, and
- ii. The likely effects on the environment of the Proposed Development, if carried out.
- iii. The likely significant effects of the Proposed Development on a European Site, if carried out.

Please note that An Bord Pleanála, following its consideration of the application can decide to:

- i. Grant the permission, or
- ii. Make such modifications to the Proposed Development as it specifies in its decision and grant permission in respect of the Proposed Development as so modified, or
- iii. Grant permission in respect of part of the Proposed Development (with or without specified modifications of it of the foregoing kind), and any of the above decisions may be subject to or without conditions, or
- iv. Refuse to grant the permission.

Any enquiries relating to the application process should be directed to the Strategic Infrastructure Development Section of An Bord Pleanála (Tel. 01-8588100 or sids@pleanala.ie).

Yours faithfully,



Gráinne Reid
Senior Environmental Planner
+44 (0)28 9089 5853
grainne.reid@mottmac.com

Health and Safety Authority (SEVESO)
Head Office
Metropolitan Building
James Joyce Street
Dublin
D01 K0Y8

Your Reference
Shannon LNG Grid
Connection

Our Reference
229100682

Mott MacDonald
South Block
Rockfield
Dundrum
Dublin 16
D16 R6V0
Ireland

T +353 (0)1 2916 700
mottmac.com

Notification of intention to seek approval in accordance with Section 182A of the Planning and Development Act, 2000, as amended, for Strategic Infrastructure Development

30 July 2024

Dear Sir/Madam,

Please be advised that Shannon LNG Limited intends to apply to An Bord Pleanála for permission for development in the townlands of Carhoona, Carhoonakilla, Carhoonakineely, Cockhill, Coolnagoonagh, Farranawana, Kilcolgan Lower, Kilcolgan Upper, Kilpaddogem and Ralappane, County Kerry, on or after the 30 July 2024, pursuant to the provisions of Section 182A of the Planning and Development Act 2000, as amended.

An Bord Pleanála, under Article 213(1) of the Planning and Development Regulations 2001, as amended, has identified the Health and Safety Authority as a prescribed body for the purposes of this Strategic Infrastructure Development application, and is therefore provided with the application documents.

The permission, if granted, will comprise the following:

a) An EirGrid plc operated Gas Insulated Switchgear (GIS) substation compound (Glansillagh 220kV substation) measuring a total footprint of approximately 3,666.4 sqm, enclosed with a 2.6m high security fence and 1.4m high post and rail fence in the townland of Ralappane, and comprising of the following:

- 1no. 906.5 sqm. two storey GIS 220kV building measuring 17m in height,
- 1no. Reactor compound (19m L x 18m W) enclosed with 2.6m high security fencing and containing 3no. shunt reactors (3.4m diameter x 10m H),
- Associated Air Insulated Switchgear electrical equipment including cable sealing ends (6.2m H), surge arrestors and associated steelwork (6.2m H), post insulators (6.2m H) and 2no. lightning masts (18.5m high);

b) A Customer operated Gas Insulated Switchgear (GIS) substation compound (Knockfinglas 220kV substation) measuring a total footprint of approximately 3,166 sqm. enclosed with a 2.6m high security fence in the townland of

- Ralappane and including 1no. two storey 220kV GIS building measuring 925 sqm. and 17m in height; with associated 11.4m high Gas Insulated Busbar (GIB);
- c) 5km 220kV underground cables and fibre optic cable, 2.8km for which cable ducting and cables will be provided off-road, and 2.2km of cable will be pulled through existing cable ducting within the L1010, and associated cable joint bays, communication chambers and link boxes along the cable route; and
 - d) All associated ancillary site development works to facilitate the proposed development including, surface water drainage, lighting arrangements, temporary construction compounds and laydown areas, hardstanding, access tracks, vegetation clearance and decommissioning of an existing 220kV underground cable.

Both an Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) have been prepared in respect of the proposed development and accompany this application for approval.

The proposed development relates to development which comprises an activity required to be licenced by the Environmental Protection Agency (EPA) under an Industrial Emission Licence.

The nature, extent and location of the proposed development is fully described in the application plans and particulars. A copy of this application is enclosed herewith. In addition, a copy of this application is available for viewing and downloading on the dedicated project website below: www.STEP220kVConnection.com.

Public consultation in respect to this application runs for a seven-week period commencing on 07 August 2024. Any submission / observation must be received by An Bord Pleanála **no later than 5.30p.m on 25 September 2024**. Such submissions / observations must also include the following information:

- The name of the person making the submission or observation, the name of the person acting on his or her behalf, if any, and the address to which any correspondence relating to the application should be sent,
- The subject matter of the submission or observation, and
- The reasons, considerations and arguments on which the submission or observation is based in full.

Any submissions or observations which do not comply with the above requirements cannot be considered by An Bord Pleanála.

Submissions/ observations shall relate to:

- i. The implications of the Proposed Development for proper planning and sustainable development of the area concerned, and
- ii. The likely effects on the environment of the Proposed Development, if carried out.
- iii. The likely significant effects of the Proposed Development on a European Site, if carried out.

Please note that An Bord Pleanála, following its consideration of the application can decide to:

- i. Grant the permission, or
- ii. Make such modifications to the Proposed Development as it specifies in its decision and grant permission in respect of the Proposed Development as so modified, or
- iii. Grant permission in respect of part of the Proposed Development (with or without specified modifications of it of the foregoing kind), and any of the above decisions may be subject to or without conditions, or
- iv. Refuse to grant the permission.

Any enquiries relating to the application process should be directed to the Strategic Infrastructure Development Section of An Bord Pleanála (Tel. 01-8588100 or sids@pleanala.ie).

Yours faithfully,



Gráinne Reid
Senior Environmental Planner
+44 (0)28 9089 5853
grainne.reid@mottmac.com

Ms Natasha Anderson
Commission for Regulation of Utilities
The Grain House,
Belgard Square North
The Exchange
Tallaght
Dublin

Your Reference
Shannon LNG Grid
Connection

Our Reference
229100682

Mott MacDonald
South Block
Rockfield
Dundrum
Dublin 16
D16 R6V0
Ireland

T +353 (0)1 2916 700
mottmac.com

Notification of intention to seek approval in accordance with Section 182A of the Planning and Development Act, 2000, as amended, for Strategic Infrastructure Development

30 July 2024

Dear Ms Anderson,

Please be advised that Shannon LNG Limited intends to apply to An Bord Pleanála for permission for development in the townlands of Carhoona, Carhoonakilla, Carhoonakineely, Cockhill, Coolnagoonagh, Farranawana, Kilcolgan Lower, Kilcolgan Upper, Kilpaddoge and Ralappane, County Kerry, on or after the 30 July 2024, pursuant to the provisions of Section 182A of the Planning and Development Act 2000, as amended.

An Bord Pleanála, under Article 213(1) of the Planning and Development Regulations 2001, as amended, has identified the Commission for Regulation of Utilities as a prescribed body for the purposes of this Strategic Infrastructure Development application, and is therefore provided with the application documents.

The permission, if granted, will comprise the following:

a) An EirGrid plc operated Gas Insulated Switchgear (GIS) substation compound (Glansillagh 220kV substation) measuring a total footprint of approximately 3,666.4 sqm, enclosed with a 2.6m high security fence and 1.4m high post and rail fence in the townland of Ralappane, and comprising of the following:

- 1no. 906.5 sqm. two storey GIS 220kV building measuring 17m in height,
- 1no. Reactor compound (19m L x 18m W) enclosed with 2.6m high security fencing and containing 3no. shunt reactors (3.4m diameter x 10m H),
- Associated Air Insulated Switchgear electrical equipment including cable sealing ends (6.2m H), surge arrestors and associated steelwork (6.2m H), post insulators (6.2m H) and 2no. lightning masts (18.5m high);

b) A Customer operated Gas Insulated Switchgear (GIS) substation compound (Knockfinglas 220kV substation) measuring a total footprint of approximately 3,166 sqm. enclosed with a 2.6m high security fence in the townland of

- Ralappane and including 1 no. two storey 220kV GIS building measuring 925 sqm. and 17m in height; with associated 11.4m high Gas Insulated Busbar (GIB);
- c) 5km 220kV underground cables and fibre optic cable, 2.8km for which cable ducting and cables will be provided off-road, and 2.2km of cable will be pulled through existing cable ducting within the L1010, and associated cable joint bays, communication chambers and link boxes along the cable route; and
 - d) All associated ancillary site development works to facilitate the proposed development including, surface water drainage, lighting arrangements, temporary construction compounds and laydown areas, hardstanding, access tracks, vegetation clearance and decommissioning of an existing 220kV underground cable.

Both an Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) have been prepared in respect of the proposed development and accompany this application for approval.

The proposed development relates to development which comprises an activity required to be licenced by the Environmental Protection Agency (EPA) under an Industrial Emission Licence.

The nature, extent and location of the proposed development is fully described in the application plans and particulars. A copy of this application is enclosed herewith. In addition, a copy of this application is available for viewing and downloading on the dedicated project website below: www.STEP220kVConnection.com.

Public consultation in respect to this application runs for a seven-week period commencing on 07 August 2024. Any submission / observation must be received by An Bord Pleanála **no later than 5.30p.m on 25 September 2024**. Such submissions / observations must also include the following information:

- The name of the person making the submission or observation, the name of the person acting on his or her behalf, if any, and the address to which any correspondence relating to the application should be sent,
- The subject matter of the submission or observation, and
- The reasons, considerations and arguments on which the submission or observation is based in full.

Any submissions or observations which do not comply with the above requirements cannot be considered by An Bord Pleanála.

Submissions/ observations shall relate to:

- i. The implications of the Proposed Development for proper planning and sustainable development of the area concerned, and
- ii. The likely effects on the environment of the Proposed Development, if carried out.
- iii. The likely significant effects of the Proposed Development on a European Site, if carried out.

Please note that An Bord Pleanála, following its consideration of the application can decide to:

- i. Grant the permission, or
- ii. Make such modifications to the Proposed Development as it specifies in its decision and grant permission in respect of the Proposed Development as so modified, or
- iii. Grant permission in respect of part of the Proposed Development (with or without specified modifications of it of the foregoing kind), and any of the above decisions may be subject to or without conditions, or
- iv. Refuse to grant the permission.

Any enquiries relating to the application process should be directed to the Strategic Infrastructure Development Section of An Bord Pleanála (Tel. 01-8588100 or sids@pleanala.ie).

Yours faithfully,



Gráinne Reid
Senior Environmental Planner
+44 (0)28 9089 5853
grainne.reid@mottmac.com

Mr Robert Mooney
Office of Public Works
Jonathan Swift Street
Trim
Co Meath
C15 NX36

Your Reference
Shannon LNG Grid
Connection

Our Reference
229100682

Mott MacDonald
South Block
Rockfield
Dundrum
Dublin 16
D16 R6V0
Ireland

T +353 (0)1 2916 700
mottmac.com

Directors: B Williams BE (Hons) MEngSc
CEng MIEI FConsEI (Managing), R
Jefferson MSCSI MRICS BSc Dip Con
Law, J Shinkwin BE (Hons) DipMechEng
CEng MIEI, T Keane BE (Hons) CEEng
MIET, J H K Harris BSc CEEng (British), C
H Travers MEng CEEng (British), I M
Galbraith MRICS BSc (Hons) MSc
(British), E G Roud FCA MA (Hons)
Economics (British)
Innealtóirí Comhairleach (Consulting
Engineers)
Company Secretary: E Counihan ACCA
Registered in Ireland no. 53280.
Mott MacDonald Ireland Limited is a
member of the Mott MacDonald Group

Notification of intention to seek approval in accordance with Section 182A of the Planning and Development Act, 2000, as amended, for Strategic Infrastructure Development

30 July 2024

Dear Mr Mooney,

Please be advised that Shannon LNG Limited intends to apply to An Bord Pleanála for permission for development in the townlands of Carhoona, Carhoonakilla, Carhoonakineely, Cockhill, Coolnagoonagh, Farranawana, Kilcolgan Lower, Kilcolgan Upper, Kilpaddoge and Ralappane, County Kerry, on or after the 30 July 2024, pursuant to the provisions of Section 182A of the Planning and Development Act 2000, as amended.

An Bord Pleanála, under Article 213(1) of the Planning and Development Regulations 2001, as amended, has identified the Office of Public Works as a prescribed body for the purposes of this Strategic Infrastructure Development application, and is therefore provided with the application documents.

The permission, if granted, will comprise the following:

a) An EirGrid plc operated Gas Insulated Switchgear (GIS) substation compound (Glansillagh 220kV substation) measuring a total footprint of approximately 3,666.4 sqm, enclosed with a 2.6m high security fence and 1.4m high post and rail fence in the townland of Ralappane, and comprising of the following:

- 1no. 906.5 sqm. two storey GIS 220kV building measuring 17m in height,
- 1no. Reactor compound (19m L x 18m W) enclosed with 2.6m high security fencing and containing 3no. shunt reactors (3.4m diameter x 10m H),
- Associated Air Insulated Switchgear electrical equipment including cable sealing ends (6.2m H), surge arrestors and associated steelwork (6.2m H), post insulators (6.2m H) and 2no. lightning masts (18.5m high);

b) A Customer operated Gas Insulated Switchgear (GIS) substation compound (Knockfinglas 220kV substation) measuring a total footprint of approximately 3,166 sqm. enclosed with a 2.6m high security fence in the townland of Ralappane and including 1no. two storey 220kV GIS building measuring 925 sqm. and 17m in height; with associated 11.4m high Gas Insulated Busbar (GIB);

- c) 5km 220kV underground cables and fibre optic cable, 2.8km for which cable ducting and cables will be provided off-road, and 2.2km of cable will be pulled through existing cable ducting within the L1010, and associated cable joint bays, communication chambers and link boxes along the cable route; and
- d) All associated ancillary site development works to facilitate the proposed development including, surface water drainage, lighting arrangements, temporary construction compounds and laydown areas, hardstanding, access tracks, vegetation clearance and decommissioning of an existing 220kV underground cable.

Both an Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) have been prepared in respect of the proposed development and accompany this application for approval.

The proposed development relates to development which comprises an activity required to be licenced by the Environmental Protection Agency (EPA) under an Industrial Emission Licence.

The nature, extent and location of the proposed development is fully described in the application plans and particulars. A copy of this application is enclosed herewith. In addition, a copy of this application is available for viewing and downloading on the dedicated project website below: www.STEP220kVConnection.com.

Public consultation in respect to this application runs for a seven-week period commencing on 07 August 2024. Any submission / observation must be received by An Bord Pleanála **no later than 5.30p.m on 25 September 2024**. Such submissions / observations must also include the following information:

- The name of the person making the submission or observation, the name of the person acting on his or her behalf, if any, and the address to which any correspondence relating to the application should be sent,
- The subject matter of the submission or observation, and
- The reasons, considerations and arguments on which the submission or observation is based in full.

Any submissions or observations which do not comply with the above requirements cannot be considered by An Bord Pleanála.

Submissions/ observations shall relate to:

- i. The implications of the Proposed Development for proper planning and sustainable development of the area concerned, and
- ii. The likely effects on the environment of the Proposed Development, if carried out.
- iii. The likely significant effects of the Proposed Development on a European Site, if carried out.

Please note that An Bord Pleanála, following its consideration of the application can decide to:

- i. Grant the permission, or
- ii. Make such modifications to the Proposed Development as it specifies in its decision and grant permission in respect of the Proposed Development as so modified, or
- iii. Grant permission in respect of part of the Proposed Development (with or without specified modifications of it of the foregoing kind), and any of the above decisions may be subject to or without conditions, or
- iv. Refuse to grant the permission.

Any enquiries relating to the application process should be directed to the Strategic Infrastructure Development Section of An Bord Pleanála (Tel. 01-8588100 or sids@pleanala.ie).

Yours faithfully,



Gráinne Reid
Senior Environmental Planner
+44 (0)28 9089 5853
grainne.reid@mottmac.com

Electricity Supply Board
27 Fitzwilliam Street Lower
Dublin
D02 KT92

Your Reference
Shannon LNG Grid
Connection

Our Reference
229100682

Mott MacDonald
South Block
Rockfield
Dundrum
Dublin 16
D16 R6V0
Ireland

T +353 (0)1 2916 700
mottmac.com

Directors: B Williams BE (Hons) MEngSc
CEng MIEI FConsEI (Managing), R
Jefferson MSCSI MRICS BSc Dip Con
Law, J Shinkwin BE (Hons) DipMechEng
CEng MIEI, T Keane BE (Hons) CEEng
MIET, J H K Harris BSc CEEng (British), C
H Travers MEng CEEng (British), I M
Galbraith MRICS BSc (Hons) MSc
(British), E G Roud FCA MA (Hons)
Economics (British)
Innealtóirí Comhairleach (Consulting
Engineers)
Company Secretary: E Counihan ACCA
Registered in Ireland no. 53280.
Mott MacDonald Ireland Limited is a
member of the Mott MacDonald Group

Notification of intention to seek approval in accordance with Section 182A of the Planning and Development Act, 2000, as amended, for Strategic Infrastructure Development

30 July 2024

Dear Sir/Madam,

Please be advised that Shannon LNG Limited intends to apply to An Bord Pleanála for permission for development in the townlands of Carhoona, Carhoonakilla, Carhoonakineely, Cockhill, Coolnagoonagh, Farranawana, Kilcolgan Lower, Kilcolgan Upper, Kilpaddoge and Ralappane, County Kerry, on or after the 30 July 2024, pursuant to the provisions of Section 182A of the Planning and Development Act 2000, as amended.

An Bord Pleanála, under Article 213(1) of the Planning and Development Regulations 2001, as amended, has identified ESB as a prescribed body for the purposes of this Strategic Infrastructure Development application, and is therefore provided with the application documents.

The permission, if granted, will comprise the following:

a) An EirGrid plc operated Gas Insulated Switchgear (GIS) substation compound (Glansillagh 220kV substation) measuring a total footprint of approximately 3,666.4 sqm, enclosed with a 2.6m high security fence and 1.4m high post and rail fence in the townland of Ralappane, and comprising of the following:

- 1no. 906.5 sqm. two storey GIS 220kV building measuring 17m in height,
- 1no. Reactor compound (19m L x 18m W) enclosed with 2.6m high security fencing and containing 3no. shunt reactors (3.4m diameter x 10m H),
- Associated Air Insulated Switchgear electrical equipment including cable sealing ends (6.2m H), surge arrestors and associated steelwork (6.2m H), post insulators (6.2m H) and 2no. lightning masts (18.5m high);

b) A Customer operated Gas Insulated Switchgear (GIS) substation compound (Knockfinglas 220kV substation) measuring a total footprint of approximately 3,166 sqm. enclosed with a 2.6m high security fence in the townland of Ralappane and including 1no. two storey 220kV GIS building measuring 925 sqm. and 17m in height; with associated 11.4m high Gas Insulated Busbar (GIB);

- c) 5km 220kV underground cables and fibre optic cable, 2.8km for which cable ducting and cables will be provided off-road, and 2.2km of cable will be pulled through existing cable ducting within the L1010, and associated cable joint bays, communication chambers and link boxes along the cable route; and
- d) All associated ancillary site development works to facilitate the proposed development including, surface water drainage, lighting arrangements, temporary construction compounds and laydown areas, hardstanding, access tracks, vegetation clearance and decommissioning of an existing 220kV underground cable.

Both an Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) have been prepared in respect of the proposed development and accompany this application for approval.

The proposed development relates to development which comprises an activity required to be licenced by the Environmental Protection Agency (EPA) under an Industrial Emission Licence.

The nature, extent and location of the proposed development is fully described in the application plans and particulars. A copy of this application is enclosed herewith. In addition, a copy of this application is available for viewing and downloading on the dedicated project website below: www.STEP220kVConnection.com.

Public consultation in respect to this application runs for a seven-week period commencing on 07 August 2024. Any submission / observation must be received by An Bord Pleanála **no later than 5.30p.m on 25 September 2024**. Such submissions / observations must also include the following information:

- The name of the person making the submission or observation, the name of the person acting on his or her behalf, if any, and the address to which any correspondence relating to the application should be sent,
- The subject matter of the submission or observation, and
- The reasons, considerations and arguments on which the submission or observation is based in full.

Any submissions or observations which do not comply with the above requirements cannot be considered by An Bord Pleanála.

Submissions/ observations shall relate to:

- i. The implications of the Proposed Development for proper planning and sustainable development of the area concerned, and
- ii. The likely effects on the environment of the Proposed Development, if carried out.
- iii. The likely significant effects of the Proposed Development on a European Site, if carried out.

Please note that An Bord Pleanála, following its consideration of the application can decide to:

- i. Grant the permission, or
- ii. Make such modifications to the Proposed Development as it specifies in its decision and grant permission in respect of the Proposed Development as so modified, or
- iii. Grant permission in respect of part of the Proposed Development (with or without specified modifications of it of the foregoing kind), and any of the above decisions may be subject to or without conditions, or
- iv. Refuse to grant the permission.

Any enquiries relating to the application process should be directed to the Strategic Infrastructure Development Section of An Bord Pleanála (Tel. 01-8588100 or sids@pleanala.ie).

Yours faithfully,



Gráinne Reid
Senior Environmental Planner
+44 (0)28 9089 5853
grainne.reid@mottmac.com

EirGrid plc
The Oval
160 Shelbourne Road
Ballsbridge
Dublin
D04 FW28

Your Reference
Shannon LNG Grid
Connection

Our Reference
229100682

Mott MacDonald
South Block
Rockfield
Dundrum
Dublin 16
D16 R6V0
Ireland

T +353 (0)1 2916 700
mottmac.com

Directors: B Williams BE (Hons) MEngSc
CEng MIEI FConsEI (Managing), R
Jefferson MSCSI MRICS BSc Dip Con
Law, J Shinkwin BE (Hons) DipMechEng
CEng MIEI, T Keane BE (Hons) CEEng
MIET, J H K Harris BSc CEEng (British), C
H Travers MEng CEEng (British), I M
Galbraith MRICS BSc (Hons) MSc
(British), E G Roud FCA MA (Hons)
Economics (British)
Innealtóirí Comhairleach (Consulting
Engineers)
Company Secretary: E Counihan ACCA
Registered in Ireland no. 53280.
Mott MacDonald Ireland Limited is a
member of the Mott MacDonald Group

Notification of intention to seek approval in accordance with Section 182A of the Planning and Development Act, 2000, as amended, for Strategic Infrastructure Development

30 July 2024

Dear Sir/Madam,

Please be advised that Shannon LNG Limited intends to apply to An Bord Pleanála for permission for development in the townlands of Carhoona, Carhoonakilla, Carhoonakineely, Cockhill, Coolnagoonagh, Farranawana, Kilcolgan Lower, Kilcolgan Upper, Kilpaddoge and Ralappane, County Kerry, on or after the 30 July 2024, pursuant to the provisions of Section 182A of the Planning and Development Act 2000, as amended.

An Bord Pleanála, under Article 213(1) of the Planning and Development Regulations 2001, as amended, has identified EirGrid as a prescribed body for the purposes of this Strategic Infrastructure Development application, and is therefore provided with the application documents.

The permission, if granted, will comprise the following:

a) An EirGrid plc operated Gas Insulated Switchgear (GIS) substation compound (Glansillagh 220kV substation) measuring a total footprint of approximately 3,666.4 sqm, enclosed with a 2.6m high security fence and 1.4m high post and rail fence in the townland of Ralappane, and comprising of the following:

- 1no. 906.5 sqm. two storey GIS 220kV building measuring 17m in height,
- 1no. Reactor compound (19m L x 18m W) enclosed with 2.6m high security fencing and containing 3no. shunt reactors (3.4m diameter x 10m H),
- Associated Air Insulated Switchgear electrical equipment including cable sealing ends (6.2m H), surge arrestors and associated steelwork (6.2m H), post insulators (6.2m H) and 2no. lightning masts (18.5m high);

b) A Customer operated Gas Insulated Switchgear (GIS) substation compound (Knockfinglas 220kV substation) measuring a total footprint of approximately 3,166 sqm. enclosed with a 2.6m high security fence in the townland of Ralappane and including 1no. two storey 220kV GIS building measuring 925 sqm. and 17m in height; with associated 11.4m high Gas Insulated Busbar (GIB);

- c) 5km 220kV underground cables and fibre optic cable, 2.8km for which cable ducting and cables will be provided off-road, and 2.2km of cable will be pulled through existing cable ducting within the L1010, and associated cable joint bays, communication chambers and link boxes along the cable route; and
- d) All associated ancillary site development works to facilitate the proposed development including, surface water drainage, lighting arrangements, temporary construction compounds and laydown areas, hardstanding, access tracks, vegetation clearance and decommissioning of an existing 220kV underground cable.

Both an Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) have been prepared in respect of the proposed development and accompany this application for approval.

The proposed development relates to development which comprises an activity required to be licenced by the Environmental Protection Agency (EPA) under an Industrial Emission Licence.

The nature, extent and location of the proposed development is fully described in the application plans and particulars. A copy of this application is enclosed herewith. In addition, a copy of this application is available for viewing and downloading on the dedicated project website below: www.STEP220kVConnection.com.

Public consultation in respect to this application runs for a seven-week period commencing on 07 August 2024. Any submission / observation must be received by An Bord Pleanála **no later than 5.30p.m on 25 September 2024**. Such submissions / observations must also include the following information:

- The name of the person making the submission or observation, the name of the person acting on his or her behalf, if any, and the address to which any correspondence relating to the application should be sent,
- The subject matter of the submission or observation, and
- The reasons, considerations and arguments on which the submission or observation is based in full.

Any submissions or observations which do not comply with the above requirements cannot be considered by An Bord Pleanála.

Submissions/ observations shall relate to:

- i. The implications of the Proposed Development for proper planning and sustainable development of the area concerned, and
- ii. The likely effects on the environment of the Proposed Development, if carried out.
- iii. The likely significant effects of the Proposed Development on a European Site, if carried out.

Please note that An Bord Pleanála, following its consideration of the application can decide to:

- i. Grant the permission, or
- ii. Make such modifications to the Proposed Development as it specifies in its decision and grant permission in respect of the Proposed Development as so modified, or
- iii. Grant permission in respect of part of the Proposed Development (with or without specified modifications of it of the foregoing kind), and any of the above decisions may be subject to or without conditions, or
- iv. Refuse to grant the permission.

Any enquiries relating to the application process should be directed to the Strategic Infrastructure Development Section of An Bord Pleanála (Tel. 01-8588100 or sids@pleanala.ie).

Yours faithfully,



Gráinne Reid
Senior Environmental Planner
+44 (0)28 9089 5853
grainne.reid@mottmac.com

Philomena Kelly
Environmental Licensing Programme
Environmental Protection Agency
Johnstown Castle Estate
Co. Wexford
Y35 W821

Your Reference
Shannon LNG Grid
Connection

Our Reference
229100682

Mott MacDonald
South Block
Rockfield
Dundrum
Dublin 16
D16 R6V0
Ireland

T +353 (0)1 2916 700
mottmac.com

Notification of intention to seek approval in accordance with Section 182A of the Planning and Development Act, 2000, as amended, for Strategic Infrastructure Development

30 July 2024

Dear Ms Kelly,

Please be advised that Shannon LNG Limited intends to apply to An Bord Pleanála for permission for development in the townlands of Carhoona, Carhoonakilla, Carhoonakineely, Cockhill, Coolnagoonagh, Farranawana, Kilcolgan Lower, Kilcolgan Upper, Kilpaddoge and Ralappane, County Kerry, on or after the 30 July 2024, pursuant to the provisions of Section 182A of the Planning and Development Act 2000, as amended.

As the application relates to development which comprises an activity required to be licenced by the Environmental Protection Agency (EPA) under an Industrial Emission Licence, the Environmental Protection Agency (EPA) are being provided with the application documents.

The permission, if granted, will comprise the following:

a) An EirGrid plc operated Gas Insulated Switchgear (GIS) substation compound (Glansillagh 220kV substation) measuring a total footprint of approximately 3,666.4 sqm, enclosed with a 2.6m high security fence and 1.4m high post and rail fence in the townland of Ralappane, and comprising of the following:

- 1no. 906.5 sqm. two storey GIS 220kV building measuring 17m in height,
- 1no. Reactor compound (19m L x 18m W) enclosed with 2.6m high security fencing and containing 3no. shunt reactors (3.4m diameter x 10m H),
- Associated Air Insulated Switchgear electrical equipment including cable sealing ends (6.2m H), surge arrestors and associated steelwork (6.2m H), post insulators (6.2m H) and 2no. lightning masts (18.5m high);

b) A Customer operated Gas Insulated Switchgear (GIS) substation compound (Knockfinglas 220kV substation) measuring a total footprint of approximately 3,166 sqm. enclosed with a 2.6m high security fence in the townland of Ralappane and including 1no. two storey 220kV GIS building measuring 925 sqm. and 17m in height; with associated 11.4m high Gas Insulated Busbar (GIB);

- c) 5km 220kV underground cables and fibre optic cable, 2.8km for which cable ducting and cables will be provided off-road, and 2.2km of cable will be pulled through existing cable ducting within the L1010, and associated cable joint bays, communication chambers and link boxes along the cable route; and
- d) All associated ancillary site development works to facilitate the proposed development including, surface water drainage, lighting arrangements, temporary construction compounds and laydown areas, hardstanding, access tracks, vegetation clearance and decommissioning of an existing 220kV underground cable.

Both an Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) have been prepared in respect of the proposed development and accompany this application for approval.

The proposed development relates to development which comprises an activity required to be licenced by the Environmental Protection Agency (EPA) under an Industrial Emission Licence.

The nature, extent and location of the proposed development is fully described in the application plans and particulars. A copy of this application is enclosed herewith. In addition, a copy of this application is available for viewing and downloading on the dedicated project website below: www.STEP220kVConnection.com.

Public consultation in respect to this application runs for a seven-week period commencing on 07 August 2024. Any submission / observation must be received by An Bord Pleanála **no later than 5.30p.m on 25 September 2024**. Such submissions / observations must also include the following information:

- The name of the person making the submission or observation, the name of the person acting on his or her behalf, if any, and the address to which any correspondence relating to the application should be sent,
- The subject matter of the submission or observation, and
- The reasons, considerations and arguments on which the submission or observation is based in full.

Any submissions or observations which do not comply with the above requirements cannot be considered by An Bord Pleanála.

Submissions/ observations shall relate to:

- i. The implications of the Proposed Development for proper planning and sustainable development of the area concerned, and
- ii. The likely effects on the environment of the Proposed Development, if carried out.
- iii. The likely significant effects of the Proposed Development on a European Site, if carried out.

Please note that An Bord Pleanála, following its consideration of the application can decide to:

- i. Grant the permission, or
- ii. Make such modifications to the Proposed Development as it specifies in its decision and grant permission in respect of the Proposed Development as so modified, or
- iii. Grant permission in respect of part of the Proposed Development (with or without specified modifications of it of the foregoing kind), and any of the above decisions may be subject to or without conditions, or
- iv. Refuse to grant the permission.

Any enquiries relating to the application process should be directed to the Strategic Infrastructure Development Section of An Bord Pleanála (Tel. 01-8588100 or sids@pleanala.ie).

Yours faithfully,



Gráinne Reid
Senior Environmental Planner
+442890895853
grainne.reid@mottmac.com

Elaine A Bennett

From: Housing Eiaportal <EIAportal@housing.gov.ie>
Sent: 17 July 2024 12:03
To: Elaine A Bennett
Subject: EIA Portal Confirmation Notice Portal ID 2024126

Dear Elaine,

An EIA Portal notification was received on 17/07/2024 in respect of this proposed application. The information provided has been uploaded to the EIA Portal on 17/07/2024 under EIA Portal ID number 2024126 and is available to view at <http://housinggovie.maps.arcgis.com/apps/webappviewer/index.html?id=d7d5a3d48f104ecbb206e7e5f84b71f1>.

Portal ID: 2024126

Competent Authority: An Bord Pleanála

Applicant Name: Shannon LNG Limited

Location: Located in the townlands of Carhoona, Carhoonakilla, Carhoonakineely, Cockhill, Coolnagoonagh, Farranawana, Kilcolgan Lower, Kilcolgan Upper, Kilpaddoge and Ralappane, County Kerry

Description: Two 220kV substations and two 220kV underground cable circuits between the Shannon Technology and Energy Park Power Plant and the existing line cable interface mast near the existing Kilpaddoge substation.

Linear Development: Yes

Date Uploaded to Portal: 17/07/2024

Kindest Regards,

Hugh Wogan,

EIA Portal team

An Roinn Tithíochta, Rialtais Áitiúil agus Oidhreachta
Department of Housing, Local Government and Heritage

Teach an Chustaim, Baile Átha Cliath 1, D01 W6X0
Custom House, Dublin 1, D01 W6X0

T +353 (0) 1 888 2142

www.gov.ie/housing



An Roinn Tithíochta,
Rialtais Áitiúil agus Oidhreachta
Department of Housing,
Local Government and Heritage

Shannon Technology and Energy Park (STEP) 220kV Grid Connection

Planning Drawing Schedule

No.	Drawing Reference	Drawing Name	Scale (at A1)
Site Location Maps			
1	229100682-MMD-04-XX-DR-E-0001	Site Location in Geographical Context	1:20,000
2	229100682-MMD-04-XX-DR-E-0002	Site Location Plan - Sheet 1	1:2500
3	229100682-MMD-04-XX-DR-E-0003	Site Location Plan - Sheet 2	1:2500
4	229100682-MMD-04-XX-DR-E-0004	Site Location Plan - Sheet 3	1:2500
Site Layout Plans			
5	229100682-MMD-04-XX-DR-E-0010	Site Layout Key Plan	1:10,000
6	229100682-MMD-04-XX-DR-E-0011	Site Layout Plan - Sheet 1	1:1000
7	229100682-MMD-04-XX-DR-E-0012	Site Layout Plan - Sheet 2	1:1000
8	229100682-MMD-04-XX-DR-E-0013	Site Layout Plan - Sheet 3	1:1000
9	229100682-MMD-04-XX-DR-E-0014	Site Layout Plan - Sheet 4	1:1000
10	229100682-MMD-04-XX-DR-E-0015	Site Layout Plan - Sheet 5	1:1000
11	229100682-MMD-04-XX-DR-E-0016	Site Layout Plan - Sheet 6	1:1000
12	229100682-MMD-04-XX-DR-E-0017	Site Layout Plan - Sheet 7	1:1000
13	229100682-MMD-04-XX-DR-E-0018	Site Layout Plan - Sheet 8	1:1000
220kV Substations			
14	229100682-MMD-04-XX-DR-E-0100	Knockfinglas & Glansillagh 220kV Substations - Site Layout Plan	1:500
15	229100682-MMD-04-XX-DR-E-0110	Knockfinglas 220Kv GIS Substation Plan Layouts & Section	1:200
16	229100682-MMD-04-XX-DR-E-0111	Knockfinglas 220kV GIS Substation Elevations	1:200
17	229100682-MMD-04-XX-DR-E-0120	Glansillagh 220kV GIS Substation Plan Layouts & Section	1:200
18	229100682-MMD-04-XX-DR-E-0121	Glansillagh 220kV GIS Substation Elevations	1:200
19	229100682-MMD-04-XX-DR-E-0122	Glansillagh 220kV Reactor Compound Plan & Elevation	1:100
20	229100682-MMD-XX-04-DR-E-0130	Knockfinglas & Glansillagh 220kV Substations Contiguous Elevations - Sheet 1 of 2	1:250

Shannon Technology and Energy Park (STEP) 220kV Grid Connection

No.	Drawing Reference	Drawing Name	Scale (at A1)
21	229100682-MMD-XX-04-DR-E-0131	Knockfinglas & Glansillagh 220kV Substations Contiguous Elevations - Sheet 2 of 2	1:250
HDD & LCIM Interface			
22	229100682-MMD-XX-04-DR-E-0210	New 220kV Cable Duct - Existing HV Cables HDD Crossing - Plan Layout	1:500
22	229100682-MMD-XX-04-DR-E-0220	New 220kV Cable Duct - Interface with Existing LCIM Mast - Plan Layout	1:200
Detail Sheets			
23	229100682-MMD-04-XX-DR-E-0300	220kV Cable Trench Detail Sheet 1	1:20
24	229100682-MMD-04-XX-DR-E-0301	220kV Cable Trench Detail Sheet 2	1:25/1:50
25	229100682-MMD-04-XX-DR-E-0302	Joint Bay Details	1:25
26	229100682-MMD-04-XX-DR-E-0303	Comms Chamber & Link Box Details	1:20
27	229100682-MMD-04-XX-DR-E-0304	Transition Bay Details	1:20
28	229100682-MMD-04-XX-DR-E-0305	Fence - Details	1:20
29	229100682-MMD-04-XX-DR-E-0306	Gate - Details	1:20
30	229100682-MMD-04-XX-DR-E-0307	Typical Off-Road Construction Swathe Details	1:50/1:100
Drainage & Water			
31	229100682-MMD-04-XX-DR-D-0100	Knockfinglas & Glansillagh 220kV Substations - Storm Water Drainage Layout	1:500
32	229100682-MMD-04-XX-DR-D-0101	Knockfinglas & Glansillagh 220kV Substations - Waste Water Drainage Layout	1:500
33	229100682-MMD-04-XX-DR-D-0110	Knockfinglas & Glansillagh 220kV Substations - Water Supply Layout	1:500
34	229100682-MMD-04-XX-DR-D-0120	Typical Drainage Details Sheet 1	1:20
35	229100682-MMD-04-XX-DR-D-0121	Typical Drainage Details Sheet 2	1:10
36	229100682-MMD-04-XX-DR-D-0122	Typical Drainage Details Sheet 3	1:50