



NOTES

1. ALL DIMENSIONS ARE IN MILLIMETERS UNLESS OTHERWISE STATED. DO NOT SCALE. WORK TO MEASURED DIMENSIONS ONLY. ALL DIMENSIONS & LEVELS ARE TO BE CHECKED BY THE CONTRACTOR. THE CONTRACTOR SHALL NOTE THAT THIS DRAWING IS INDICATIVE AND ILLUSTRATES DESIGN INTENT ONLY. THE CONTRACTOR SHALL BE RESPONSIBLE FOR DETAILED DESIGN AND COORDINATION WITH THE STRUCTURE.
2. ANY DISCREPANCIES, ERRORS OR OMISSIONS ARE TO BE CLARIFIED WITH THE RELEVANT ENGINEER AT THE EARLIEST OPPORTUNITY.
3. ALL WORKS ARE TO BE IN ACCORDANCE WITH THE CURRENT RELEVANT REGULATIONS BUILDING PRACTICE & TRADE ASSOCIATION REQUIREMENTS.
4. ALL ELECTRICAL INSTALLATIONS SHALL COMPLY WITH THE CURRENT I.S. 10101 (2020) WIRING REGULATIONS.
5. ALL M&E SERVICES DUCTING, METERS AND TIE IN POINTS TO BE CONFIRMED BY UTILITY SUPPLIERS.
6. FINAL SETTING OUT AND COORDINATION OF DUCTING TO BE CONFIRMED BY ARCHITECT AND CIVIL ENGINEERS.
7. ALL DUCTING TO BE COMPLIANCE WITH THE ESB/VIRGINEIR AND THE LOCAL COUNTY COUNCIL.
8. PLEASE REFER TO CMHD-EDC-00-00-DR-E-1001 FOR TYPICAL DUCTING DETAILS.
9. PUBLIC LIGHTING DUCTING TO BE INSTALLED USING TRENCHLESS TECHNOLOGY WITHIN TREE ROOT PROTECTION ZONES & SHALL BE LAID AT 800-900MM WITH THE USE OF THE MOLING TOOL AS REQUIRED. FOR ALL ROOT PROTECTION ZONES OF TREES TO BE RETAINED-REFER TO ARBORISTS FINAL DRAWING.
10. COURTYARD LAYOUTS TBC. COURTYARD LIGHTING LAYOUTS DEPENDANT ON FINAL COURTYARD ARRANGEMENT.

LEGEND

DUCTING	
TYPICALLY DENOTES: 2 x 160mm ESB MV DUCTING, 2 x 125mm ESB LV DUCTING, 2 x 110mm EIR DUCTING, 2 x 110mm VIRGIN DUCTING, 2 x 150mm EV LV DUCTING, 1 x 110mm EV ELV DUCTING & 1 x 107mm PUBLIC LIGHTING DUCTING	
TYPICALLY DENOTES: NATURAL GAS PIPEWORK	
LTHW PIPEWORK FROM HEATING PLANTROOM	

Rev	Date	Description	Orig	App
P09	19/09/2024	ISSUED FOR PLANNING	MOC	ROF
P08	13/09/2024	ISSUED FOR PLANNING	MOC	ROF
P07	06/09/2024	ISSUED FOR PLANNING	MOC	ROF
P06	02/08/2024	ISSUED FOR PLANNING	MOC	ROF
P05	12/07/2024	ISSUED FOR PLANNING	MOC	ROF
P04	11/07/2024	ISSUED FOR PLANNING	MOC	ROF
P03	23/05/2024	ISSUED FOR PLANNING	MOC	ROF
P02	17/04/2024	ISSUED FOR PLANNING	MOC	ROF
P01	24/01/2021	ISSUED FOR PLANNING	AD	ROF

Applicant: **DÚN LAOGHAIRE RATHDOWN COUNTY COUNCIL, IN PARTNERSHIP WITH THE LAND DEVELOPMENT AGENCY**

Name of Job: **PROPOSED PART 10 RESIDENTIAL DEVELOPMENT DUNDRUM CENTRAL DEVELOPMENT DUNDRUM ROAD DUBLIN 14**

Title of Drawing: **SITE SERVICES LAYOUT**

Drawing No: **CMHD-EDC-00-00-DR-E-1000**

Scale	Model Manager	Project Manager	Status	Revision
A0	AD	ROF	S2	P09

Mechanical & Electrical Consulting Engineers

EDC

Cork Office: Tel: +353 (0)21 4280470, email: info@edcengineers.com
 Dublin Office: Tel: +353 (0)1 5313663, email: info@edcengineers.com
 London Office: Tel: +44 (0)203 0040062, email: info@edcengineers.com
 www.edcengineers.com

