

RECEIVED: 29/08/2024



APPENDIX 12-3

**BESS OPERATIONAL NOISE
REPORT**



A specialist energy consultancy

RECEIVED: 29/08/2024

Appendix 12-3

Battery Energy Storage System (BESS) Noise Report

Lackareagh Wind Farm, Co. Clare

EDF Renewables Ireland

IE00101-009-R0
02 August 2024



tneigroup.com

.....

Quality Assurance

TNEI Services Ltd, TNEI Africa (PTY) Ltd and TNEI Ireland Ltd operate an Integrated Management System and is registered with The British Assessment Bureau as being compliant with ISO 9001 (Quality), ISO 14001 (Environmental) and ISO 45001 (Health and Safety).

Disclaimer

This document is issued for the sole use of the Customer as detailed on the front page of this document to whom the document is addressed and who entered into a written agreement with TNEI. All other use of this document is strictly prohibited and no other person or entity is permitted to use this report unless it has otherwise been agreed in writing by TNEI. This document must be read in its entirety and statements made within may be based on assumptions or the best information available at the time of producing the document and these may be subject to material change with either actual amounts differing substantially from those used in this document or other assumptions changing significantly. TNEI hereby expressly disclaims any and all liability for the consequences of any

such changes. TNEI also accept no liability or responsibility for the consequences of this document being relied upon or being used for anything other than the specific purpose for which it is intended, or containing any error or omission which is due to an error or omission in data used in the document that has been provided by a third party.

This document is protected by copyright and may only be reproduced and circulated in accordance with the Document Classification and associated conditions stipulated or referred to in this document and/or in TNEI's written agreement with the Customer. No part of this document may be disclosed in any public offering memorandum, prospectus or stock exchange listing, circular or announcement without the express and prior written consent of TNEI. A Document Classification permitting the Customer to redistribute this document shall not thereby imply that TNEI has any liability to any recipient other than the Customer.

Any information provided by third parties that is included in this report has not been independently verified by TNEI and as such TNEI accept no responsibility for its accuracy and completeness. The Customer should take appropriate steps to verify this information before placing any reliance on it.

Document Control

RECEIVED: 29/08/2024

| Revision | Status | Prepared by | Checked by | Approved by | Date |
|----------|-------------|-------------|------------|-------------|------------|
| D0 | DRAFT | AD | JS | JS | 05/06/2024 |
| R0 | FIRST ISSUE | AD | JS | JS | 02/08/2024 |
| | | | | | |
| | | | | | |

TNEI Services Ltd

Company Registration Number: 03891836

VAT Registration Number: 239 0146 20

Registered Address

Bainbridge House
86-90 London Road
Manchester
M1 2PW
Tel: +44 (0)161 233 4800

7th Floor West One
Forth Banks
Newcastle upon Tyne
NE1 3PA
Tel: +44 (0)191 211 1400

7th Floor
80 St. Vincent Street
Glasgow
G2 5UB
Tel: +44 (0)141 428 3180

TNEI Ireland Ltd

Registered: 104 Lower Baggot Street, Dublin 2, DO2 Y940

Company Registration Number: 662195

VAT Registration Number: 3662952IH

Unit S12, Synergy Centre
TU Dublin Tallaght Campus
Tallaght
D24 A386
Tel: +353 (0)190 36445

TNEI Africa (Pty) Ltd

Registered: Mazars House, Rialto Rd, Grand Moorings Precinct, 7441 Century City, South Africa

Company Number: 2016/088929/07

Unit 514 Tyger Lake
Niagara Rd & Tyger Falls Blvd
Bellville, Cape Town
South Africa, 7530

TNEI Inc.

Registered Address: 9319 Robert D/ Snyder Rd. PORTAL Building Mecklenburg County
Charlotte, NC 228223-0001 USA

Certification Number: C202305805696-1

Unit 216 PORTAL Building,
9319 Robert D. Snyder Road
Charlotte, Mecklenburg County,
North Carolina 28223
Tel: +1 (980) 245-4024

Contents

RECEIVED: 29/08/2024

| | |
|--|----|
| Document Control | 3 |
| Contents | 4 |
| 1 Introduction..... | 6 |
| 1.1 Nomenclature | 6 |
| 2 Proposed Project Description | 7 |
| 2.1 Description of the Proposed BESS Compound..... | 7 |
| 2.2 Study Area | 7 |
| 3 Assessment Methodology..... | 8 |
| 3.1 Legislation and Policy Context | 8 |
| 3.2 Assessment Methods..... | 8 |
| 3.2.1 'Context' Based Limits (BS 4142:2014 +A1:2019) | 8 |
| 3.2.2 Fixed Guideline Levels (BS 8233:2014) | 9 |
| 3.3 Calculation Method | 10 |
| 3.3.1 Noise Propagation Model (ISO 9613-2:1996) | 10 |
| 3.3.2 Uncertainties and Limitations | 10 |
| 4 Baseline Sound Level Monitoring | 11 |
| 5 Operational Noise Impacts..... | 14 |
| 5.1 Modelling of Individual Sound Sources..... | 14 |
| 5.1.1 Fluence Cube and MV Transformer | 14 |
| 5.1.2 High Voltage (HV) Grid Transformer..... | 14 |
| 5.2 Calculated Immission Levels | 15 |
| Noise Impact Assessment..... | 16 |
| 5.3 Quantitative Assessment..... | 16 |
| 5.4 Qualitative Assessment | 16 |
| 5.4.1 Tonality..... | 17 |
| 5.4.2 Impulsivity | 17 |
| 5.4.3 Intermittency | 17 |
| 5.4.4 Other Sound Characteristics | 17 |
| 5.4.5 Calculation of the Rating Level..... | 18 |
| 5.4.6 Assessment of the Impacts | 18 |
| 6 Summary | 21 |
| 7 References..... | 22 |



RECEIVED: 29/08/2024

TABLES

Table 3.1: Indoor Ambient Noise Levels for Dwellings (*BS 8233:2014 Table 4*) 9

Table 4.1: Baseline Noise Monitoring Locations 11

Table 4.2: Measured baseline sound levels 12

Table 4.3: Representative Background Sound level, dB $L_{A90(10mins)}$ 13

Table 5.1: 1/3 Octave Band SWL, dBA used to model the HV Grid Transformer 14

Table 5.2: BESS Noise Assessment Locations (BNALs) 15

Table 5.3: Predicted Immission Levels, dB $L_{Aeq(t)}$ 15

Table 5.4: Derived BS 8233 Fixed Level Limits 16

Table 5.5: Quantitative Assessment 16

Table 5.6: Margin Above / Below (+/-) Background Sound Level, dB 19

APPENDICES

- Annex 1 – Glossary of Terms
- Annex 2– Development Information
- Annex 3 - Baseline Survey Data
- Annex 4 – Noise Modelling Data
- Annex 5 – Figures
- Annex 6 – Quantitative assessments at all NSRs



1 Introduction

TNEI Ireland Ltd was commissioned by MKO on behalf of EDF Renewables Ireland Ltd to undertake a Noise Impact Assessment (NIA) for the operation of a Battery Energy Storage System (BESS), which forms part of the Proposed Lackareagh Wind Farm (hereinafter referred to as 'the Proposed Project'). The project referencing as laid out in Section 1.1.1 of Chapter 1 will be followed throughout this report also, i.e. 'the Proposed Wind Farm', 'The Proposed Grid Connection Route', 'the site'.

The method of assessment of operational noise for a BESS is very different from that used for the assessment of operational wind turbine noise and the two assessment types cannot be combined. Accordingly, the assessment of operational noise attributable to the BESS is presented separately in this report, and the operational wind farm noise assessment is provided in Technical Appendix 12-2.

The BESS is proposed to be located within an area approximately 1 km east of Kilbane, at approximate ITM grid coordinates 563627, 672541. The land surrounding the proposed BESS is rural in nature, predominantly consisting of commercially forested areas. A small number of residential properties are located within the area, the nearest of which is approximately 825 m to the west.

The aims of this BESS NIA were to:

- Identify the nearest noise sensitive receptors in the vicinity of the proposed BESS;
- Identify the primary sound sources associated with the operation of the BESS;
- Calculate the likely levels of operational noise at the identified receptors to determine the noise impacts; and
- Indicate any requirements for mitigation measures, if required, to provide sufficient levels of protection for all noise sensitive receptors.

1.1 Nomenclature

Please note the following terms and definitions, which are used throughout this report:

- **Emission** refers to the noise level emitted from a noise source, expressed as either a sound power level or a sound pressure level;
- **Immission** refers to the sound pressure level received at a specific location from a noise source;
- **SWL** indicates the sound power level in decibels (dB);
- **SPL** indicates the sound pressure level in decibels (dB);
- **NML** (Noise Monitoring Location) refers to any location where baseline noise levels have been measured;
- **NSRs** (Noise Sensitive Receptors) are all identified receptors which are sensitive to noise; and
- **BNAL** (BESS Noise Assessment Location) refers to any location where the noise immission levels from the BESS are calculated and assessed.

A Glossary of Terms is also provided as Annex 1 of this report.

All figures referenced within the report can be found in Annex 5.

Unless otherwise stated, all sound levels refer to free field levels i.e. sound levels without influence from any nearby reflective surfaces.

All grid coordinates refer to the Irish Transverse Mercator (ITM) coordinate system using ITM X and ITM Y, unless stated otherwise.

2 Proposed Project Description

2.1 Description of the Proposed BESS Compound

The proposed BESS compound would introduce new sound sources to the local area in the form of externally located fixed plant. The BESS is expected to consist of 48 liquid cooled battery cubes, which would be connected into a series of Power Conversion Systems (PCS), each consisting of a pair of inverters and a medium voltage (MV) transformer. It is also assumed that a single High Voltage (HV) Grid Transformer will be located within an adjacent substation. Some auxiliary plant, such as switch gear, will also be installed but would be insignificant in noise output in comparison to the BESS plant and HV transformer.

Specifically, the dominant sound sources considered within this assessment are assumed as follows:

- Fluence Cubes (48 of);
- PE HEMK PCSK Inverter (6 of);
- Chint Electric MV Transformer (3 of); and,
- HV Grid Transformer (1 of).

The assumed plant is indicative only and has been selected as the sound power levels are comparable to other plant available for a BESS of this scale. A layout plan providing an overview of the proposed BESS development in Annex 2. The layout plan may be subject to minor changes but not of sufficient scale to alter the conclusions of the assessment.

2.2 Study Area

All of the Noise Sensitive Receptors (NSRs) considered in this assessment are residential properties. The study area has been defined through the identification of the closest NSRs within 3 km of the site. The closest NSR to the BESS is located approximately 825 m to the west. To the east the closest NSR is approximately 1000 m. There are receptors at similar or greater distances. Figure A5.1 in Annex 5 details the location of the proposed BESS in context of the closest NSRs considered within the assessment. Figures A5.1a-d detail the location of the proposed BESS in the context of all the NSRs considered within the assessment.

3 Assessment Methodology

3.1 Legislation and Policy Context

There is no specific Irish guidance that contains a detailed method for the assessment of environmental noise, however, to address this gap and try to bring consistency across Local Authorities, the Association of Acoustic Consultants of Ireland have published 'Environmental Noise Guidelines (ENG) for Local Authority Enforcement and Planning Sections', which states (in relation to Industrial developments); "Useful guidance is additionally presented in British Standard BS 4142:2014 Methods for rating and assessing industrial and commercial sound (2014), which provides an assessment methodology based on existing background levels."

The ENG also refers to BS 8233, stating;

"Although not an environmental noise standard, BS 8233:2014 Guidance on sound insulation and noise reduction for buildings (2014) is occasionally referenced in noise impact assessments due to its inclusion of recommendations for internal noise levels. The standard is not directly applicable to the assessment of impacts from external sources on building occupants. However, the standard lists internal noise criteria to facilitate use and enjoyment of certain building types, and these criteria are useful in providing a reference".

3.2 Assessment Methods

Typically, assessments of environmental noise are based on a comparison of likely noise levels against either 'context' based limits or a set of fixed limits.

Context based limits are set relative to the existing noise environment and may also consider the characteristics of the noise source(s), whilst fixed limits are usually set regardless of the existing noise environment or type of noise source(s).

3.2.1 'Context' Based Limits (BS 4142:2014 +A1:2019)

BS 4142:2014+A1:2019 is commonly used to assess the potential impacts of new industrial sound sources on nearby receptors.

The BS 4142 form of assessment is based on the predicted or measured levels of an assessed sound source compared to the measured background sound levels without the specific sound source present and uses, "outdoor sound levels to assess the likely effects of sound on people who might be inside or outside a dwelling or premises used for residential purposes upon which sound is incident".

BS4142 uses the following definitions;

- **Ambient Sound:** Totally encompassing sound in a given situation at a given time, usually composed of sound from many sources, both near and far. Described using the metric, $L_{Aeq(t)}$.
- **Specific Sound Level:** Equivalent continuous A-weighted sound pressure level produced by the specific sound source at the assessment location over a given reference time interval, T_r . Described using the metric $L_{Aeq(t)}$. Also referred to in this Appendix as the *Immission Level*.
- **Residual Sound Level:** Equivalent continuous A-weighted sound pressure level of the residual sound without the specific sound source(s) present at the assessment location over a given time interval, T . Described using the metric $L_{Aeq(t)}$.
- **Background Sound Level:** A-weighted sound pressure level that is exceeded by the residual sound at the assessment location for 90% of a given time interval, T , measured using time

weighting F and quoted to the nearest whole number of decibels. Described using the metric $L_{A90}(t)$.

- Rating Level:** The Specific Sound Level adjusted for the characteristics of the sound. The Rating Level is calculated by adding a penalty or penalties (if required) to the Specific Sound Level when the sound source contains audible characteristics such as tonal, impulsive or intermittent components. Described using the metric, $L_{Aeq}(t)$.

BS 4142 is a qualitative assessment, not a quantitative assessment i.e. it does not simply provide a pass or fail result by comparing a predicted noise level to a noise limit. Rather, it considers predicted levels in context with the wider setting to estimate whether adverse impacts may occur.

The starting point of the BS 4142 assessment is to compare the Rating Level with the background sound level, however, where background sound levels are very low and where Rating Levels are low, the standard suggests that it may be more appropriate to consider the absolute levels, rather than comparing directly to the background. The Associate of Noise Consultants (ANC) provide additional information on this in the BS 4142 Technical Guide

“BS 4142 does not indicate how the initial estimate of impact should be adjusted when background and rating levels are low, only that the absolute levels may be more important than the difference between the two values. It is likely that where the background and rating levels are low, the absolute levels might suggest a more acceptable outcome than would otherwise be suggested by the difference between the values. For example, a situation might be considered acceptable where a rating level of 30 dB is 10 dB above a background sound level of 20 dB, i.e., an initial estimate of a significant adverse impact is modified by the low rating and background sound levels.

There may be situations where the opposite is true, and it is for the assessor to justify any modifications to the initial estimate of impact. BS 4142 does not define ‘low’ in the context of background sound levels nor rating levels. The note to the Scope of the 1997 version of BS 4142 defined very low background sound levels as being less than about 30 dB L_{A90} , and low rating levels as being less than about 35 dB $L_{Ar,Tr}$. The WG [Working Group] suggest that similar values would not be unreasonable in the context of BS 4142, but that the assessor should make a judgement and justify it where appropriate.”

3.2.2 Fixed Guideline Levels (BS 8233:2014)

BS 8233 ‘Guidance on sound insulation and noise reduction for buildings’ presents guideline noise levels for daytime and night-time for the design of a number of different building types. For residential developments, these are based on guidelines issued by the World Health Organisation (WHO).

The Standard states; *“In general, for steady external noise sources, it is desirable that the internal ambient noise level does not exceed the guideline values in Table 4.”* Table 4 is reproduced here as Table 3.1.

Table 3.1: Indoor Ambient Noise Levels for Dwellings (BS 8233:2014 Table 4)

| Activity | Location | 07:00 to 23:00 | 23:00 to 07:00 |
|----------------------------|------------------|-------------------------|------------------------|
| Resting | Living room | 35 dB $L_{Aeq(16hour)}$ | - |
| Dining | Dining room/area | 40 dB $L_{Aeq(16hour)}$ | - |
| Sleeping (daytime resting) | Bedroom | 35 dB $L_{Aeq(16hour)}$ | 30 dB $L_{Aeq(8hour)}$ |

The *Acoustics, Ventilation and Overheating Guide (AVO)* (January 2020), jointly published by the UK's ANC and the Institute of Acoustics (1), suggests that a value of 13 dB (3) is an appropriate to convert between internal and external sound levels for a partially open window. Therefore, an assessment of external noise levels can assume an external noise level limit of 13 dB above those values detailed within Table 3.1 (i.e. to achieve an internal night-time level of 30 dB $L_{Aeq(8hour)}$ with windows open, the external sound level must not exceed 43 dB $L_{Aeq(8hour)}$).

3.3 Calculation Method

3.3.1 Noise Propagation Model (ISO 9613-2:1996)

To predict the noise immission levels attributable to the proposed BESS a noise propagation model was created using the propriety noise modelling software CadnaA. Within the software, complex models can be produced to simulate the propagation of noise according to a wide range of international calculation standards.

For this assessment, noise propagation was calculated in accordance with ISO 9613 '*Acoustics – Attenuation of Sound During Propagation Outdoors*' (2) using the following input parameters:

- Temperature was assumed to be 10 °C and relative humidity as 70%;
- A ground attenuation factor of 0.5 (mixed ground) has been used; and
- Receiver heights were set to 4 m, to replicate the height of a first floor (bedroom) window. At lower heights, noise levels would also typically be lower.

3.3.2 Uncertainties and Limitations

Modelled sound sources represent candidate plant only and an indicative site layout. The noise output of individual items of plant may vary from what is presented in this report after final plant specification and procurement.

The noise propagation model is designed to give a good approximation of the specific sound level and the contribution of each individual sound source; however, it is expected that measured levels are unlikely to be matched exactly with modelled values and the following limitations in the model should be considered:

- In accordance with ISO 9613, all assessment locations are modelled as downwind of all sound sources and propagation calculations are based on a moderate ground-based temperature inversion, such as commonly occurs at night. These conditions are favourable to noise propagation;
- The predicted barrier attenuation provided by local topography, embankments, walls, buildings and other structures in the intervening ground between source and receiver can only be approximated and not all barrier attenuation will have been accounted for; and,
- The model assumes all sound sources are operating continuously, simultaneously and at maximum noise output.
- All of these elements will favour noise propagation and predicted levels will tend to be higher than the noise levels that will actually occur.

4 Baseline Sound Level Monitoring

TNEI undertook an operational wind turbine noise assessment for the Proposed Wind Farm. As part of the study, TNEI undertook continuous background sound level monitoring for the period between 4th April 2023 and 21st of June 2023 at seven neighbouring properties. The dataset collected during the period 19th of May – 21st of June has been used for the purpose of this assessment.

Table 4.1 details all seven Noise Monitoring Locations (NMLs), which are being used in this assessment. The NMLs are also shown in Figure A5.1 included within Annex 5.

Table 4.1: Baseline Noise Monitoring Locations

| NML | Approximate Distance and bearing to BESS plant (m) | Coordinates (ITM X, Y) | |
|-------|--|------------------------|--------|
| NML01 | 2,066 m WNW | 561633 | 673082 |
| NML02 | 883 m WNW | 562790 | 672823 |
| NML03 | 1,329 m SW | 562528 | 671793 |
| NML04 | 1,927 m ESE | 565465 | 671963 |
| NML05 | 1,130 m E | 564756 | 672486 |
| NML06 | 1,299 m NE | 564796 | 673108 |
| NML07 | 1,579 m NNE | 564713 | 673687 |

The noise monitoring equipment consisted of Rion NL-31's, Rion NL-32's and a Rion NL-52 Sound Level Meter (SLM), fitted with appropriate environmental wind shields. All noise monitoring equipment (calibrator, SLM and microphones) used for the study are categorised as Class 1, as specified in IEC 61672-1 'Electroacoustics. Sound level meters. Specifications' (3). The equipment was calibrated onsite at the beginning and end of each measurement period with no significant deviations noted.

Wind speed and direction data was measured continuously during the noise survey using a LIDAR unit, which was temporarily installed within the Proposed Wind Farm site for the purposes of background noise collection. For wind farm operational noise assessments, the measured noise data is organised into wind speed 'bins' to determine wind-speed specific noise limits. In contrast, BS 4142 states, "Exercise caution when making measurements in poor weather conditions, such as wind speeds greater than 5 m/s." Accordingly, the noise data was filtered to remove any data points that were measured during periods of high wind speeds and rain. In this particular case, all noise data measured with wind speeds at or above 5 ms⁻¹ has been removed. Time series charts are provided in Annex 3 for each of the NMLs, which present the measured 10-minute LAeq and LA90, the wind speed (m/s) and any periods where data has been removed, including for precipitation events.

RECEIVED: 19/08/2024

It should be noted that the wind speed data used in this assessment is based on measurements made at wind speeds at 10 m height (standardised). BS4142 suggest that wind speed measurements should be undertaken at the NMLs, at comparable measurement heights to the Sound Level Meters. Therefore, the approach undertaken here in using wind speed measurements captured by a LiDAR unit on the site, measuring at the turbine hub height and then standardising to 10 m, is a more cautious approach. This is due to the resulting higher wind speeds than if measurements were undertaken at each NML at a height of 1.5 m.

Table 4.2 presents an overview of the measured baseline sound levels.

Table 4.2: Measured baseline sound levels

| NML | Average LAeq _(10mins) | | Mean LA90 _(10mins) | | Mode LA90 _(10mins) | | Range LA90 _(10mins) | |
|-------|----------------------------------|-------|-------------------------------|-------|-------------------------------|-------|--------------------------------|-------|
| | Day | Night | Day | Night | Day | Night | Day | Night |
| NML01 | 41 | 35 | 35 | 32 | 36 | 32 | 30 | 18 |
| NML02 | 44 | 32 | 33 | 26 | 35 | 23 | 32 | 23 |
| NML03 | 41 | 32 | 34 | 29 | 35 | 29 | 44 | 20 |
| NML04 | 42 | 30 | 33 | 26 | 36 | 22 | 26 | 23 |
| NML05 | 43 | 30 | 32 | 26 | 35 | 26 | 29 | 22 |
| NML06 | 45 | 32 | 34 | 27 | 34 | 25 | 36 | 21 |
| NML07 | 41 | 30 | 31 | 26 | 34 | 23 | 42 | 25 |

Subjective observations during site visits (for installation and collection of equipment and period calibrations), noted the following;

- At NML01 watercourses were audible both to the east and the west of the house, therefore the kit was sited such that the separation distance from the two watercourses was maximised. In addition, birdsong and wind induced noise from the vegetation were audible.
- At NML02 birdsong, wind induced noise from the vegetation and dogs barking were the main noise sources observed during installation and collection.
- At NML03 cattle lowing, wind induced noise from the vegetation, birdsong and machinery operating within a cattle yard approximately 100 m from the monitoring location were the main noise sources observed.
- At NML04 wind induced noise from the surrounding vegetation and birdsong were the main noise sources observed.
- At NML05 birdsong, wind induced noise from the vegetation and trees and cars passing were the main noise sources observed. In addition, a watercourse to was faintly audible to the south of the property.
- At NML06 birdsong and wind induced noise from the vegetation were the main noise sources observed. Distant road noise was also audible.
- At NML07 birdsong and wind induced noise from the vegetation were the main noise sources observed. Distant road noise was also audible.

Table 4.3 details the representative background sound levels, $L_{A90(10mins)}$, which have been determined after considering the distribution of data for each measurement period. Typically, baseline sound level measurements made in accordance with BS 4142 are undertaken in 15-minute periods. However, as the baseline data was measured as part of the operational wind turbine noise assessment, a 10-minute measurement period was adopted for use as part of this assessment. Annex 3 contains the statistical and distribution analysis charts used to ascertain the representative background sound levels.

Table 4.3: Representative Background Sound level, dB $L_{A90(10mins)}$

| NML ID | Daytime $L_{A90(10mins)}$ | Night-time $L_{A90(10mins)}$ |
|--------|---------------------------|------------------------------|
| NML01 | 33 | 29 |
| NML02 | 32 | 25 |
| NML03 | 33 | 28 |
| NML04 | 33 | 22 |
| NML05 | 31 | 24 |
| NML06 | 33 | 25 |
| NML07 | 30 | 23 |

The daytime representative background sound level at all NMLs is 30dB $L_{A90(10mins)}$ or higher. During the night-time, however, the background sound level is below 30 dB $L_{A90(10mins)}$ at all NMLs, which can be classified as 'very low' (see Section 3.2.1).

5 Operational Noise Impacts

RECEIVED: 23/08/2024

5.1 Modelling of Individual Sound Sources

The noise model considers all the sound sources detailed within Section 2.1 and the following paragraphs describe how each sound source has been incorporated into the noise model.

5.1.1 Fluence Cube and MV Transformer

TNEI have used noise data for a Fluence Cube, offered by the supplier, Fluence.

Each Fluence Cube includes a number of internally and externally located sound sources, most notably the HVAC and chiller units, which are housed within the Cube. Each Fluence Cube has been modelled as a box with the outer façade being modelled as an area source.

Chint Electric MV Transformers and Power Electronics (PE) E HEMK PCSK Inverters were also assumed. The MV transformers and accompanying Inverters have been modelled as boxes consisting of five area sources (four facades and the roof). Each area source has been modelled with 7 dB of attenuation such that the logarithmic sum of the five area sources per piece of plant equates to the overall sound power of their respective plant.

The noise data for the Cubes, MV Transformers and Inverters has been provided to TNEI under a Non-Disclosure Agreement and as such detailed noise level data cannot be provided in this report. TNEI would be happy to discuss this data in more detail with the Local Authority, if required.

5.1.2 High Voltage (HV) Grid Transformer

The modelled HV transformer has been assumed to be an ABB HV transformer with a broadband sound power level (SWL) value of 88 dBA. The transformer has been modelled as a box consisting of five area sources (four facades and the roof). Each area source has been modelled with 7 dB of attenuation such that the logarithmic sum of the five sources equates to the overall sound power level of 88 dBA. Table 5.1 details the resulting SWL used within the noise model and the relevant data sheets are included within Annex 4.

Table 5.1: 1/3 Octave Band SWL, dBA used to model the HV Grid Transformer

| | Frequency (Hz) | | | | | | | |
|-----|----------------|------|------|------|------|------|------|-------|
| Hz | 50 | 63 | 80 | 100 | 125 | 160 | 200 | 250 |
| dBA | 63.8 | 47.8 | 55.1 | 72.1 | 68.6 | 78.4 | 74.1 | 76.5 |
| Hz | 315 | 400 | 500 | 630 | 800 | 1000 | 1250 | 1600 |
| dBA | 80.1 | 77.1 | 77.1 | 79.3 | 78.6 | 76.7 | 74.5 | 72.4 |
| Hz | 2000 | 2500 | 3150 | 4000 | 5000 | 6300 | 8000 | 10000 |
| dBA | 70.2 | 68.5 | 67.6 | 67.0 | 64.9 | 61.9 | 59.8 | 58.2 |

5.2 Calculated Immission Levels

Noise immission levels have been calculated at seven BESS Noise Assessment Locations (BNALs), which have been selected to represent the closest NSRs. The BNALs have been set on the side of the property facing the proposed BESS compound, representing the closest point of the property's amenity area.

The BNALs are detailed in Table 5.2 and shown on Figure A5.1 and Figures A5.1a-d within Annex 5.

Table 5.2: BESS Noise Assessment Locations (BNALs)

| BNAL ID | ITM X | ITM Y |
|----------------|--------|--------|
| BNAL01 (NSR10) | 564702 | 673649 |
| BNAL02 (NSR2) | 564689 | 673091 |
| BNAL03 (NSR7) | 564759 | 672513 |
| BNAL04 (NSR65) | 565439 | 671960 |
| BNAL05 (NSR34) | 562540 | 671813 |
| BNAL06 (NSR8) | 562288 | 672235 |
| BNAL07 (NSR11) | 561663 | 673086 |

The immission levels (Specific Sound Level) are calculated assuming all plant is operating continuously and concurrently. The levels are detailed in Table 5.3 as dB $L_{Aeq(t)}$. No time period is specified as the model assumes that noise levels will not fluctuate and will remain the same for all time periods.

Table 5.3: Predicted Immission Levels, dB $L_{Aeq(t)}$

| Noise Assessment Location, BNAL ID | Immission Level, dB $L_{Aeq(t)}$ |
|------------------------------------|----------------------------------|
| BNAL01 (NSR10) | 10 |
| BNAL02 (NSR2) | 19 |
| BNAL03 (NSR7) | 15 |
| BNAL04 (NSR65) | 13 |
| BNAL05 (NSR34) | 23 |
| BNAL06 (NSR8) | 28 |
| BNAL07 (NSR46) | 22 |

The levels presented in Table 5.3 represent the noise immission levels at the closest NSRs only. For completeness, predictions at all identified NSRs are provided in Annex 6.

RECEIVED 29/05/2024

Noise Impact Assessment

RECEIVED: 29/08/2024

5.3 Quantitative Assessment

An assessment is detailed below in **Table 5.4** against the most stringent of the guideline levels presented in BS 8233:2014 (as detailed in Table 3.1).

Table 5.4: Derived BS 8233 Fixed Level Limits

| Assessment Parameter | BS 8233 Guideline Level | Allowance for Open Window Attenuation | Equivalent External Level |
|------------------------|-------------------------|---------------------------------------|----------------------------------|
| Daytime 07:00-23:00 | 35 | 13 | 48 dB L _{Aeq} (16-hour) |
| Night-time 23:00-07:00 | 30 | 13 | 43 dB L _{Aeq} (8-hour) |

Table 5. below compares the predicted immission levels with the derived noise limits.

Table 5.5: Quantitative Assessment

| Noise Assessment Location | Daytime | | Night-time | |
|---------------------------|---|--|---|--|
| | Immission Level, dB L _{Aeq(t)} | Margin above/below Noise Level Limit, dB | Immission Level, dB L _{Aeq(t)} | Margin above/below Noise Level Limit, dB |
| BNAL01 (NSR10) | 10 | -38 | 10 | -33 |
| BNAL02 (NSR2) | 19 | -29 | 19 | -24 |
| BNAL03 (NSR7) | 15 | -33 | 15 | -28 |
| BNAL04 (NSR65) | 13 | -35 | 13 | -30 |
| BNAL05 (NSR34) | 23 | -25 | 23 | -20 |
| BNAL06 (NSR8) | 28 | -20 | 28 | -15 |
| BNAL07 (NSR46) | 22 | -26 | 22 | -21 |

The predictions are at least 15 dB below the night-time guideline levels and 20 dB below the daytime guideline levels of BS 8233.

5.4 Qualitative Assessment

The qualitative assessment, which is undertaken following the guidance presented in BS 4142, considers the predicted immission levels, the character of the sound, the existing sound environment and the context of the development.

In order to assess the immission levels in accordance with BS 4142, the Specific Sound Level must be converted into a Rating Level. The Rating Level allows for character corrections to be added to account

for particular characteristics of the sound that may be perceived as more annoying. In particular the Rating Level considers tonality, impulsivity and intermittency of the sound, as well other sound characteristics that are neither tonal, impulsive, or intermittent, but are otherwise readily distinctive against the residual acoustic environment.

5.4.1 Tonality

With regards to tonality, BS4142 states:

“For sound ranging from not tonal to prominently tonal the Joint Nordic Method gives a correction of between 0 dB and +6 dB for tonality. Subjectively, this can be converted to a penalty of 2 dB for a tone which is just perceptible at the noise receptor, 4 dB where it is clearly perceptible and 6 dB where it is highly perceptible.”

Some electrical plant such as power transformers are inherently tonal at source, typically in the 100 Hz frequency band, however, the BS 4142 corrections are only applied if noise characteristics are present at the receptor location. Consideration of the one third octave predicted levels does not suggest that tonality from any plant will be noticeable. For example, predicted noise immissions at BNAL06 in the 100 Hz third octave band are 7.2 dB, well below the night-time background sound level of 25 dB. As such, no tonal character correction has been applied.

5.4.2 Impulsivity

With regards to impulsivity, BS 4142 states:

“A correction of up to +9dB can be applied for sound that is highly impulsive, considering both the rapidity of the change in sound level and the overall change in sound level. Subjectively this can be converted to a penalty of 3dB for impulsivity which is just perceptible at the noise receptor, 6dB where it is clearly perceptible, and 9dB where it is highly perceptible.”

Impulsivity is not considered to be a relevant sound characteristic of a BESS and substation as when operational, the noise level will be predictable and consistent.

5.4.3 Intermittency

The intermittency of the sound source needs to be considered when it has identifiable on/off conditions with regards to intermittency, BS4142 states:

“If the intermittency is readily distinctive against the residual acoustic environment, a penalty of 3 dB can be applied.”

As with impulsivity, intermittency is not considered to be a relevant sound characteristic in this case. Once operational, noise levels may fluctuate by a small amount over long periods of time, but no regular step changes in noise level are anticipated.

5.4.4 Other Sound Characteristics

With regards to other sound characteristics, BS4142 states:

“Where the specific sound features characteristics that are neither tonal nor impulsive, nor intermittent, though otherwise are readily distinctive against the residual acoustic environment, a penalty of 3 dB can be applied.”

Based on TNEI’s understanding and experience of this type of plant, it is not anticipated that any additional sound characteristics that would be considered readily distinctive against the residual acoustic environment.

5.4.5 Calculation of the Rating Level

With due regard to the above, no character corrections are required. Therefore, the BS4142 Rating Levels are equal to the Specific Sound Levels. At all NALs the Rating Level is less than 35 dB LAeq(t), which can be classed as 'low' (see Section 3.2.1.).

5.4.6 Assessment of the Impacts

BS4142, Section 11, requires that the assessment considers the context in which the sound occurs, and as such there is no definitive pass/fail element to the standard. However, as a starting point the standard states:

"Obtain an initial estimate of the impact of the specific sound by subtracting the measured background sound level from the rating level, and consider the following..."

- a) Typically, the greater this difference, the greater the magnitude of the impact.*
- b) A difference of around +10 dB or more is likely to be an indication of a significant adverse impact, depending on the context.*
- c) A difference of around +5 dB is likely to be an indication of an adverse impact, depending on the context.*
- d) The lower the rating level is relative to the measured background sound level, the less likely it is that the specific sound source will have an adverse impact or a significant adverse impact. Where the rating level does not exceed the background sound level, this is an indication of the specific sound source having a low impact, depending on the context."*

To determine a Magnitude of Impact, the following criteria has been adopted;

- Where BS 4142 indicates a significant adverse impact, this is a Major Magnitude of Impact;
- Where BS 4142 indicates adverse impact, this is a Moderate Magnitude of Impact;
- Where BS 4142 indicates no adverse impact, this is a Minor Magnitude of Impact;
- Where the BS 4142 Rating Level is less than the measured background sound levels, this is a Negligible Magnitude of Impact.

With due regard to the sensitivity of the assessed residential receptors being high, the following criteria has been adopted to determine the significance criteria;

- Where a Major Magnitude of Impact is predicted, this is a Major Significant Effect;
- Where a Moderate Magnitude of Impact is predicted, this is a Moderate Significant Effect;
- Where a Minor Magnitude of Impact is predicted, this is a Minor Significant Effect;
- Where a Negligible Magnitude of Impact is predicted, this is a Negligible Significant Effect.

Table 5. presents a comparison of the Rating Levels to the daytime and night-time background sound levels. Annex 6 present a comparison of the Rating Levels to the daytime and night-time background sound levels at all assessed NSRs.

Table 5.6: Margin Above / Below (+/-) Background Sound Level, dB

| Noise Assessment Location | Daytime | | | Night-time | | |
|---------------------------|---------|-------------------|--|------------|-------------------|--|
| | BNAL ID | Rating Level, dBA | Representative Background Sound Level, dBA | Margin, dB | Rating Level, dBA | Representative Background Sound Level, dBA |
| BNAL01 (NSR10) | 10 | 30 | -20 | 10 | 23 | -13 |
| BNAL02 (NSR2) | 19 | 33 | -14 | 19 | 25 | -6 |
| BNAL03 (NSR7) | 15 | 31 | -16 | 15 | 24 | -9 |
| BNAL04 (NSR65) | 13 | 33 | -20 | 13 | 22 | -9 |
| BNAL05 (NSR34) | 23 | 33 | -10 | 23 | 28 | -5 |
| BNAL06 (NSR8) | 28 | 32 | -4 | 28 | 25 | +3 |
| BNAL07 (NSR46) | 22 | 33 | -11 | 22 | 29 | -7 |

RECEIVED: 29/08/2024

For all receptors the Rating Levels remain below the background sound levels during the daytime. This is *“an indication of the specific sound source having a low impact, depending on the context.”*

For all NALs except BNAL06, the Rating level also remains below the background sound level during the night-time. This is *“an indication of the specific sound source having a low impact, depending on the context.”*

At BNAL06 the Rating Level exceeds the background sound level by a maximum of +3 dB during the night-time, which is below the level that is *“indication of an adverse impact, depending on the context.”*

The context in which the assessment is made is as follows;

- The primary noise generation mechanism for all plant associated with this development is related to cooling. The noise model assumes all cooling plant for batteries, inverters and transformers is operating at maximum noise level output, however, this will only occur when ambient temperatures are high or the equipment is under full load. For much of the time cooling equipment will be operating at lower capacities and overall sound output will be reduced.
- Similarly, the noise model assumes all plant is operating concurrently, however not all cooling (or heating) units will necessarily be required to operate at the same time and as such, overall noise levels are likely to be lower than predicted.
- The Rating Levels at all NALs have been classed as ‘low’ i.e. below 35 dB LAeq(t) and the background sound levels at night are classed as ‘very low’ (below 30 dB LA90(10mins)). In this situation BS 4142 states that the *“absolute levels might be as, or more, relevant than the margin by which the rating level exceeds the background. This is especially true at*

night". The absolute levels will remain well below the fixed guideline values as detailed in BS 8233 for all receptors and for all time periods.

Additionally, BS 4142 defines Residual Sound as the "*ambient sound remaining at the assessment location when the specific sound source is suppressed to such a degree that it does not contribute to the ambient sound*". The Residual Sound Level, L_r , is the 'equivalent continuous A-weighted sound pressure level of the residual sound at the assessment location over a given time interval, T' measured using the $L_{Aeq,t}$ index. In this situation, the specific sound source (i.e. the BESS development) is proposed and as is not currently operational, therefore, baseline $L_{Aeq,t}$ sound level measurements represent the Residual Sound Level.

An analysis of the measured $L_{Aeq,t}$ values at NML2 (where the highest levels are predicted – BNAL06) shows the average daytime and night-time levels to be 45 dBA and 32 dBA, respectively. The overall sound level increase during the night-time (32 dB + 28 dB) is less than 1.5 dB. For context, a change of 3 dB(A) is generally considered to be the smallest change in environmental noise that is perceptible to the human ear and is considered '*just perceptible*'. As such, an increase of 1.5 dB is not anticipated to result in an adverse impact.

With due regards to the context of the development, **the outcome of the BS 4142 assessment is that the Proposed Project is not expected to have an adverse impact in terms of noise resulting from the BESS.**

6 Summary

In order to assess the impact of noise emissions from the proposed BESS compound within the Proposed Project, TNEI has produced a noise propagation model in accordance with ISO 9613-2:1996 that predicts the noise immission levels at the nearest identified residential receptors. The model is based on a layout and candidate plant that is typical for this type of BESS development. A number of residential properties were identified and assessed, the nearest of which is approximately 825 m to the west of the proposed BESS location.

Two assessments considering the nearest residential NSRs have been carried out;

- A quantitative assessment has concluded that levels would remain below the fixed guideline levels detailed in BS 8233 for the daytime and night-time assessment periods.
- A quantitative assessment was undertaken in accordance with BS 4142. This assessment concluded that for all BNALs during the daytime and all BNALs except NAL06 during the night-time, *“the rating level does not exceed the background sound level, this is an indication of the specific sound source having a low impact, depending on the context.”*
- At BNAL06 the Rating Level exceeds the background sound level during the night-time by +3 dB which is below the level that is an *“indication of an adverse impact, depending on the context.”* After consideration of the context the assessment concludes that there is no indication of an adverse impact at the receptors.

Accordingly, the Noise Impact Assessment concludes that the Proposed BESS Development will not have an adverse noise impact on the local area.

7 References

1. **Association of Noise Consultants.** *Acoustics Ventilation and Overheating (AVO) Residential Design Guide.* 2020.
2. **(ISO), International Organization for Standardization.** *Acoustics – Attenuation of Sound During Propagation Outdoors: Part 2 – General Method of Calculation.* Geneva : (ISO), International Organization for Standardization, 1996. ISO 9613-2:1996.
3. **Commission Electrotechnique Internationale (IEC).** *Electroacoustics - Sound level meters - Part 1: Specifications.* Geneva : IEC, 2013. IEC 61672-1:2013.
4. **British Standards Institute.** *Guidance on Sound Insulation and Noise Reduction for Buildings.* UK : BSI, 2014. BS8233:2014.
5. —. *Methods for Rating and Assessing Industrial and Commercial Sound.* UK : BSI, 2014. BS4142:2014 + A1:2019.
6. **Association of Noise Consultants.** *ANC Good Practice Working Group, BS 4142:2014+A1:2019 Technical Note. s.1.* 2020.

Annex 1 – Glossary of Terms

RECEIVED: 29/08/2024

Attenuation: the reduction in level of a sound between the source and a receiver due to any combination of effects including: distance, atmospheric absorption, acoustic screening, the presence of a building façade, etc.

Background Sound Level: the sound level rarely fallen below in any given location over any given time period, often classed according to daytime, evening or night-time periods. The LA90 indices (see below) are typically used to represent the background sound level.

Broadband Noise: noise with components over a wide range of frequencies.

Decibel (dB): the ratio between the quietest audible sound and the loudest tolerable sound is a million to one in terms of the change in sound pressure. A logarithmic scale is used in sound level measurements because of this wide range. The scale used is the decibel (dB) scale which extends from 0 to 140 decibels (dB) corresponding to the intensity of the sound level.

dB(A): the ear has the ability to recognise a particular sound depending on its pitch or frequency. Microphones cannot differentiate sound in the same way as the ear, and to counter this weakness the sound measuring instrument applies a correction to correspond more closely to the frequency response of the human ear. The correction factor is called 'A Weighting' and the resulting measurements are written as dB(A). The dB(A) weighting is internationally accepted and has been found to correspond well with people's subjective reaction to sound levels and noise. Some typical subjective changes in sound levels are:

- a change of 3 dB(A) is just perceptible;
- a change of 5 dB(A) is clearly perceptible; and
- a change of 10 dB(A) is twice (or half) as loud.

Directivity: the property of a sound source that causes more sound to be radiated in one direction than another.

Emission: the sound energy emitted by a sound source (e.g. a wind turbine).

Frequency: the pitch of a sound in Hz or kHz. See Hertz.

Ground Effects: the modification of sound at a receiver location due to the interaction of the sound waves with the ground along its propagation path from source to receiver. Described using the term 'G', and ranges between 0 (hard ground), 0.5 (mixed ground) and 1 (soft ground).

Hertz (Hz): sound frequency refers to how quickly the air vibrates, or how close the sound waves are to each other (in cycles per second, or Hertz (Hz)).

Immission: the sound pressure level detected at a given location (e.g. the nearest dwelling).

Isopleth: a line on a map connecting points of equal value, for example air pressure, noise level etc.

Noise: unwanted sound.

L_w : is the sound power level. It is a measure of the total sound energy radiated by a sound source and is used to calculate sound levels at a distant location. The L_{WA} is the A - weighted sound power level.

L_{eq} : is the equivalent continuous sound level, and is the sound level of a steady sound with the same energy as a fluctuating sound over the same period. It is possible to consider this level as the ambient noise encompassing all noise at a given time. The $L_{Aeq,T}$ is the A - weighted equivalent continuous sound level over a given time period (T).

L_{90} : index represents the sound level exceeded for 90 percent of the measurement period and is used to indicate quieter times during the measurement period. It is often used to measure the background sound level. The $L_{A90,10min}$ is the A - weighted background sound level over a ten-minute measurement sample.

Sound Level Meter: an instrument for measuring sound pressure level.

Sound Pressure Level: a measure of the sound pressure at a point, in decibels.


Tonal Noise: noise which covers a very restricted range of frequencies (e.g. a range of ≤ 20 Hz). This noise is subjectively more annoying than broadband noise.

Annex 2– Development Information

RECEIVED: 29/08/2024

Project Management Initials: Designer: JC Checked: JWP Approved: DB
 ISC A1 594mm x 841mm

Map Series:
 Prime Data Vector
 ITM Centre Point Co-ordinate:
 X,Y = 659882.0,667199.37
 Ordnance Survey Ireland Licence No.
 CYAL50261649
 Copyright:
 © Suirbhéireacht Ordnáis Éireann, 2024
 © Ordnance Survey Ireland, 2024



Wind Farm-Substation Compound Layout
 SCALE 1:250



| | Description |
|-------|---------------------------|
| VT | Voltage Transformer. |
| CT | Current Transformer. |
| CT/VT | Combined CT & VT |
| CB | Circuit Breaker. |
| LM | Lighting Mast. |
| LS | Lamp Standard. |
| NER | Neutral Earthing Resistor |
| CSE | Cable Sealing End. |
| DS | Disconnect Switch |
| T | Transformer |

tli GROUP
 Head Office: Beenreigh, Abbeydorney, Tralee, Co. Kerry, Ireland. Tel: 00353 66 7135710
 Regional Office: Basepoint Business Centre, Stroudley Road, Basingstoke, Hampshire, RG24 8UP, UK. Tel: 00 44 1256406664

PROJECT
 Lackareagh Wind Farm
 38kV Grid Connection

CLIENT

CONSULTANTS

- NOTES: -**
- Configuration of substation equipment and infrastructure is subject to detailed design and ESB design approval.
 - The proposed substation layout should be used for planning purposes only.
 - This drawing is to be read in conjunction with relevant drawings, specifications and reports.
 - Dimensions are in millimeters, unless noted otherwise.
 - Drawings are not to be scaled use figured dimensions only.

- LEGEND: -**
- Surface water drainage shown thus
 - Lamp Standard shown thus
 - Proposed Levels Shown thus (Planning)
 - Proposed UGC Route
 - Contours 14.0
 - Planning Boundary shown thus
 - Cut Area shown thus
 - Fill Area shown thus

ISSUE/REVISION

| I/R | DATE | DESCRIPTION |
|-----|----------|---------------------|
| P6 | 05.03.24 | Issued for Planning |
| P5 | 21.02.24 | Issued for Planning |
| P4 | 23.01.24 | Issued for Planning |
| P3 | 11.10.23 | Issued for Planning |
| P2 | 09.10.23 | Issued for Planning |
| P1 | 14.07.23 | Issued for Planning |

PROJECT NUMBER
 05-909
SHEET TITLE
 38kV Substation Compound Layout
SHEET NUMBER
 05909-DR-150


Annex 3 - Baseline Survey Data

RECEIVED: 29/08/2024

IE00101 - Lackareagh - Measured Sound Levels:

RECEIVED: 29/08/2024

Time History - NML01




- | | |
|--|---|
| — LA_{eq} (10 mins) | ✕ Auto Exclusion - Windspeed > 5.0 m/s |
| ● Weekday - Daytime LA_{90} (10 mins) | ✕ Manual Exclusion |
| ● Weekday - Night-time LA_{90} (10 mins) | ✕ Corrupt/Incomplete Data |
| ▲ Weekend - Daytime LA_{90} (10 mins) | — Windspeed |
| ▲ Weekend - Night-time LA_{90} (10 mins) | - - - Windspeed Cutoff |
| ✕ Auto Exclusion - Precipitation Event | |

IE00101 - Lackareagh - Measured Sound Levels:

RECEIVED: 29/08/2024

Time History - NML02




- | | |
|--|---|
| — LA_{eq} (10 mins) | ✕ Auto Exclusion - Windspeed > 5.0 m/s |
| ● Weekday - Daytime LA_{90} (10 mins) | ✕ Manual Exclusion |
| ● Weekday - Night-time LA_{90} (10 mins) | ✕ Corrupt/Incomplete Data |
| ▲ Weekend - Daytime LA_{90} (10 mins) | — Windspeed |
| ▲ Weekend - Night-time LA_{90} (10 mins) | - - - Windspeed Cutoff |
| ✕ Auto Exclusion - Precipitation Event | |

IE00101 - Lackareagh - Measured Sound Levels:

RECEIVED: 29/08/2024

Time History - NML03




- | | |
|--|---|
| — LA_{eq} (10 mins) | ✕ Auto Exclusion - Windspeed > 5.0 m/s |
| ● Weekday - Daytime LA_{90} (10 mins) | ✕ Manual Exclusion |
| ● Weekday - Night-time LA_{90} (10 mins) | ✕ Corrupt/Incomplete Data |
| ▲ Weekend - Daytime LA_{90} (10 mins) | — Windspeed |
| ▲ Weekend - Night-time LA_{90} (10 mins) | - - - Windspeed Cutoff |
| ✕ Auto Exclusion - Precipitation Event | |

IE00101 - Lackareagh - Measured Sound Levels:

RECEIVED: 29/08/2024

Time History - NML04




- | | |
|--|---|
| — LA_{eq} (10 mins) | ✕ Auto Exclusion - Windspeed > 5.0 m/s |
| ● Weekday - Daytime LA_{90} (10 mins) | ✕ Manual Exclusion |
| ● Weekday - Night-time LA_{90} (10 mins) | ✕ Corrupt/Incomplete Data |
| ▲ Weekend - Daytime LA_{90} (10 mins) | — Windspeed |
| ▲ Weekend - Night-time LA_{90} (10 mins) | - - - Windspeed Cutoff |
| ✕ Auto Exclusion - Precipitation Event | |

IE00101 - Lackareagh - Measured Sound Levels:

RECEIVED: 29/08/2024

Time History - NML05




- | | | | |
|---|---|-------|--------------------------------------|
| — | LA _{eq} (10 mins) | ✕ | Auto Exclusion - Windspeed > 5.0 m/s |
| ● | Weekday - Daytime LA ₉₀ (10 mins) | ✕ | Manual Exclusion |
| ● | Weekday - Night-time LA ₉₀ (10 mins) | ✕ | Corrupt/Incomplete Data |
| ▲ | Weekend - Daytime LA ₉₀ (10 mins) | — | Windspeed |
| ▲ | Weekend - Night-time LA ₉₀ (10 mins) | - - - | Windspeed Cutoff |
| ✕ | Auto Exclusion - Precipitation Event | | |

IE00101 - Lackareagh - Measured Sound Levels:

RECEIVED: 29/08/2024

Time History - NML06




- LA_{eq} (10 mins)
- Weekday - Daytime LA₉₀ (10 mins)
- Weekday - Night-time LA₉₀ (10 mins)
- ▲ Weekend - Daytime LA₉₀ (10 mins)
- ▲ Weekend - Night-time LA₉₀ (10 mins)
- × Auto Exclusion - Precipitation Event
- × Auto Exclusion - Windspeed > 5.0 m/s
- × Manual Exclusion
- × Corrupt/Incomplete Data
- Windspeed
- - - Windspeed Cutoff

IE00101 - Lackareagh - Measured Sound Levels:

RECEIVED: 29/08/2024

Time History - NML07




- | | |
|--|---|
| — LA_{eq} (10 mins) | ✕ Auto Exclusion - Windspeed > 5.0 m/s |
| ● Weekday - Daytime LA_{90} (10 mins) | ✕ Manual Exclusion |
| ● Weekday - Night-time LA_{90} (10 mins) | ✕ Corrupt/Incomplete Data |
| ▲ Weekend - Daytime LA_{90} (10 mins) | — Windspeed |
| ▲ Weekend - Night-time LA_{90} (10 mins) | - - - Windspeed Cutoff |
| ✕ Auto Exclusion - Precipitation Event | |


IE00101 - Lackareagh - Measured Sound Levels:

RECEIVED: 29/08/2024

Statistical Analysis - NML01




Statistical Analysis - NML01




IE00101 - Lackareagh - Measured Sound Levels:

RECEIVED: 29/08/2024

Statistical Analysis - NML02




Statistical Analysis - NML02




IE00101 - Lackareagh - Measured Sound Levels:

RECEIVED: 29/08/2024

Statistical Analysis - NML03




Statistical Analysis - NML03




IE00101 - Lackareagh - Measured Sound Levels:

RECEIVED: 29/08/2024

Statistical Analysis - NML04




Statistical Analysis - NML04




IE00101 - Lackareagh - Measured Sound Levels:

RECEIVED: 29/08/2024

Statistical Analysis - NML05




Statistical Analysis - NML05




IE00101 - Lackereagh - Measured Sound Levels:

RECEIVED: 29/08/2024

Statistical Analysis - NML06




Statistical Analysis - NML06




IE00101 - Lackareagh - Measured Sound Levels:

RECEIVED: 29/08/2024

Statistical Analysis - NML07



Statistical Analysis - NML07



Annex 4 – Noise Modelling Data

RECEIVED: 29/08/2024



TEST REPORT

Report No.:

2021/0141/031

Page 12 of 68

RECEIVED: 29/08/2024

Sound Level

Serial No.: 1ZPL009134582

| Measurement Details | | | |
|-------------------------------|--|------|------------|
| Measurement Standard | IEC 60076-10:2016 | | |
| Measurement Method | Sound Intensity Method | | |
| Measurement Procedure | Walk around | | |
| Frequency Resolution | ½ Octave Band | | |
| Acoustic Filter Function | A-weighted | | |
| Measurement Instruments | Manufacturer | Type | Serial No. |
| Sound Level Meter | Brüel & Kjær | 2270 | 3023666 |
| Sound Level Meter Calibration | Brüel & Kjær | 4297 | 3082325 |
| X | The equipment used has been laboratory calibrated in accordance with manufacturers recommendations and field calibrated before and after each measurement session. | | |

| Test Program | | | | | | | | | | | | | | |
|--------------|-----------------------|--------------------|--------------|----------------|-----------------|----------------|--------------|------------------------|------------|-------------------|----------------------|--------------------------|-------------------|------------------------------|
| Test# | No-Load condition [%] | Load condition [%] | Tap position | Number of fans | Number of pumps | Frequency [Hz] | Distance [m] | Prescribed contour [m] | Height [m] | Surface area [m²] | Surface measure [dB] | Top oil temperature [°C] | Guarantee [dB(A)] | Sound Pressure Level [dB(A)] |
| 1 | 100 | | 11 | 0 | | 50 | 1.0 | 31.1 | 5.2 | 193 | 22.9 | | | 54.0 |
| 2 | 100 | | 11 | 8 | | 50 | 2.0 | 37.5 | 5.2 | 270 | 24.3 | | | 63.4 |
| 3 | | 100 | 11 | 0 | | 50 | 1.0 | 31.1 | 5.2 | 193 | 22.9 | | | 56.1 |
| 4 | | 100 | 11 | 8 | | 50 | 2.0 | 37.5 | 5.2 | 270 | 24.3 | | | 63.5 |
| 5 | | | | | | | | | | | | | | |
| 6 | | | | | | | | | | | | | | |
| 7 | | | | | | | | | | | | | | |
| 8 | | | | | | | | | | | | | | |
| 1+4 | 100 | 100 | | 8 | | | 2.0 | | | | | | 70.0 | 63.8 |

Standard: IEC 60076-10
Test Date 16/08/2021
Test Engineer Kamil Maliński

Issue Date
29/09/2021

Test Engineer
Kamil Maliński


Test Department
Test Field

RECEIVED 29/08/2024

Sound Level

Serial No. : 1ZP4.001134582

| Prescribed Contours | | | | |
|---------------------|-----------------------------|-------------|-------------------|--------------------------|
| x Distance | l_m Prescribed contour | h Height | S Surface area | L_s Surface measure |
| [m] | [m] | [m] | [m ²] | [dB] |
| 1 | 31.1 | 5.2 | 192.82 | 22.9 |
| 2 | 37.5 | 5.2 | 270 | 24.3 |



Issue Date
29/09/2021

Test Engineer
Kamil Maliński

Test Department
Test Field



TEST REPORT

Report No.:
2021/0141/031
Page 14 of 68

RECEIVED 29/08/2024

Sound Level

Serial No. : 1ZPL001134582

| Measurement 1 | | | | | | | | | | | | | | |
|---------------|-----------------|---------------|-----------------|--------------|-------------------|--------------------|-----------|----------|--------------------|--------|-------------------|-----------------|---------------------|-----------|
| Rated voltage | Applied voltage | Rated current | Applied current | Tap position | Fans in operation | Pumps in operation | Frequency | Distance | Prescribed contour | Height | Surface area | Surface measure | Top oil temperature | Guarantee |
| [kV] | [kV] | [A] | [A] | | | | [Hz] | [m] | [m] | [m] | [m ²] | [dB] | [°C] | [dB(A)] |
| 100 | 33 | | | 11 | 0 | | 50 | 1 | 31.1 | 5.2 | 192.8 | 22.9 | | |

Measurement duration: 85 s

| | Frequency | L_{pA0} | L_{pA0} | $L_{pA0} - L_{pA0}$ | Pressure Intensity Correction | L_{pA} | L_{WA} |
|--------------------------|-----------|-----------|-----------|---------------------|-------------------------------|-----------|-----------|
| | [Hz] | [dB(A)] | [dB(A)] | [dB(A)] | | [dB(A)] | [dB(A)] |
| Total Sound Level | | 54.0 | 1 | 57.3 | 3.3 | A | 54.0 76.9 |
| Octave Band | 63 | 15.5 | 1 | 23.3 | 7.8 | A | 16.8 39.6 |
| | 125 | 36.6 | 1 | 39.9 | 3.2 | A | 36.6 59.5 |
| | 250 | 53.3 | 1 | 56.2 | 2.9 | A | 53.3 76.1 |
| | 500 | 44.5 | 1 | 47.5 | 3.0 | A | 44.5 67.3 |
| | 1000 | 33.4 | 1 | 40.3 | 6.8 | A | 33.4 56.3 |
| | 2000 | 28.8 | 1 | 40.1 | 11.3 | A | 28.8 51.6 |
| | 4000 | 31.3 | 1 | 40.8 | 9.5 | A | 31.3 54.1 |
| 1/3 Octave Band | 8000 | 34.6 | 1 | 43.3 | 8.7 | A | 34.6 57.4 |
| | 50 | 13.3 | 1 | 13.5 | 0.3 | A | 13.3 36.1 |
| | 63 | 14.2 | 1 | 16.0 | 1.8 | A | 14.2 37.0 |
| | 80 | 10.9 | -1 | 21.8 | 10.9 | A | 0.0 0.0 |
| | 100 | 35.6 | 1 | 37.5 | 1.9 | A | 35.6 58.4 |
| | 125 | 24.6 | 1 | 34.3 | 9.6 | A | 24.6 47.5 |
| | 160 | 28.4 | 1 | 31.6 | 3.2 | A | 28.4 51.3 |
| | 200 | 40.3 | 1 | 43.4 | 3.1 | A | 40.3 63.1 |
| | 250 | 38.0 | 1 | 41.2 | 3.1 | A | 38.0 60.9 |
| | 315 | 52.9 | 1 | 55.8 | 2.9 | A | 52.9 75.8 |
| | 400 | 38.4 | 1 | 41.1 | 2.7 | A | 38.4 61.2 |
| | 500 | 40.8 | 1 | 43.9 | 3.1 | A | 40.8 63.7 |
| | 630 | 39.6 | 1 | 42.7 | 3.1 | A | 39.6 62.5 |
| | 800 | 30.9 | 1 | 36.3 | 5.4 | A | 30.9 53.7 |
| | 1000 | 28.6 | 1 | 35.3 | 6.7 | A | 28.6 51.4 |
| | 1250 | 24.3 | 1 | 34.8 | 10.5 | A | 24.3 47.1 |
| | 1600 | 24.1 | 1 | 35.3 | 11.2 | A | 24.1 47.0 |
| 2000 | 23.8 | 1 | 35.5 | 11.7 | A | 23.8 46.7 | |
| 2500 | 24.1 | 1 | 35.1 | 11.0 | A | 24.1 46.9 | |
| 3150 | 25.6 | 1 | 35.9 | 10.4 | A | 25.6 48.4 | |
| 4000 | 26.7 | 1 | 36.1 | 9.3 | A | 26.7 49.6 | |
| 5000 | 27.1 | 1 | 36.1 | 9.0 | A | 27.1 49.9 | |
| 6300 | 28.4 | 1 | 37.5 | 9.2 | A | 28.4 51.2 | |
| 8000 | 30.1 | 1 | 39.1 | 9.1 | A | 30.1 52.9 | |
| 10000 | 30.7 | 1 | 38.9 | 8.1 | A | 30.7 53.6 | |

Case A: Applies, if the total P-I index is $\Delta L \leq 4$ dB. Then it follows $L_{pA} = L_{pA0}$ for both the total sound level and sound levels of the individual frequency bands.

Case B: Applies, if the total P-I index is $4 \text{ dB} < \Delta L \leq 8$ dB. Then it follows $L_{pA} = L_{pA0} - 4$ dB for both the total sound level and sound levels of the individual frequency bands.

Issue Date
29/09/2021

Test Engineer
Kamil Maliński

Test Department
Test Field




TEST REPORT

Report No.:
2021/0141/031
Page 15 of 68

RECEIVED 29/08/2024

Sound Level

Serial No. : 1ZPL001134582



Issue Date
29/09/2021

Test Engineer
Kamil Maliński

Test Department
Test Field



TEST REPORT

Report No.:
2021/0141/031
Page 16 of 68

RECEIVED 29/08/2024

Sound Level

Serial No. : 1ZPL001134582

| Measurement 2 | | | | | | | | | | | | | | |
|---------------|-----------------|---------------|-----------------|--------------|-------------------|--------------------|-----------|----------|--------------------|--------|-------------------|-----------------|---------------------|-----------|
| Rated voltage | Applied voltage | Rated current | Applied current | Tap position | Fans in operation | Pumps in operation | Frequency | Distance | Prescribed contour | Height | Surface area | Surface measure | Top oil temperature | Guarantee |
| [%] | [kV] | [%] | [A] | | | | [Hz] | [m] | [m] | [m] | [m ²] | [dB] | [°C] | [dB(A)] |
| 100 | 33 | | | 11 | 8 | | 50 | 2 | 37.5 | 5.2 | 270.0 | 24.3 | | |

Measurement duration: 95 s

| | Frequency | L _{1A0} | | L _{1pA0} | L _{1pA0} - L _{1A0} | Pressure Intensity Correction | L _{1A} | L _{1WA} |
|--------------------------|-----------|------------------|------|-------------------|--------------------------------------|-------------------------------|-----------------|------------------|
| | [Hz] | [dB(A)] | | [dB(A)] | [dB(A)] | | [dB(A)] | [dB(A)] |
| Total Sound Level | | 63.4 | 1 | 65.6 | 2.2 | A | 63.4 | 87.7 |
| Octave Band | 63 | 33.4 | 1 | 34.1 | 0.7 | A | 33.4 | 57.8 |
| | 125 | 47.7 | 1 | 49.2 | 1.5 | A | 47.7 | 72.0 |
| | 250 | 58.5 | 1 | 60.3 | 1.9 | A | 58.5 | 82.8 |
| | 500 | 58.5 | 1 | 60.7 | 2.2 | A | 58.5 | 82.8 |
| | 1000 | 57.2 | 1 | 59.6 | 2.4 | A | 57.2 | 81.5 |
| | 2000 | 50.6 | 1 | 53.3 | 2.6 | A | 50.6 | 74.9 |
| | 4000 | 46.7 | 1 | 49.8 | 3.0 | A | 46.7 | 71.0 |
| 8000 | 41.6 | 1 | 46.1 | 4.6 | A | 41.6 | 65.9 | |
| 1/3 Octave Band | 50 | 26.8 | 1 | 27.3 | 0.5 | A | 26.8 | 51.1 |
| | 63 | 24.0 | 1 | 23.6 | -0.4 | A | 24.0 | 48.3 |
| | 80 | 31.7 | 1 | 32.6 | 0.9 | A | 31.7 | 56.0 |
| | 100 | 39.9 | 1 | 41.4 | 1.5 | A | 39.9 | 64.2 |
| | 125 | 43.6 | 1 | 45.0 | 1.4 | A | 43.6 | 67.9 |
| | 160 | 44.2 | 1 | 45.7 | 1.5 | A | 44.2 | 68.5 |
| | 200 | 49.2 | 1 | 50.9 | 1.7 | A | 49.2 | 73.5 |
| | 250 | 52.1 | 1 | 53.7 | 1.6 | A | 52.1 | 76.4 |
| | 315 | 56.6 | 1 | 58.6 | 2.0 | A | 56.6 | 80.9 |
| | 400 | 52.8 | 1 | 55.1 | 2.2 | A | 52.8 | 77.2 |
| | 500 | 52.8 | 1 | 55.1 | 2.3 | A | 52.8 | 77.1 |
| | 630 | 55.1 | 1 | 57.2 | 2.2 | A | 55.1 | 79.4 |
| | 800 | 54.1 | 1 | 56.5 | 2.4 | A | 54.1 | 78.4 |
| | 1000 | 52.1 | 1 | 54.5 | 2.3 | A | 52.1 | 76.5 |
| | 1250 | 50.0 | 1 | 52.5 | 2.6 | A | 50.0 | 74.3 |
| | 1600 | 47.7 | 1 | 50.3 | 2.6 | A | 47.7 | 72.0 |
| | 2000 | 45.3 | 1 | 48.0 | 2.7 | A | 45.3 | 69.6 |
| 2500 | 43.6 | 1 | 46.3 | 2.7 | A | 43.6 | 67.9 | |
| 3150 | 42.7 | 1 | 45.6 | 2.9 | A | 42.7 | 67.0 | |
| 4000 | 42.3 | 1 | 45.4 | 3.1 | A | 42.3 | 66.6 | |
| 5000 | 40.6 | 1 | 43.7 | 3.1 | A | 40.6 | 64.9 | |
| 6300 | 37.9 | 1 | 41.9 | 4.0 | A | 37.9 | 62.2 | |
| 8000 | 36.3 | 1 | 41.1 | 4.8 | A | 36.3 | 60.6 | |
| 10000 | 35.9 | 1 | 41.0 | 5.1 | A | 35.9 | 60.3 | |

Case A: Applies, if the total P-I index is $\Delta L \leq 4$ dB. Then it follows $L_{1A} = L_{1A0}$ for both the total sound level and sound levels of the individual frequency bands.

Case B: Applies, if the total P-I index is $4 \text{ dB} < \Delta L \leq 8$ dB. Then it follows $L_{1A} = L_{1A0} - 4$ dB for both the total sound level and sound levels of the individual frequency bands.

Issue Date
29/09/2021

Test Engineer
Kamil Maliński



Test Department
Test Field

RECEIVED 29/08/2024

Sound Level

Serial No. : 1ZPL001134582

Measurement 2





TEST REPORT

Report No.:
2021/0141/031
Page 18 of 68

RECEIVED 29/08/2024

Sound Level

Serial No. : 1ZPL001134582

| Measurement 3 | | | | | | | | | | | | | | |
|---------------|-----------------|---------------|-----------------|--------------|-------------------|--------------------|-----------|----------|--------------------|--------|-------------------|-----------------|---------------------|-----------|
| Rated voltage | Applied voltage | Rated current | Applied current | Tap position | Fans in operation | Pumps in operation | Frequency | Distance | Prescribed contour | Height | Surface area | Surface measure | Top oil temperature | Guarantee |
| [kV] | [kV] | [A] | [A] | | | | [Hz] | [m] | [m] | [m] | [m ²] | [dB] | [°C] | [dB(A)] |
| | | 100 | 262.43 | 11 | 0 | | 50 | 1 | 31.1 | 5.2 | 192.8 | 22.9 | | |

Measurement duration: 85 s

| | Frequency | L_{WA} | L_{pAD} | $L_{pAD} - L_{WA}$ | Pressure Intensity Correction | L_{JA} | L_{WA} |
|--------------------------|-----------|-------------|-----------|--------------------|-------------------------------|----------|-------------|
| | [Hz] | [dB(A)] | [dB(A)] | [dB(A)] | | [dB(A)] | [dB(A)] |
| Total Sound Level | | 56.1 | 1 | 58.1 | 2.1 | A | 56.1 |
| Octave Band | 63 | 40.3 | 1 | 46.7 | 6.4 | A | 40.3 |
| | 125 | 55.0 | 1 | 56.5 | 1.5 | A | 55.0 |
| | 250 | 47.0 | 1 | 49.4 | 2.4 | A | 47.0 |
| | 500 | 39.9 | 1 | 43.3 | 3.4 | A | 39.9 |
| | 1000 | 37.9 | 1 | 42.2 | 4.3 | A | 37.9 |
| | 2000 | 39.0 | 1 | 43.1 | 4.1 | A | 39.0 |
| | 4000 | 28.6 | 1 | 38.2 | 9.6 | A | 28.6 |
| 1/3 Octave Band | 8000 | 18.4 | 1 | 31.5 | 13.1 | A | 18.6 |
| | 50 | 40.2 | 1 | 46.5 | 6.4 | A | 40.2 |
| | 63 | 24.6 | 1 | 30.1 | 5.6 | A | 24.6 |
| | 80 | 21.0 | 1 | 29.3 | 8.3 | A | 21.0 |
| | 100 | 49.0 | 1 | 51.8 | 2.8 | A | 49.0 |
| | 125 | 38.9 | 1 | 41.0 | 2.1 | A | 38.9 |
| | 160 | 53.7 | 1 | 54.6 | 0.9 | A | 53.7 |
| | 200 | 42.2 | 1 | 44.7 | 2.5 | A | 42.2 |
| | 250 | 39.7 | 1 | 42.0 | 2.3 | A | 39.7 |
| | 315 | 43.9 | 1 | 46.2 | 2.3 | A | 43.9 |
| | 400 | 37.4 | 1 | 40.5 | 3.1 | A | 37.4 |
| | 500 | 33.8 | 1 | 37.6 | 3.8 | A | 33.8 |
| | 630 | 32.4 | 1 | 36.3 | 3.8 | A | 32.4 |
| | 800 | 31.9 | 1 | 35.3 | 3.4 | A | 31.9 |
| | 1000 | 32.2 | 1 | 37.2 | 5.0 | A | 32.2 |
| | 1250 | 34.7 | 1 | 38.9 | 4.3 | A | 34.7 |
| | 1600 | 37.3 | 1 | 40.7 | 3.3 | A | 37.3 |
| | 2000 | 31.3 | 1 | 37.0 | 5.7 | A | 31.3 |
| | 2500 | 30.8 | 1 | 36.0 | 5.2 | A | 30.8 |
| | 3150 | 25.5 | 1 | 34.7 | 9.1 | A | 25.5 |
| 4000 | 24.1 | 1 | 33.6 | 9.5 | A | 24.1 | |
| 5000 | 20.2 | 1 | 31.3 | 11.1 | A | 20.2 | |
| 6300 | 17.3 | 1 | 28.7 | 11.4 | A | 17.3 | |
| 8000 | 12.5 | 1 | 26.4 | 13.9 | A | 12.5 | |
| 10000 | 2.9 | -1 | 23.9 | 21.0 | A | 0.0 | |

Case A: Applies, if the total P-I index is $\Delta L \leq 4$ dB. Then it follows $L_{JA} = L_{pAD}$ for both the total sound level and sound levels of the individual frequency bands.

Case B: Applies, if the total P-I index is $4 \text{ dB} < \Delta L \leq 8$ dB. Then it follows $L_{JA} = L_{pAD} - 4$ dB for both the total sound level and sound levels of the individual frequency bands.

Issue Date
29/09/2021

Test Engineer
Kamil Maliński



Test Department
Test Field

RECEIVED 29/08/2024

Sound Level

Serial No. : 1ZPL001134582

Measurement 3





TEST REPORT

Report No.:
2021/0141/031
Page 20 of 68

RECEIVED 29/08/2024

Sound Level

Serial No. : 1ZPL001134582

| Measurement 4 | | | | | | | | | | | | | | |
|---------------|-----------------|---------------|-----------------|--------------|-------------------|--------------------|-----------|----------|--------------------|--------|-------------------|-----------------|---------------------|-----------|
| Rated voltage | Applied voltage | Rated current | Applied current | Tap position | Fans in operation | Pumps in operation | Frequency | Distance | Prescribed contour | Height | Surface area | Surface measure | Top oil temperature | Guarantee |
| [kV] | [kV] | [A] | [A] | | | | [Hz] | [m] | [m] | [m] | [m ²] | [dB] | [°C] | [dB(A)] |
| | | 100 | 262.43 | 11 | 8 | | 50 | 2 | 37.5 | 5.2 | 270.0 | 24.3 | | |

Measurement duration: 89 s

| | Frequency | L_{pAO} | L_{pAO} | $L_{pAO} - L_{pAO}$ | Pressure Intensity Correction | L_{pA} | L_{WA} |
|--------------------------|-----------|-------------|-----------|---------------------|-------------------------------|----------|-------------|
| | [Hz] | [dB(A)] | [dB(A)] | [dB(A)] | | [dB(A)] | [dB(A)] |
| Total Sound Level | | 63.5 | 1 | 65.5 | 2.0 | A | 63.5 |
| Octave Band | 63 | 40.1 | 1 | 43.3 | 3.2 | A | 40.1 |
| | 125 | 55.3 | 1 | 56.9 | 1.6 | A | 55.3 |
| | 250 | 56.9 | 1 | 58.6 | 1.7 | A | 56.9 |
| | 500 | 58.3 | 1 | 60.4 | 2.1 | A | 58.3 |
| | 1000 | 57.4 | 1 | 59.6 | 2.2 | A | 57.4 |
| | 2000 | 51.1 | 1 | 53.5 | 2.4 | A | 51.1 |
| | 4000 | 47.0 | 1 | 49.3 | 2.3 | A | 47.0 |
| 8000 | 39.9 | 1 | 41.6 | 1.8 | A | 39.9 | |
| 1/3 Octave Band | 50 | 39.4 | 1 | 42.7 | 3.3 | A | 39.4 |
| | 63 | 23.1 | 1 | 28.0 | 4.9 | A | 23.1 |
| | 80 | 30.8 | 1 | 33.5 | 2.6 | A | 30.8 |
| | 100 | 47.6 | 1 | 50.6 | 2.9 | A | 47.6 |
| | 125 | 44.2 | 1 | 45.9 | 1.7 | A | 44.2 |
| | 160 | 54.1 | 1 | 55.3 | 1.2 | A | 54.1 |
| | 200 | 49.4 | 1 | 50.9 | 1.6 | A | 49.4 |
| | 250 | 52.1 | 1 | 53.6 | 1.6 | A | 52.1 |
| | 315 | 53.7 | 1 | 55.6 | 1.9 | A | 53.7 |
| | 400 | 52.7 | 1 | 54.8 | 2.1 | A | 52.7 |
| | 500 | 52.6 | 1 | 54.7 | 2.1 | A | 52.6 |
| | 630 | 54.9 | 1 | 56.9 | 2.1 | A | 54.9 |
| | 800 | 54.3 | 1 | 56.6 | 2.3 | A | 54.3 |
| | 1000 | 52.3 | 1 | 54.4 | 2.1 | A | 52.3 |
| | 1250 | 50.2 | 1 | 52.6 | 2.4 | A | 50.2 |
| | 1600 | 48.0 | 1 | 50.5 | 2.5 | A | 48.0 |
| | 2000 | 45.9 | 1 | 48.2 | 2.3 | A | 45.9 |
| | 2500 | 44.2 | 1 | 46.3 | 2.1 | A | 44.2 |
| | 3150 | 43.2 | 1 | 45.5 | 2.3 | A | 43.2 |
| | 4000 | 42.6 | 1 | 45.0 | 2.4 | A | 42.6 |
| 5000 | 40.5 | 1 | 42.6 | 2.1 | A | 40.5 | |
| 6300 | 37.2 | 1 | 39.4 | 2.1 | A | 37.2 | |
| 8000 | 34.5 | 1 | 35.9 | 1.4 | A | 34.5 | |
| 10000 | 32.1 | 1 | 33.0 | 0.9 | A | 32.1 | |

Case A: Applies, if the total P-I index is $\Delta L \leq 4$ dB. Then it follows $L_{pA} = L_{pAO}$ for both the total sound level and sound levels of the individual frequency bands.

Case B: Applies, if the total P-I index is $4 \text{ dB} < \Delta L \leq 8$ dB. Then it follows $L_{pA} = L_{pAO} - 4$ dB for both the total sound level and sound levels of the individual frequency bands.

Issue Date
29/09/2021

Test Engineer
Kamil Maliński



Test Department
Test Field

RECEIVED 29/08/2024

Sound Level

Serial No. : 1ZPL001134582

Measurement 4





TEST REPORT

Report No.:
2021/0141/031
Page 22 of 68

RECEIVED 29/08/2024

Sound Level

Serial No. : 1ZPL001134582

Combination of sound level measurements

| Rated voltage | Applied voltage | Rated current | Applied current | Tap position | Fans in operation | Pumps in operation |
|---------------|-----------------|---------------|-----------------|--------------|-------------------|--------------------|
| [%] | [kV] | [%] | [A] | | | |
| 100 | 33 | 100 | 262.43 | | 8 | |

| Rated voltage | Applied voltage | Rated current | Applied current | Tap position | Fans in operation | Pumps in operation |
|---------------|-----------------|---------------|-----------------|--------------|-------------------|--------------------|
| [%] | [kV] | [%] | [A] | | | |
| | | | | | | |

| Frequency | Measurement 1 Sound Power Level | Measurement 4 Sound Power Level | Combined Sound Power Level |
|-----------|---------------------------------|---------------------------------|----------------------------|
| [Hz] | [dB(A)] | [dB(A)] | [dB(A)] |
| | | | |

| Frequency | Combined Sound Power Level |
|-----------|----------------------------|
| [Hz] | [dB(A)] |
| | |

| | | | | |
|--------------------------|--|------|------|-------------|
| Total Sound Level | | 76.9 | 87.8 | 88.2 |
|--------------------------|--|------|------|-------------|

| | | | | |
|--------------------------|--|--|--|--|
| Total Sound Level | | | | |
|--------------------------|--|--|--|--|

| Octave Band | 63 | 39.6 | 64.4 | 64.4 |
|-------------|------|------|------|------|
| | 125 | 59.5 | 79.6 | 79.6 |
| | 250 | 76.1 | 81.2 | 82.3 |
| | 500 | 67.3 | 82.6 | 82.7 |
| | 1000 | 56.3 | 81.7 | 81.7 |
| | 2000 | 51.6 | 75.4 | 75.4 |
| | 4000 | 54.1 | 71.3 | 71.4 |
| | 8000 | 57.4 | 64.2 | 65.0 |

| Octave Band | 63 | | | |
|-------------|------|--|--|--|
| | 125 | | | |
| | 250 | | | |
| | 500 | | | |
| | 1000 | | | |
| | 2000 | | | |
| | 4000 | | | |
| | 8000 | | | |

| 1/3 Octave Band | 50 | 36.1 | 63.8 | 63.8 |
|-----------------|------|------|------|------|
| | 63 | 37.0 | 47.4 | 47.8 |
| | 80 | 0.0 | 55.1 | 55.1 |
| | 100 | 58.4 | 71.9 | 72.1 |
| | 125 | 47.5 | 68.5 | 68.6 |
| | 160 | 51.3 | 78.4 | 78.4 |
| | 200 | 63.1 | 73.7 | 74.1 |
| | 250 | 60.9 | 76.4 | 76.5 |
| | 315 | 75.8 | 78.0 | 80.1 |
| | 400 | 61.2 | 77.0 | 77.1 |
| | 500 | 63.7 | 76.9 | 77.1 |
| | 630 | 62.5 | 79.2 | 79.3 |
| | 800 | 53.7 | 78.6 | 78.6 |
| | 1000 | 51.4 | 76.7 | 76.7 |
| | 1250 | 47.1 | 74.5 | 74.5 |
| | 1600 | 47.0 | 72.4 | 72.4 |
| | 2000 | 46.7 | 70.2 | 70.2 |
| | 2500 | 46.9 | 68.5 | 68.5 |
| | 3150 | 48.4 | 67.5 | 67.6 |
| | 4000 | 49.6 | 66.9 | 67.0 |
| 5000 | 49.9 | 64.8 | 64.9 | |
| 6300 | 51.2 | 61.5 | 61.9 | |
| 8000 | 52.9 | 58.8 | 59.8 | |
| 10000 | 53.6 | 56.4 | 58.2 | |

| 1/3 Octave Band | 50 | | | |
|-----------------|------|--|--|--|
| | 63 | | | |
| | 80 | | | |
| | 100 | | | |
| | 125 | | | |
| | 160 | | | |
| | 200 | | | |
| | 250 | | | |
| | 315 | | | |
| | 400 | | | |
| | 500 | | | |
| | 630 | | | |
| | 800 | | | |
| | 1000 | | | |
| | 1250 | | | |
| | 1600 | | | |
| | 2000 | | | |
| | 2500 | | | |
| | 3150 | | | |
| | 4000 | | | |
| 5000 | | | | |
| 6300 | | | | |
| 8000 | | | | |
| 10000 | | | | |

Issue Date
29/09/2021

Test Engineer
Kamil Maliński

Test Department
Test Field

Annex 5 – Figures

RECEIVED: 29/08/2024



TEST REPORT

Report No.:

2021/0141/031

Page 12 of 68

RECEIVED: 29/08/2024

Sound Level

Serial No.: 1ZPL009134582

| Measurement Details | | | |
|-------------------------------|--|------|------------|
| Measurement Standard | IEC 60076-10:2016 | | |
| Measurement Method | Sound Intensity Method | | |
| Measurement Procedure | Walk around | | |
| Frequency Resolution | ½ Octave Band | | |
| Acoustic Filter Function | A-weighted | | |
| Measurement Instruments | Manufacturer | Type | Serial No. |
| Sound Level Meter | Brüel & Kjær | 2270 | 3023666 |
| Sound Level Meter Calibration | Brüel & Kjær | 4297 | 3082325 |
| X | The equipment used has been laboratory calibrated in accordance with manufacturers recommendations and field calibrated before and after each measurement session. | | |

| Test Program | | | | | | | | | | | | | | |
|--------------|-----------------------|--------------------|--------------|----------------|-----------------|----------------|--------------|------------------------|------------|-------------------|----------------------|--------------------------|-------------------|------------------------------|
| Test# | No-Load condition [%] | Load condition [%] | Tap position | Number of fans | Number of pumps | Frequency [Hz] | Distance [m] | Prescribed contour [m] | Height [m] | Surface area [m²] | Surface measure [dB] | Top oil temperature [°C] | Guarantee [dB(A)] | Sound Pressure Level [dB(A)] |
| 1 | 100 | | 11 | 0 | | 50 | 1.0 | 31.1 | 5.2 | 193 | 22.9 | | | 54.0 |
| 2 | 100 | | 11 | 8 | | 50 | 2.0 | 37.5 | 5.2 | 270 | 24.3 | | | 63.4 |
| 3 | | 100 | 11 | 0 | | 50 | 1.0 | 31.1 | 5.2 | 193 | 22.9 | | | 56.1 |
| 4 | | 100 | 11 | 8 | | 50 | 2.0 | 37.5 | 5.2 | 270 | 24.3 | | | 63.5 |
| 5 | | | | | | | | | | | | | | |
| 6 | | | | | | | | | | | | | | |
| 7 | | | | | | | | | | | | | | |
| 8 | | | | | | | | | | | | | | |
| 1+4 | 100 | 100 | | 8 | | | 2.0 | | | | | | 70.0 | 63.8 |

Standard: IEC 60076-10
Test Date 16/08/2021
Test Engineer Kamil Maliński

Issue Date
29/09/2021

Test Engineer
Kamil Maliński


Test Department
Test Field

RECEIVED 29/08/2024

Sound Level

Serial No. : 1ZP4.001134582

| Prescribed Contours | | | | |
|---------------------|-----------------------------|-------------|-------------------|--------------------------|
| x Distance | l_m Prescribed contour | h Height | S Surface area | L_s Surface measure |
| [m] | [m] | [m] | [m ²] | [dB] |
| 1 | 31.1 | 5.2 | 192.82 | 22.9 |
| 2 | 37.5 | 5.2 | 270 | 24.3 |



Issue Date
29/09/2021

Test Engineer
Kamil Maliński

Test Department
Test Field



TEST REPORT

Report No.:
2021/0141/031
Page 14 of 68

RECEIVED 29/08/2024

Sound Level

Serial No. : 1ZPL001134582

| Measurement 1 | | | | | | | | | | | | | | |
|---------------|-----------------|---------------|-----------------|--------------|-------------------|--------------------|-----------|----------|--------------------|--------|-------------------|-----------------|---------------------|-----------|
| Rated voltage | Applied voltage | Rated current | Applied current | Tap position | Fans in operation | Pumps in operation | Frequency | Distance | Prescribed contour | Height | Surface area | Surface measure | Top oil temperature | Guarantee |
| [kV] | [kV] | [A] | [A] | | | | [Hz] | [m] | [m] | [m] | [m ²] | [dB] | [°C] | [dB(A)] |
| 100 | 33 | | | 11 | 0 | | 50 | 1 | 31.1 | 5.2 | 192.8 | 22.9 | | |

Measurement duration: 85 s

| | Frequency | L_{pA0} | L_{pA0} | $L_{pA0} - L_{pA0}$ | Pressure Intensity Correction | L_{pA} | L_{WA} |
|--------------------------|-----------|-------------|-----------|---------------------|-------------------------------|----------|-------------|
| | [Hz] | [dB(A)] | [dB(A)] | [dB(A)] | | [dB(A)] | [dB(A)] |
| Total Sound Level | | 54.0 | 1 | 57.3 | 3.3 | A | 54.0 |
| Octave Band | 63 | 15.5 | 1 | 23.3 | 7.8 | A | 16.8 |
| | 125 | 36.6 | 1 | 39.9 | 3.2 | A | 36.6 |
| | 250 | 53.3 | 1 | 56.2 | 2.9 | A | 53.3 |
| | 500 | 44.5 | 1 | 47.5 | 3.0 | A | 44.5 |
| | 1000 | 33.4 | 1 | 40.3 | 6.8 | A | 33.4 |
| | 2000 | 28.8 | 1 | 40.1 | 11.3 | A | 28.8 |
| | 4000 | 31.3 | 1 | 40.8 | 9.5 | A | 31.3 |
| 1/3 Octave Band | 8000 | 34.6 | 1 | 43.3 | 8.7 | A | 34.6 |
| | 50 | 13.3 | 1 | 13.5 | 0.3 | A | 13.3 |
| | 63 | 14.2 | 1 | 16.0 | 1.8 | A | 14.2 |
| | 80 | 10.9 | -1 | 21.8 | 10.9 | A | 0.0 |
| | 100 | 35.6 | 1 | 37.5 | 1.9 | A | 35.6 |
| | 125 | 24.6 | 1 | 34.3 | 9.6 | A | 24.6 |
| | 160 | 28.4 | 1 | 31.6 | 3.2 | A | 28.4 |
| | 200 | 40.3 | 1 | 43.4 | 3.1 | A | 40.3 |
| | 250 | 38.0 | 1 | 41.2 | 3.1 | A | 38.0 |
| | 315 | 52.9 | 1 | 55.8 | 2.9 | A | 52.9 |
| | 400 | 38.4 | 1 | 41.1 | 2.7 | A | 38.4 |
| | 500 | 40.8 | 1 | 43.9 | 3.1 | A | 40.8 |
| | 630 | 39.6 | 1 | 42.7 | 3.1 | A | 39.6 |
| | 800 | 30.9 | 1 | 36.3 | 5.4 | A | 30.9 |
| | 1000 | 28.6 | 1 | 35.3 | 6.7 | A | 28.6 |
| | 1250 | 24.3 | 1 | 34.8 | 10.5 | A | 24.3 |
| | 1600 | 24.1 | 1 | 35.3 | 11.2 | A | 24.1 |
| | 2000 | 23.8 | 1 | 35.5 | 11.7 | A | 23.8 |
| 2500 | 24.1 | 1 | 35.1 | 11.0 | A | 24.1 | |
| 3150 | 25.6 | 1 | 35.9 | 10.4 | A | 25.6 | |
| 4000 | 26.7 | 1 | 36.1 | 9.3 | A | 26.7 | |
| 5000 | 27.1 | 1 | 36.1 | 9.0 | A | 27.1 | |
| 6300 | 28.4 | 1 | 37.5 | 9.2 | A | 28.4 | |
| 8000 | 30.1 | 1 | 39.1 | 9.1 | A | 30.1 | |
| 10000 | 30.7 | 1 | 38.9 | 8.1 | A | 30.7 | |

Case A: Applies, if the total P-I index is $\Delta L \leq 4$ dB. Then it follows $L_{pA} = L_{pA0}$ for both the total sound level and sound levels of the individual frequency bands.

Case B: Applies, if the total P-I index is $4 \text{ dB} < \Delta L \leq 8$ dB. Then it follows $L_{pA} = L_{pA0} - 4$ dB for both the total sound level and sound levels of the individual frequency bands.

Issue Date
29/09/2021

Test Engineer
Kamil Maliński

Test Department
Test Field




TEST REPORT

Report No.:
2021/0141/031
Page 15 of 68

RECEIVED 29/08/2024

Sound Level

Serial No. : 1ZPL001134582



Issue Date
29/09/2021

Test Engineer
Kamil Maliński

Test Department
Test Field



TEST REPORT

Report No.:
2021/0141/031
Page 16 of 68

RECEIVED 29/08/2024

Sound Level

Serial No. : 1ZPL001134582

| Measurement 2 | | | | | | | | | | | | | | |
|---------------|-----------------|---------------|-----------------|--------------|-------------------|--------------------|-----------|----------|--------------------|--------|-------------------|-----------------|---------------------|-----------|
| Rated voltage | Applied voltage | Rated current | Applied current | Tap position | Fans in operation | Pumps in operation | Frequency | Distance | Prescribed contour | Height | Surface area | Surface measure | Top oil temperature | Guarantee |
| [%] | [kV] | [%] | [A] | | | | [Hz] | [m] | [m] | [m] | [m ²] | [dB] | [°C] | [dB(A)] |
| 100 | 33 | | | 11 | 8 | | 50 | 2 | 37.5 | 5.2 | 270.0 | 24.3 | | |

Measurement duration: 95 s

| | Frequency | L _{1A0} | | L _{1pA0} | L _{1pA0} - L _{1A0} | Pressure Intensity Correction | L _{1A} | L _{1WA} |
|--------------------------|-----------|------------------|------|-------------------|--------------------------------------|-------------------------------|-----------------|------------------|
| | [Hz] | [dB(A)] | | [dB(A)] | [dB(A)] | | [dB(A)] | [dB(A)] |
| Total Sound Level | | 63.4 | 1 | 65.6 | 2.2 | A | 63.4 | 87.7 |
| Octave Band | 63 | 33.4 | 1 | 34.1 | 0.7 | A | 33.4 | 57.8 |
| | 125 | 47.7 | 1 | 49.2 | 1.5 | A | 47.7 | 72.0 |
| | 250 | 58.5 | 1 | 60.3 | 1.9 | A | 58.5 | 82.8 |
| | 500 | 58.5 | 1 | 60.7 | 2.2 | A | 58.5 | 82.8 |
| | 1000 | 57.2 | 1 | 59.6 | 2.4 | A | 57.2 | 81.5 |
| | 2000 | 50.6 | 1 | 53.3 | 2.6 | A | 50.6 | 74.9 |
| | 4000 | 46.7 | 1 | 49.8 | 3.0 | A | 46.7 | 71.0 |
| 8000 | 41.6 | 1 | 46.1 | 4.6 | A | 41.6 | 65.9 | |
| 1/3 Octave Band | 50 | 26.8 | 1 | 27.3 | 0.5 | A | 26.8 | 51.1 |
| | 63 | 24.0 | 1 | 23.6 | -0.4 | A | 24.0 | 48.3 |
| | 80 | 31.7 | 1 | 32.6 | 0.9 | A | 31.7 | 56.0 |
| | 100 | 39.9 | 1 | 41.4 | 1.5 | A | 39.9 | 64.2 |
| | 125 | 43.6 | 1 | 45.0 | 1.4 | A | 43.6 | 67.9 |
| | 160 | 44.2 | 1 | 45.7 | 1.5 | A | 44.2 | 68.5 |
| | 200 | 49.2 | 1 | 50.9 | 1.7 | A | 49.2 | 73.5 |
| | 250 | 52.1 | 1 | 53.7 | 1.6 | A | 52.1 | 76.4 |
| | 315 | 56.6 | 1 | 58.6 | 2.0 | A | 56.6 | 80.9 |
| | 400 | 52.8 | 1 | 55.1 | 2.2 | A | 52.8 | 77.2 |
| | 500 | 52.8 | 1 | 55.1 | 2.3 | A | 52.8 | 77.1 |
| | 630 | 55.1 | 1 | 57.2 | 2.2 | A | 55.1 | 79.4 |
| | 800 | 54.1 | 1 | 56.5 | 2.4 | A | 54.1 | 78.4 |
| | 1000 | 52.1 | 1 | 54.5 | 2.3 | A | 52.1 | 76.5 |
| | 1250 | 50.0 | 1 | 52.5 | 2.6 | A | 50.0 | 74.3 |
| | 1600 | 47.7 | 1 | 50.3 | 2.6 | A | 47.7 | 72.0 |
| | 2000 | 45.3 | 1 | 48.0 | 2.7 | A | 45.3 | 69.6 |
| | 2500 | 43.6 | 1 | 46.3 | 2.7 | A | 43.6 | 67.9 |
| | 3150 | 42.7 | 1 | 45.6 | 2.9 | A | 42.7 | 67.0 |
| 4000 | 42.3 | 1 | 45.4 | 3.1 | A | 42.3 | 66.6 | |
| 5000 | 40.6 | 1 | 43.7 | 3.1 | A | 40.6 | 64.9 | |
| 6300 | 37.9 | 1 | 41.9 | 4.0 | A | 37.9 | 62.2 | |
| 8000 | 36.3 | 1 | 41.1 | 4.8 | A | 36.3 | 60.6 | |
| 10000 | 35.9 | 1 | 41.0 | 5.1 | A | 35.9 | 60.3 | |

Case A: Applies, if the total P-I index is $\Delta L \leq 4$ dB. Then it follows $L_{1A} = L_{1A0}$ for both the total sound level and sound levels of the individual frequency bands.

Case B: Applies, if the total P-I index is $4 \text{ dB} < \Delta L \leq 8$ dB. Then it follows $L_{1A} = L_{1A0} - 4$ dB for both the total sound level and sound levels of the individual frequency bands.

Issue Date
29/09/2021

Test Engineer
Kamil Maliński



Test Department
Test Field

RECEIVED 29/08/2024

Sound Level

Serial No. : 1ZPL001134582

Measurement 2





TEST REPORT

Report No.:
2021/0141/031
Page 18 of 68

RECEIVED 29/08/2024

Sound Level

Serial No. : 1ZPL001134582

| Measurement 3 | | | | | | | | | | | | | | |
|---------------|-----------------|---------------|-----------------|--------------|-------------------|--------------------|-----------|----------|--------------------|--------|-------------------|-----------------|---------------------|-----------|
| Rated voltage | Applied voltage | Rated current | Applied current | Tap position | Fans in operation | Pumps in operation | Frequency | Distance | Prescribed contour | Height | Surface area | Surface measure | Top oil temperature | Guarantee |
| [kV] | [kV] | [A] | [A] | | | | [Hz] | [m] | [m] | [m] | [m ²] | [dB] | [°C] | [dB(A)] |
| | | 100 | 262.43 | 11 | 0 | | 50 | 1 | 31.1 | 5.2 | 192.8 | 22.9 | | |

Measurement duration: 85 s

| | Frequency | L_{WA} | L_{pAD} | $L_{pAD} - L_{WA}$ | Pressure Intensity Correction | L_{IA} | L_{WA} |
|--------------------------|-----------|-------------|-----------|--------------------|-------------------------------|----------|-------------|
| | [Hz] | [dB(A)] | [dB(A)] | [dB(A)] | | [dB(A)] | [dB(A)] |
| Total Sound Level | | 56.1 | 1 | 58.1 | 2.1 | A | 56.1 |
| Octave Band | 63 | 40.3 | 1 | 46.7 | 6.4 | A | 40.3 |
| | 125 | 55.0 | 1 | 56.5 | 1.5 | A | 55.0 |
| | 250 | 47.0 | 1 | 49.4 | 2.4 | A | 47.0 |
| | 500 | 39.9 | 1 | 43.3 | 3.4 | A | 39.9 |
| | 1000 | 37.9 | 1 | 42.2 | 4.3 | A | 37.9 |
| | 2000 | 39.0 | 1 | 43.1 | 4.1 | A | 39.0 |
| | 4000 | 28.6 | 1 | 38.2 | 9.6 | A | 28.6 |
| 8000 | 18.4 | 1 | 31.5 | 13.1 | A | 18.6 | |
| 1/3 Octave Band | 50 | 40.2 | 1 | 46.5 | 6.4 | A | 40.2 |
| | 63 | 24.6 | 1 | 30.1 | 5.6 | A | 24.6 |
| | 80 | 21.0 | 1 | 29.3 | 8.3 | A | 21.0 |
| | 100 | 49.0 | 1 | 51.8 | 2.8 | A | 49.0 |
| | 125 | 38.9 | 1 | 41.0 | 2.1 | A | 38.9 |
| | 160 | 53.7 | 1 | 54.6 | 0.9 | A | 53.7 |
| | 200 | 42.2 | 1 | 44.7 | 2.5 | A | 42.2 |
| | 250 | 39.7 | 1 | 42.0 | 2.3 | A | 39.7 |
| | 315 | 43.9 | 1 | 46.2 | 2.3 | A | 43.9 |
| | 400 | 37.4 | 1 | 40.5 | 3.1 | A | 37.4 |
| | 500 | 33.8 | 1 | 37.6 | 3.8 | A | 33.8 |
| | 630 | 32.4 | 1 | 36.3 | 3.8 | A | 32.4 |
| | 800 | 31.9 | 1 | 35.3 | 3.4 | A | 31.9 |
| | 1000 | 32.2 | 1 | 37.2 | 5.0 | A | 32.2 |
| | 1250 | 34.7 | 1 | 38.9 | 4.3 | A | 34.7 |
| | 1600 | 37.3 | 1 | 40.7 | 3.3 | A | 37.3 |
| | 2000 | 31.3 | 1 | 37.0 | 5.7 | A | 31.3 |
| | 2500 | 30.8 | 1 | 36.0 | 5.2 | A | 30.8 |
| | 3150 | 25.5 | 1 | 34.7 | 9.1 | A | 25.5 |
| 4000 | 24.1 | 1 | 33.6 | 9.5 | A | 24.1 | |
| 5000 | 20.2 | 1 | 31.3 | 11.1 | A | 20.2 | |
| 6300 | 17.3 | 1 | 28.7 | 11.4 | A | 17.3 | |
| 8000 | 12.5 | 1 | 26.4 | 13.9 | A | 12.5 | |
| 10000 | 2.9 | -1 | 23.9 | 21.0 | A | 0.0 | |

Case A: Applies, if the total P-I index is $\Delta L \leq 4$ dB. Then it follows $L_{IA} = L_{pAD}$ for both the total sound level and sound levels of the individual frequency bands.

Case B: Applies, if the total P-I index is $4 \text{ dB} < \Delta L \leq 8$ dB. Then it follows $L_{IA} = L_{pAD} - 4$ dB for both the total sound level and sound levels of the individual frequency bands.

Issue Date
29/09/2021

Test Engineer
Kamil Maliński



Test Department
Test Field

RECEIVED 29/08/2024

Sound Level

Serial No. : 1ZPL001134582

Measurement 3





TEST REPORT

Report No.:
2021/0141/031
Page 20 of 68

RECEIVED 29/08/2024

Sound Level

Serial No. : 1ZPL001134582

| Measurement 4 | | | | | | | | | | | | | | |
|---------------|-----------------|---------------|-----------------|--------------|-------------------|--------------------|-----------|----------|--------------------|--------|-------------------|-----------------|---------------------|-----------|
| Rated voltage | Applied voltage | Rated current | Applied current | Tap position | Fans in operation | Pumps in operation | Frequency | Distance | Prescribed contour | Height | Surface area | Surface measure | Top oil temperature | Guarantee |
| [kV] | [kV] | [A] | [A] | | | | [Hz] | [m] | [m] | [m] | [m ²] | [dB] | [°C] | [dB(A)] |
| | | 100 | 262.43 | 11 | 8 | | 50 | 2 | 37.5 | 5.2 | 270.0 | 24.3 | | |

Measurement duration: 89 s

| | Frequency | L_{pAO} | L_{pAO} | $L_{pAO} - L_{pAO}$ | Pressure Intensity Correction | L_{pA} | L_{WA} |
|--------------------------|-----------|-------------|-----------|---------------------|-------------------------------|----------|-------------|
| | [Hz] | [dB(A)] | [dB(A)] | [dB(A)] | | [dB(A)] | [dB(A)] |
| Total Sound Level | | 63.5 | 1 | 65.5 | 2.0 | A | 63.5 |
| Octave Band | 63 | 40.1 | 1 | 43.3 | 3.2 | A | 40.1 |
| | 125 | 55.3 | 1 | 56.9 | 1.6 | A | 55.3 |
| | 250 | 56.9 | 1 | 58.6 | 1.7 | A | 56.9 |
| | 500 | 58.3 | 1 | 60.4 | 2.1 | A | 58.3 |
| | 1000 | 57.4 | 1 | 59.6 | 2.2 | A | 57.4 |
| | 2000 | 51.1 | 1 | 53.5 | 2.4 | A | 51.1 |
| | 4000 | 47.0 | 1 | 49.3 | 2.3 | A | 47.0 |
| 8000 | 39.9 | 1 | 41.6 | 1.8 | A | 39.9 | |
| 1/3 Octave Band | 50 | 39.4 | 1 | 42.7 | 3.3 | A | 39.4 |
| | 63 | 23.1 | 1 | 28.0 | 4.9 | A | 23.1 |
| | 80 | 30.8 | 1 | 33.5 | 2.6 | A | 30.8 |
| | 100 | 47.6 | 1 | 50.6 | 2.9 | A | 47.6 |
| | 125 | 44.2 | 1 | 45.9 | 1.7 | A | 44.2 |
| | 160 | 54.1 | 1 | 55.3 | 1.2 | A | 54.1 |
| | 200 | 49.4 | 1 | 50.9 | 1.6 | A | 49.4 |
| | 250 | 52.1 | 1 | 53.6 | 1.6 | A | 52.1 |
| | 315 | 53.7 | 1 | 55.6 | 1.9 | A | 53.7 |
| | 400 | 52.7 | 1 | 54.8 | 2.1 | A | 52.7 |
| | 500 | 52.6 | 1 | 54.7 | 2.1 | A | 52.6 |
| | 630 | 54.9 | 1 | 56.9 | 2.1 | A | 54.9 |
| | 800 | 54.3 | 1 | 56.6 | 2.3 | A | 54.3 |
| | 1000 | 52.3 | 1 | 54.4 | 2.1 | A | 52.3 |
| | 1250 | 50.2 | 1 | 52.6 | 2.4 | A | 50.2 |
| | 1600 | 48.0 | 1 | 50.5 | 2.5 | A | 48.0 |
| | 2000 | 45.9 | 1 | 48.2 | 2.3 | A | 45.9 |
| | 2500 | 44.2 | 1 | 46.3 | 2.1 | A | 44.2 |
| | 3150 | 43.2 | 1 | 45.5 | 2.3 | A | 43.2 |
| 4000 | 42.6 | 1 | 45.0 | 2.4 | A | 42.6 | |
| 5000 | 40.5 | 1 | 42.6 | 2.1 | A | 40.5 | |
| 6300 | 37.2 | 1 | 39.4 | 2.1 | A | 37.2 | |
| 8000 | 34.5 | 1 | 35.9 | 1.4 | A | 34.5 | |
| 10000 | 32.1 | 1 | 33.0 | 0.9 | A | 32.1 | |

Case A: Applies, if the total P-I index is $\Delta L \leq 4$ dB. Then it follows $L_{pA} = L_{pAO}$ for both the total sound level and sound levels of the individual frequency bands.

Case B: Applies, if the total P-I index is $4 \text{ dB} < \Delta L \leq 8$ dB. Then it follows $L_{pA} = L_{pAO} - 4$ dB for both the total sound level and sound levels of the individual frequency bands.

Issue Date
29/09/2021

Test Engineer
Kamil Maliński



Test Department
Test Field

RECEIVED 29/08/2024

Sound Level

Serial No. : 1ZPL001134582

Measurement 4





TEST REPORT

Report No.:
2021/0141/031
Page 22 of 68

RECEIVED 29/08/2024

Sound Level

Serial No. : 1ZPL001134582

Combination of sound level measurements

| Rated voltage | Applied voltage | Rated current | Applied current | Tap position | Fans in operation | Pumps in operation |
|---------------|-----------------|---------------|-----------------|--------------|-------------------|--------------------|
| [%] | [kV] | [%] | [A] | | | |
| 100 | 33 | 100 | 262.43 | | 8 | |

| Rated voltage | Applied voltage | Rated current | Applied current | Tap position | Fans in operation | Pumps in operation |
|---------------|-----------------|---------------|-----------------|--------------|-------------------|--------------------|
| [%] | [kV] | [%] | [A] | | | |
| | | | | | | |

| Frequency | Measurement 1 Sound Power Level | Measurement 4 Sound Power Level | Combined Sound Power Level |
|-----------|---------------------------------|---------------------------------|----------------------------|
| [Hz] | [dB(A)] | [dB(A)] | [dB(A)] |
| | | | |

| Frequency | Combined Sound Power Level |
|-----------|----------------------------|
| [Hz] | [dB(A)] |
| | |

| | | | | |
|--------------------------|--|------|------|-------------|
| Total Sound Level | | 76.9 | 87.8 | 88.2 |
|--------------------------|--|------|------|-------------|

| | | | | |
|--------------------------|--|--|--|--|
| Total Sound Level | | | | |
|--------------------------|--|--|--|--|

| Octave Band | 63 | 39.6 | 64.4 | 64.4 |
|-------------|------|------|------|------|
| | 125 | 59.5 | 79.6 | 79.6 |
| | 250 | 76.1 | 81.2 | 82.3 |
| | 500 | 67.3 | 82.6 | 82.7 |
| | 1000 | 56.3 | 81.7 | 81.7 |
| | 2000 | 51.6 | 75.4 | 75.4 |
| | 4000 | 54.1 | 71.3 | 71.4 |
| | 8000 | 57.4 | 64.2 | 65.0 |

| Octave Band | 63 | | | |
|-------------|------|--|--|--|
| | 125 | | | |
| | 250 | | | |
| | 500 | | | |
| | 1000 | | | |
| | 2000 | | | |
| | 4000 | | | |
| | 8000 | | | |


| 1/3 Octave Band | 50 | 36.1 | 63.8 | 63.8 |
|-----------------|------|------|------|------|
| | 63 | 37.0 | 47.4 | 47.8 |
| | 80 | 0.0 | 55.1 | 55.1 |
| | 100 | 58.4 | 71.9 | 72.1 |
| | 125 | 47.5 | 68.5 | 68.6 |
| | 160 | 51.3 | 78.4 | 78.4 |
| | 200 | 63.1 | 73.7 | 74.1 |
| | 250 | 60.9 | 76.4 | 76.5 |
| | 315 | 75.8 | 78.0 | 80.1 |
| | 400 | 61.2 | 77.0 | 77.1 |
| | 500 | 63.7 | 76.9 | 77.1 |
| | 630 | 62.5 | 79.2 | 79.3 |
| | 800 | 53.7 | 78.6 | 78.6 |
| | 1000 | 51.4 | 76.7 | 76.7 |
| | 1250 | 47.1 | 74.5 | 74.5 |
| | 1600 | 47.0 | 72.4 | 72.4 |
| | 2000 | 46.7 | 70.2 | 70.2 |
| | 2500 | 46.9 | 68.5 | 68.5 |
| | 3150 | 48.4 | 67.5 | 67.6 |
| | 4000 | 49.6 | 66.9 | 67.0 |
| 5000 | 49.9 | 64.8 | 64.9 | |
| 6300 | 51.2 | 61.5 | 61.9 | |
| 8000 | 52.9 | 58.8 | 59.8 | |
| 10000 | 53.6 | 56.4 | 58.2 | |

| 1/3 Octave Band | 50 | | | |
|-----------------|------|--|--|--|
| | 63 | | | |
| | 80 | | | |
| | 100 | | | |
| | 125 | | | |
| | 160 | | | |
| | 200 | | | |
| | 250 | | | |
| | 315 | | | |
| | 400 | | | |
| | 500 | | | |
| | 630 | | | |
| | 800 | | | |
| | 1000 | | | |
| | 1250 | | | |
| | 1600 | | | |
| | 2000 | | | |
| | 2500 | | | |
| | 3150 | | | |
| | 4000 | | | |
| 5000 | | | | |
| 6300 | | | | |
| 8000 | | | | |
| 10000 | | | | |

Issue Date
29/09/2021

Test Engineer
Kamil Maliński

Test Department
Test Field



LEGEND

- Noise Monitoring Locations (NMLs)
- Battery Noise Assessment Locations (BNALs)
- Modelled Noise Sources
- Modelled Buildings

Noise Sensitive Receptors (NSRs)


- NSRs Represented by NML1
- NSRs Represented by NML2
- NSRs Represented by NML3
- NSRs Represented by NML4
- NSRs Represented by NML5
- NSRs Represented by NML6
- NSRs Represented by NML7

Predicted Noise Levels (dBA)

| | |
|---------|---------|
| 25 - 30 | 55 - 60 |
| 30 - 35 | 60 - 65 |
| 35 - 40 | 65 - 70 |
| 40 - 45 | 70 - 75 |
| 45 - 50 | 75 - 80 |
| 50 - 55 | 80 - 85 |

Noise contours modelled in accordance with ISO9613 Part 2:1996 at a height of 4 m and displayed on a 10 m by 10 m grid. All noise sources assumed to be operating concurrently.

All levels shown as dB LAeq(t)



| Rev. | Date | Amendment Details | Drawn | Approved |
|------|------------|-------------------|-------|----------|
| 1 | 31/07/2024 | FINAL ISSUE | AD | GC |
| 0 | 10/05/2024 | FIRST ISSUE | JCM | AD |

© OpenStreetMap (and) contributors, CC-BY-SA

This drawing should not be relied on or used in circumstances other than those for which it was originally prepared and for which TNEI Services Ltd was commissioned. TNEI Services Ltd accepts no responsibility for this drawing to any party other than the person by whom it was commissioned. Any party which breaches the provisions of this disclaimer shall indemnify TNEI Services Ltd for all loss or damage arising therefrom.

Client:


Drawing Status: FOR PLANNING

Project Title: LACKAREAGH WIND FARM, CO. CLARE

Drawing Title: FIGURE A5.1 - BESS NOISE ASSESSMENT LOCATIONS AND NOISE CONTOUR PLOT

| | | |
|-----------------|-------------------|---|
| Scale: 1:17,500 | Original Size: A3 | Spatial Reference: IRENET95 Irish Transverse Mercator |
|-----------------|-------------------|---|

Drawing Number: IE00101-015



LEGEND

- Noise Monitoring Locations (NMLs)
- Battery Noise Assessment Locations (BNALs)
- Modelled Noise Sources
- Modelled Buildings

Noise Sensitive Receptors (NSRs)

- NSRs Represented by NML1
- NSRs Represented by NML2
- NSRs Represented by NML3
- NSRs Represented by NML4
- NSRs Represented by NML5
- NSRs Represented by NML6
- NSRs Represented by NML7

Predicted Noise Levels (dBA)

| | |
|---------|---------|
| 25 - 30 | 55 - 60 |
| 30 - 35 | 60 - 65 |
| 35 - 40 | 65 - 70 |
| 40 - 45 | 70 - 75 |
| 45 - 50 | 75 - 80 |
| 50 - 55 | 80 - 85 |

Noise contours modelled in accordance with ISO9613 Part 2:1996 at a height of 4 m and displayed on a 10 m by 10 m grid. All noise sources assumed to be operating concurrently.

All levels shown as dB LAeq(t)

| Rev. | Date | Amendment Details | Drawn | Approved |
|------|------------|-------------------|-------|----------|
| 1 | 31/07/2024 | FINAL ISSUE | AD | GC |
| 0 | 10/05/2024 | FIRST ISSUE | JCM | AD |



This drawing should not be relied on or used in circumstances other than those for which it was originally prepared and for which TNEI Services Ltd was commissioned. TNEI Services Ltd accepts no responsibility for this drawing to any party other than the person by whom it was commissioned. Any party which breaches the provisions of this disclaimer shall indemnify TNEI Services Ltd for all loss or damage arising therefrom.

Client:


Drawing Status: FOR PLANNING

Project Title: LACKAREAGH WIND FARM, CO. CLARE

Drawing Title: FIGURE A5.2a - BESS NOISE SENSITIVE RECEPTORS AND NOISE CONTOUR PLOT

| | | |
|-----------------|-------------------|---|
| Scale: 1:25,000 | Original Size: A3 | Spatial Reference: IRENET95 Irish Transverse Mercator |
|-----------------|-------------------|---|

Drawing Number: IE00101-016



LEGEND

- Noise Monitoring Locations (NMLs)
- Battery Noise Assessment Locations (BNALs)
- Modelled Noise Sources
- Modelled Buildings

Noise Sensitive Receptors (NSRs)

- NSRs Represented by NML1
- NSRs Represented by NML2
- NSRs Represented by NML3
- NSRs Represented by NML4
- NSRs Represented by NML5
- NSRs Represented by NML6
- NSRs Represented by NML7

Predicted Noise Levels (dBA)

| | |
|---------|---------|
| 25 - 30 | 55 - 60 |
| 30 - 35 | 60 - 65 |
| 35 - 40 | 65 - 70 |
| 40 - 45 | 70 - 75 |
| 45 - 50 | 75 - 80 |
| 50 - 55 | 80 - 85 |

Noise contours modelled in accordance with ISO9613 Part 2:1996 at a height of 4 m and displayed on a 10 m by 10 m grid. All noise sources assumed to be operating concurrently.

All levels shown as dB LAeq(t)

| Rev. | Date | Amendment Details | Drawn | Approved |
|------|------------|-------------------|-------|----------|
| 1 | 31/07/2024 | FINAL ISSUE | AD | GC |
| 0 | 10/05/2024 | FIRST ISSUE | JCM | AD |



This drawing should not be relied on or used in circumstances other than those for which it was originally prepared and for which TNEI Services Ltd was commissioned. TNEI Services Ltd accepts no responsibility for this drawing to any party other than the person by whom it was commissioned. Any party which breaches the provisions of this disclaimer shall indemnify TNEI Services Ltd for all loss or damage arising therefrom.

Client:


Drawing Status: FOR PLANNING

Project Title: LACKAREAGH WIND FARM, CO. CLARE

Drawing Title: FIGURE A5.2b - BESS NOISE SENSITIVE RECEPTORS AND NOISE CONTOUR PLOT


Scale: 1:50,000 | Original Size: A3 | Spatial Reference: IRENET95 Irish Transverse Mercator

Drawing Number: IE00101-017



LEGEND

- Noise Monitoring Locations (NMLs)
- Battery Noise Assessment Locations (BNALs)
- Modelled Noise Sources
- Modelled Buildings
- Noise Sensitive Receptors (NSRs)**
- NSRs Represented by NML1
- NSRs Represented by NML2
- NSRs Represented by NML3
- NSRs Represented by NML4
- NSRs Represented by NML5
- NSRs Represented by NML6
- NSRs Represented by NML7



Noise contours modelled in accordance with ISO9613 Part 2:1996 at a height of 4 m and displayed on a 10 m by 10 m grid. All noise sources assumed to be operating concurrently.

All levels shown as dB LAeq(t)

| Rev. | Date | Amendment Details | Drawn | Approved |
|------|------------|-------------------|-------|----------|
| 1 | 31/07/2024 | FINAL ISSUE | AD | GC |
| 0 | 10/05/2024 | FIRST ISSUE | JCM | AD |



This drawing should not be relied on or used in circumstances other than those for which it was originally prepared and for which TNEI Services Ltd was commissioned. TNEI Services Ltd accepts no responsibility for this drawing to any party other than the person by whom it was commissioned. Any party which breaches the provisions of this disclaimer shall indemnify TNEI Services Ltd for all loss or damage arising therefrom.





Client: **EDF renewables**


Drawing Status: **FOR PLANNING**

Project Title: **LACKAREAGH WIND FARM, CO. CLARE**

Drawing Title: **FIGURE A5.2b - BESS NOISE SENSITIVE RECEPTORS AND NOISE CONTOUR PLOT**

| | | |
|-----------------|-------------------|---|
| Scale: 1:60,000 | Original Size: A3 | Spatial Reference: IRENET95 Irish Transverse Mercator |
|-----------------|-------------------|---|

Drawing Number: **IE00101-007**



LEGEND

- Noise Monitoring Locations (NMLs)
- 🏠 Battery Noise Assessment Locations (BNALs)
- Modelled Noise Sources
- Modelled Buildings

Noise Sensitive Receptors (NSRs)

- NSRs Represented by NML1
- NSRs Represented by NML2
- NSRs Represented by NML3
- NSRs Represented by NML4
- NSRs Represented by NML5
- NSRs Represented by NML6
- NSRs Represented by NML7

Predicted Noise Levels (dBA)

| | |
|---------|---------|
| 25 - 30 | 55 - 60 |
| 30 - 35 | 60 - 65 |
| 35 - 40 | 65 - 70 |
| 40 - 45 | 70 - 75 |
| 45 - 50 | 75 - 80 |
| 50 - 55 | 80 - 85 |

Noise contours modelled in accordance with ISO9613 Part 2:1996 at a height of 4 m and displayed on a 10 m by 10 m grid. All noise sources assumed to be operating concurrently.

All levels shown as dB LAeq(t)

| Rev. | Date | Amendment Details | Drawn | Approved |
|------|------------|-------------------|-------|----------|
| 1 | 31/07/24 | FINAL ISSUE | AD | GC |
| 0 | 10/05/2024 | FIRST ISSUE | JCM | AD |



This drawing should not be relied on or used in circumstances other than those for which it was originally prepared and for which TNEI Services Ltd was commissioned. TNEI Services Ltd accepts no responsibility for this drawing to any party other than the person by whom it was commissioned. Any party which breaches the provisions of this disclaimer shall indemnify TNEI Services Ltd for all loss or damage arising therefrom.

Client: EDF renewables

Drawing Status: FOR PLANNING

Project Title: LACKAREAGH WIND FARM, CO. CLARE

Drawing Title: FIGURE A5.2d - BESS NOISE SENSITIVE RECEPTORS AND NOISE CONTOUR PLOT

| | | |
|-----------------|-------------------|---|
| Scale: 1:45,000 | Original Size: A3 | Spatial Reference: IRENET95 Irish Transverse Mercator |
|-----------------|-------------------|---|

Drawing Number: IE00101-019

Annex 6 – Quantitative assessments at all NSRs

RECEIVED: 29/08/2024

Table A6.1 - Noise Sensitive Receptors

| Noise Assessment Location | Coordinates | | Daytime | | | Night-time | | |
|---------------------------|-------------|--------|-------------------|--|------------|-------------------|--|------------|
| | ITM X | ITM Y | Rating Level, dBA | Representative Background Sound Level, dBA | Margin, dB | Rating Level, dBA | Representative Background Sound Level, dBA | Margin, dB |
| NSR1 (Derelict) | 561661 | 673439 | - | - | - | - | - | - |
| NSR2 (BNAL02) | 564701 | 673085 | 19 | 33 | -14 | 19 | 25 | -6 |
| NSR3 | 562657 | 672616 | 26 | 32 | -6 | 26 | 25 | 1 |
| NSR4 | 562790 | 672824 | 28 | 32 | -4 | 28 | 25 | 3 |
| NSR5 | 562676 | 671693 | 23 | 33 | -10 | 23 | 28 | -5 |
| NSR6 | 562680 | 672705 | 27 | 32 | -5 | 27 | 25 | 2 |
| NSR7 (BNAL03) | 564757 | 672486 | 15 | 31 | -16 | 15 | 24 | -9 |
| NSR8 (BNAL06) | 562222 | 672808 | 24 | 32 | -8 | 24 | 25 | -1 |
| NSR9 | 564794 | 673117 | 19 | 33 | -14 | 19 | 25 | -6 |
| NSR10 (BNAL01) | 564716 | 673715 | 10 | 30 | -20 | 10 | 23 | -13 |
| NSR11 | 562590 | 671808 | 23 | 33 | -10 | 23 | 28 | -5 |
| NSR12 | 564761 | 672966 | 23 | 33 | -10 | 23 | 25 | -2 |
| NSR13 | 561633 | 673083 | 21 | 33 | -12 | 21 | 29 | -8 |
| NSR14 | 562647 | 672798 | 26 | 32 | -6 | 26 | 25 | 1 |
| NSR15 | 562010 | 672778 | 23 | 32 | -9 | 23 | 25 | -2 |
| NSR16 | 562529 | 671794 | 23 | 33 | -10 | 23 | 28 | -5 |
| NSR17 | 561998 | 672751 | 23 | 32 | -9 | 23 | 25 | -2 |
| NSR18 | 561803 | 672813 | 22 | 32 | -10 | 22 | 25 | -3 |
| NSR19 | 561838 | 672785 | 22 | 32 | -10 | 22 | 25 | -3 |
| NSR20 | 562089 | 672686 | 22 | 32 | -10 | 22 | 25 | -3 |
| NSR21 | 561579 | 672964 | 21 | 33 | -12 | 21 | 29 | -8 |
| NSR22 | 562059 | 672671 | 22 | 32 | -10 | 22 | 25 | -3 |
| NSR23 | 561980 | 672693 | 22 | 32 | -10 | 22 | 25 | -3 |
| NSR24 | 561947 | 672696 | 22 | 32 | -10 | 22 | 25 | -3 |
| NSR25 | 561853 | 672723 | 22 | 32 | -10 | 22 | 25 | -3 |
| NSR26 | 561968 | 672666 | 22 | 32 | -10 | 22 | 25 | -3 |
| NSR27 | 561942 | 672666 | 22 | 32 | -10 | 22 | 25 | -3 |
| NSR28 | 562416 | 671818 | 23 | 33 | -10 | 23 | 28 | -5 |
| NSR29 | 562038 | 672619 | 22 | 32 | -10 | 22 | 25 | -3 |
| NSR30 | 562002 | 672616 | 22 | 32 | -10 | 22 | 25 | -3 |
| NSR31 | 561489 | 672953 | 21 | 33 | -12 | 21 | 29 | -8 |
| NSR32 | 562066 | 672595 | 22 | 32 | -10 | 22 | 25 | -3 |
| NSR33 | 562004 | 672602 | 22 | 32 | -10 | 22 | 25 | -3 |
| NSR34 (BNAL05) | 562272 | 672216 | 23 | 33 | -10 | 23 | 28 | -5 |
| NSR35 | 562075 | 672553 | 22 | 32 | -10 | 22 | 25 | -3 |
| NSR36 | 561435 | 672956 | 21 | 33 | -12 | 21 | 29 | -8 |
| NSR37 | 561954 | 672579 | 22 | 32 | -10 | 22 | 25 | -3 |
| NSR38 | 562291 | 672007 | 24 | 33 | -9 | 24 | 28 | -4 |
| NSR39 | 562385 | 671518 | 22 | 33 | -11 | 22 | 28 | -6 |
| NSR40 | 561933 | 672538 | 22 | 32 | -10 | 22 | 25 | -3 |
| NSR41 | 561389 | 672923 | 20 | 33 | -13 | 20 | 29 | -9 |
| NSR42 | 562360 | 671406 | 22 | 33 | -11 | 22 | 28 | -6 |
| NSR43 | 561896 | 672506 | 22 | 32 | -10 | 22 | 25 | -3 |
| NSR44 | 565161 | 673542 | 21 | 30 | -9 | 21 | 23 | -2 |
| NSR45 | 561867 | 672492 | 21 | 32 | -11 | 21 | 25 | -4 |
| NSR46 (BNAL07) | 561052 | 673780 | 18 | 33 | -15 | 18 | 29 | -11 |
| NSR47 | 565115 | 673731 | 17 | 30 | -13 | 17 | 23 | -6 |
| NSR48 | 562221 | 671777 | 23 | 33 | -10 | 23 | 28 | -5 |
| NSR49 | 562345 | 671342 | 21 | 33 | -12 | 21 | 28 | -7 |
| NSR50 | 561842 | 672467 | 21 | 32 | -11 | 21 | 25 | -4 |
| NSR51 | 561010 | 673785 | 18 | 33 | -15 | 18 | 29 | -11 |
| NSR52 | 561806 | 672456 | 21 | 32 | -11 | 21 | 25 | -4 |
| NSR53 | 561626 | 672516 | 21 | 32 | -11 | 21 | 25 | -4 |
| NSR54 | 561644 | 672378 | 21 | 32 | -11 | 21 | 25 | -4 |
| NSR55 | 562400 | 670949 | 21 | 33 | -12 | 21 | 28 | -7 |
| NSR56 | 565364 | 672522 | 20 | 31 | -11 | 20 | 24 | -4 |
| NSR57 | 561531 | 672385 | 20 | 32 | -12 | 20 | 25 | -5 |
| NSR58 | 560905 | 673232 | 16 | 33 | -17 | 16 | 29 | -13 |
| NSR59 | 561587 | 672347 | 21 | 32 | -11 | 21 | 25 | -4 |
| NSR60 | 561441 | 672436 | 20 | 32 | -12 | 20 | 25 | -5 |
| NSR61 | 565472 | 673141 | 23 | 33 | -10 | 23 | 25 | -2 |
| NSR62 | 565485 | 672351 | 19 | 31 | -12 | 19 | 24 | -5 |
| NSR63 | 565515 | 672347 | 19 | 31 | -12 | 19 | 24 | -5 |
| NSR64 | 560877 | 672991 | 18 | 33 | -15 | 18 | 29 | -11 |
| NSR65 (BNAL04) | 565466 | 671964 | 14 | 33 | -19 | 14 | 22 | -8 |
| NSR66 | 565549 | 673074 | 22 | 33 | -11 | 22 | 25 | -3 |
| NSR67 | 565560 | 672326 | 19 | 31 | -12 | 19 | 24 | -5 |
| NSR68 | 560794 | 673038 | 18 | 33 | -15 | 18 | 29 | -11 |
| NSR69 | 560656 | 673588 | 17 | 33 | -16 | 17 | 29 | -12 |

| Noise Assessment Location | Coordinates | | Daytime | | | Night-time | | |
|---------------------------|-------------|--------|-------------------|--|------------|-------------------|--|------------|
| | ITM X | ITM Y | Rating Level, dBA | Representative Background Sound Level, dBA | Margin, dB | Rating Level, dBA | Representative Background Sound Level, dBA | Margin, dB |
| NSR70 | 565513 | 671844 | 14 | 33 | -19 | 14 | 22 | -8 |
| NSR71 | 560762 | 673013 | 18 | 33 | -15 | 18 | 29 | -11 |
| NSR72 | 562292 | 670677 | 20 | 33 | -13 | 20 | 28 | -8 |
| NSR73 | 565643 | 672341 | 20 | 31 | -11 | 20 | 24 | -4 |
| NSR74 | 560724 | 672996 | 17 | 33 | -16 | 17 | 29 | -12 |
| NSR75 | 562397 | 670509 | 20 | 33 | -13 | 20 | 28 | -8 |
| NSR76 | 562285 | 670594 | 20 | 33 | -13 | 20 | 28 | -8 |
| NSR77 | 560484 | 674120 | 15 | 33 | -18 | 15 | 29 | -14 |
| NSR78 | 560471 | 674182 | 15 | 33 | -18 | 15 | 29 | -14 |
| NSR79 | 561810 | 671127 | 20 | 33 | -13 | 20 | 28 | -8 |
| NSR80 | 565714 | 672811 | 22 | 33 | -11 | 22 | 25 | -3 |
| NSR81 | 562316 | 670473 | 19 | 33 | -14 | 19 | 28 | -9 |
| NSR82 | 561860 | 670924 | 19 | 33 | -14 | 19 | 28 | -9 |
| NSR83 | 562313 | 670419 | 19 | 33 | -14 | 19 | 28 | -9 |
| NSR84 | 565817 | 672355 | 21 | 31 | -10 | 21 | 24 | -3 |
| NSR85 | 562110 | 670555 | 19 | 33 | -14 | 19 | 28 | -9 |
| NSR86 | 562272 | 670414 | 19 | 33 | -14 | 19 | 28 | -9 |
| NSR87 | 565484 | 671230 | 9 | 33 | -24 | 9 | 22 | -13 |
| NSR88 | 562199 | 670304 | 19 | 33 | -14 | 19 | 28 | -9 |
| NSR89 | 561527 | 671204 | 20 | 33 | -13 | 20 | 28 | -8 |
| NSR90 | 560306 | 673295 | 16 | 33 | -17 | 16 | 29 | -13 |
| NSR91 | 565995 | 672317 | 20 | 31 | -11 | 20 | 24 | -4 |
| NSR92 | 562187 | 670277 | 18 | 33 | -15 | 18 | 28 | -10 |
| NSR93 | 560370 | 672954 | 16 | 33 | -17 | 16 | 29 | -13 |
| NSR94 | 566011 | 672201 | 20 | 31 | -11 | 20 | 24 | -4 |
| NSR95 | 560305 | 673039 | 16 | 33 | -17 | 16 | 29 | -13 |
| NSR96 | 561659 | 670701 | 19 | 33 | -14 | 19 | 28 | -9 |
| NSR97 | 560835 | 672028 | 18 | 33 | -15 | 18 | 28 | -10 |
| NSR98 | 561295 | 671537 | 21 | 33 | -12 | 21 | 28 | -7 |
| NSR99 | 566125 | 672239 | 19 | 31 | -12 | 19 | 24 | -5 |
| NSR100 | 565241 | 670627 | 7 | 33 | -26 | 7 | 22 | -15 |
| NSR101 | 561025 | 671794 | 19 | 33 | -14 | 19 | 28 | -9 |
| NSR102 | 566216 | 672164 | 19 | 31 | -12 | 19 | 24 | -5 |
| NSR103 | 561864 | 670256 | 18 | 33 | -15 | 18 | 28 | -10 |
| NSR104 | 561160 | 671571 | 19 | 33 | -14 | 19 | 28 | -9 |
| NSR105 | 562916 | 669671 | 17 | 33 | -16 | 17 | 28 | -11 |
| NSR106 | 566252 | 672219 | 19 | 31 | -12 | 19 | 24 | -5 |
| NSR107 | 566271 | 672276 | 19 | 31 | -12 | 19 | 24 | -5 |
| NSR108 (Derelict) | 566327 | 672213 | - | - | - | - | - | - |
| NSR109 | 559925 | 673283 | 15 | 33 | -18 | 15 | 29 | -14 |
| NSR110 | 562081 | 669846 | 17 | 33 | -16 | 17 | 28 | -11 |
| NSR111 | 561874 | 669960 | 17 | 33 | -16 | 17 | 28 | -11 |
| NSR112 | 563014 | 669430 | 16 | 33 | -17 | 16 | 28 | -12 |
| NSR113 | 560947 | 671461 | 18 | 33 | -15 | 18 | 28 | -10 |
| NSR114 | 565577 | 670435 | 9 | 33 | -24 | 9 | 22 | -13 |
| NSR115 | 562065 | 669758 | 17 | 33 | -16 | 17 | 28 | -11 |
| NSR116 | 566511 | 672054 | 17 | 31 | -14 | 17 | 24 | -7 |
| NSR117 | 559688 | 673607 | 14 | 33 | -19 | 14 | 29 | -15 |
| NSR118 | 559797 | 673004 | 14 | 33 | -19 | 14 | 29 | -15 |
| NSR119 | 559657 | 673640 | 14 | 33 | -19 | 14 | 29 | -15 |
| NSR120 | 561856 | 669813 | 16 | 33 | -17 | 16 | 28 | -12 |
| NSR121 | 559749 | 673009 | 14 | 33 | -19 | 14 | 29 | -15 |
| NSR122 | 561914 | 669731 | 16 | 33 | -17 | 16 | 28 | -12 |
| NSR123 | 565833 | 670493 | 11 | 33 | -22 | 11 | 22 | -11 |
| NSR124 | 565533 | 670225 | 8 | 33 | -25 | 8 | 22 | -14 |
| NSR125 | 563141 | 669238 | 13 | 33 | -20 | 13 | 28 | -15 |
| NSR126 | 564758 | 669592 | 11 | 33 | -22 | 11 | 22 | -11 |
| NSR127 | 564899 | 669681 | 10 | 33 | -23 | 10 | 22 | -12 |
| NSR128 | 566629 | 671963 | 17 | 31 | -14 | 17 | 24 | -7 |
| NSR129 | 565519 | 670158 | 9 | 33 | -24 | 9 | 22 | -13 |
| NSR130 | 563209 | 669187 | 12 | 33 | -21 | 12 | 28 | -16 |
| NSR131 | 566028 | 670519 | 13 | 33 | -20 | 13 | 22 | -9 |
| NSR132 | 564827 | 669502 | 11 | 33 | -22 | 11 | 22 | -11 |
| NSR133 | 563170 | 669116 | 12 | 33 | -21 | 12 | 28 | -16 |
| NSR134 | 559555 | 673025 | 14 | 33 | -19 | 14 | 29 | -15 |
| NSR135 | 565020 | 669608 | 10 | 33 | -23 | 10 | 22 | -12 |
| NSR136 | 565456 | 669970 | 10 | 33 | -23 | 10 | 22 | -12 |
| NSR137 | 559405 | 674249 | 12 | 33 | -21 | 12 | 29 | -17 |
| NSR138 | 564914 | 669501 | 10 | 33 | -23 | 10 | 22 | -12 |
| NSR139 | 566086 | 670481 | 14 | 33 | -19 | 14 | 22 | -8 |

| Noise Assessment Location | Coordinates | | Daytime | | | Night-time | | |
|---------------------------|-------------|--------|-------------------|--|------------|-------------------|--|------------|
| | ITM X | ITM Y | Rating Level, dBA | Representative Background Sound Level, dBA | Margin, dB | Rating Level, dBA | Representative Background Sound Level, dBA | Margin, dB |
| NSR140 | 564552 | 669302 | 13 | 33 | -20 | 13 | 22 | -9 |
| NSR141 | 564642 | 669335 | 13 | 33 | -20 | 13 | 22 | -9 |
| NSR142 | 563343 | 669044 | 10 | 33 | -23 | 10 | 28 | -18 |
| NSR143 | 564711 | 669345 | 13 | 33 | -20 | 13 | 22 | -9 |
| NSR144 | 566826 | 671987 | 16 | 31 | -15 | 16 | 24 | -8 |
| NSR145 | 563595 | 669001 | 9 | 33 | -24 | 9 | 28 | -19 |
| NSR146 | 564726 | 669301 | 13 | 33 | -20 | 13 | 22 | -9 |
| NSR147 | 566871 | 671989 | 16 | 31 | -15 | 16 | 24 | -8 |
| NSR148 | 561961 | 669350 | 15 | 33 | -18 | 15 | 28 | -13 |
| NSR149 | 564703 | 669272 | 13 | 33 | -20 | 13 | 22 | -9 |
| NSR150 | 559670 | 672291 | 14 | 33 | -19 | 14 | 28 | -14 |
| NSR151 | 566883 | 671979 | 16 | 31 | -15 | 16 | 24 | -8 |
| NSR152 | 561828 | 669418 | 15 | 33 | -18 | 15 | 28 | -13 |
| NSR153 | 566882 | 671887 | 16 | 31 | -15 | 16 | 24 | -8 |
| NSR154 | 559994 | 671744 | 15 | 33 | -18 | 15 | 28 | -13 |
| NSR155 | 566141 | 670341 | 13 | 33 | -20 | 13 | 22 | -9 |
| NSR156 | 559413 | 672841 | 13 | 33 | -20 | 13 | 29 | -16 |
| NSR157 | 566945 | 671972 | 12 | 31 | -19 | 12 | 24 | -12 |
| NSR158 | 565203 | 669501 | 11 | 33 | -22 | 11 | 22 | -11 |
| NSR159 | 566938 | 671893 | 12 | 31 | -19 | 12 | 24 | -12 |
| NSR160 | 564692 | 669181 | 13 | 33 | -20 | 13 | 22 | -9 |