



PALISADE FENCING DETAILS - SECTION

SCALE 1:20

50 x 50 x 5mm Angle Rails Connected to Posts using Angle Bracket System with M12 x 30mm Cup Square Coachbolt with

Pales Welded with 3mm Fillet / Weld to 50 x 50 x 5mm Angle

50mm Square Lug Earthwire Connected to Existing Earth Grid

Surface Finish to Match Existing





Head Office Beenreigh, Abbeydorney, Tralee, Co. Kerry Ireland Tel: 00353 66 7135710

Regional Office Basepoint Business Centre Stroudley Road, Basingstoke, Hampshire, RG24 8UP, UK Tel: 00 44 1256406664

PROJECT

Scart Mountain WF 110 kV Grid Connection

CLIENT



CONSULTANTS



NOTES: -

- This drawing is to be read in conjuction with relevant
- drawings, specifications and reports • Dimensions are in millimetres, unless noted otherwise
- Drawings are not to be scaled use figured dimensions only

LEGEND: -

ISSUE/REVISION

P1	09.11.2023	Issued for Planning
I/R	DATE	DESCRIPTION

PROJECT NUMBER

05-854

SHEET TITLE

Wind Farm Substation Gate and Fencing Details

SHEET NUMBER

05854-DR-236