

© COPYRIGHT OF THIS DRAWING IS RESERVED BY DBFL CONSULTING ENGINEERS. NO PART SHALL BE REPRODUCED OR TRANSMITTED WITHOUT THEIR WRITTEN PERMISSION.



NO CHANGES OF WHATSOEVER NATURE ARE TO BE MADE TO ANY DETAILS SET OUT OR CONTAINED IN ANY DBFL SPECIFICATIONS OR DRAWINGS, UNLESS THE EXPRESS CONSENT HAS BEEN OBTAINED IN ADVANCE, IN WRITING, FROM DBFL.

NOTES

- CLOSE GRADED SURFACE COURSE MACADAM SHALL COMPLY WITH THE REQUIREMENTS OF CLAUSE 912 OF THE MRA. SPECIFICATION FOR ROAD WORKS AND SHALL SATISFY THE REQUIREMENTS OF TABLE B2. IT SHALL BE LAD & COMPACTED IN ACCORDANCE WITH CLAUSE 901 & CLAUSE 702.
- DENSE BITUMEN MACADAM BINDER COURSE SHALL COMPLY WITH THE REQUIREMENTS OF CLAUSE 906 OF THE MRA'S SPECIFICATION FOR ROAD WORKS & SHALL SATISFY THE REQUIREMENTS OF TABLE B1. IT SHALL BE LAD & COMPACTED IN ACCORDANCE WITH CLAUSE 901 & CLAUSE 702.
- SUB-BASE MATERIAL SHALL COMPLY WITH CLAUSE 908. GRANULAR MATERIAL TYPE B OF MRA'S SPECIFICATION FOR ROAD WORKS (SRW) & SHALL SATISFY THE REQUIREMENTS OF TABLE B4 & B2.
- SUB FORMATION & CAPPING MATERIAL SHALL COMPLY WITH CLAUSE 913 OF THE MRA'S SPECIFICATION FOR ROAD WORKS & SHALL SATISFY THE REQUIREMENTS OF TABLE B1 & B2.
- STONE BLINDING WITH 26.3mm AGGREGATE SHALL MEET THE FOLLOWING CRITERIA, IN ACCORDANCE WITH IS EN 12620.

BS SIEVE SIZE (mm) BY MASS PASSING	
14	100
10	88-100
6.3	80-99
2.0	5-20
0.5	0-5
- CRUSHED STONE WITH 4.25mm AGGREGATE SHALL MEET THE FOLLOWING CRITERIA, IN ACCORDANCE WITH IS EN 12620.

BS SIEVE SIZE (mm) BY MASS PASSING	
40	100
21.5	88-100
20	80-99
10	25-70
4	0-15
0	0-5
- ANY ROADS PROPOSED TO BE USED FOR CONSTRUCTION TRAFFIC ARE TO HAVE INCREASED DEPTH OF SUB-BASE FOR THE DURATION OF CONSTRUCTION IN ACCORDANCE WITH DBFL SPECIFICATIONS.
- ALL WORKS SHALL BE COMPLETED IN ACCORDANCE WITH THE REQUIREMENTS OF THE LOCAL AUTHORITY.
- ALL GEOTEXTILES TO BE LAD IN ACCORDANCE WITH MANUFACTURERS SPECIFICATIONS.
- ALL PERMEABLE PAVING SUB-FORMATION TO BE LAD TOWARD DRAINAGE PIPEWORK.
- SUBGRADE CRB'S ARE TO BE APPROVED BY THE ENGINEER PRIOR TO COMMENCEMENT OF ROAD CONSTRUCTION.



2	22-02-20	ISSUED FOR PLANNING	JVS	DCB
1	24-02-20	DRAFT PLANNING ISSUE	JVS	DCB
0	23-12-24	DRAFT PLANNING ISSUE	JVS	DCB
rev	000	DESCRIPTION	BY	CHKD

STATUS CODES
P3 - PLANNING PERMISSION | S - ISSUED

DBFL
CONSULTING ENGINEERS
T : +353 1 400 4000 | E: info@dbfl.ie | W: www.dbfl.ie
DUBLIN | CORK | GALWAY | WATERFORD

project ref
KISHOGUE PART 10 APPLICATION

drawing title
SITE 3 - TYPICAL ROAD
CONSTRUCTION DETAILS SHEET 4

client
SDCC

designed by	author	scale	sheet size
DCB	JVS	AS NOTED	A0
drawing no.	KSG3-DBFL-95-XX-DR-C-5204		
			2