



- Notes:
- 1) Proposed lighting ducts shall be Polypipe Ridgiduct ducts and fittings.
  - 2) All proposed ducts shall incorporate a 10mmØ polypropylene pull rope and end cap.
  - 3) Handling and installation of all new ducts shall be in strict accordance with the manufacturers guidelines.
  - 4) All bends shall be as per manufacturers maximum bending radius specification.
  - 5) Proposed ducting chamber cover shall be a ductile iron cover load classification C250 in untrafficked areas and D400 in trafficked areas to IS EN 124.
  - 6) It will the contractors responsibility to coordinate the installation of all underground services. It shall be carried out in accordance with the HSA's "Code of practice for avoiding danger from underground services".
  - 7) Proposed lighting column Luminaire shall be:
    - Type 1 Roads = 8m High 250W HPS-T High Pressure Sodium Lamp
    - Type 2 Carpark = 8m High 400W HPS High Pressure Sodium Lamp
    - Type 3 Service Yards = 8m High 400W Flood Lighting High Pressure Sodium Lamp
  - 8) Reproduced from the Ordnance Survey by permission of the Government, licence No. EN 0002815.

- Legend:
- Planning Boundary
  - Proposed External Lighting Ducts
  - Proposed Ducting Chambers
  - Lighting Type 1 - Column Mounted
  - Lighting Type 1 - Wall Mounted
  - Lighting Type 2 - Column Mounted
  - Lighting Type 3 - Column Mounted
  - Lighting Type 3 - Wall Mounted

External Lighting Standards Table				
Area	Min. Ave illuminance (E <sub>av</sub> )	Min. illuminance (E <sub>min</sub> )	Uniformity (U <sub>o</sub> )	Standard
Roadway	10Lux	3Lux		BS EN 13201-2
Queuing Area	15Lux		0.40	BS EN 13201-2
Footpath	5Lux		0.25	BS EN 12464-2
Carpark	10Lux		0.25	BS EN 12464-2
Loading Bay/ Service Yards	50Lux		0.40	BS EN 12464-2

CYAL50382430 © Tailte Eireann - Surveying.

- Notes:
- 1. Topographical survey to ITM grid reference and Malin Head Ordnance Datum.
  - 2. Do not scale from this drawing.
  - 3. All dimension are in metres unless noted otherwise.

PL2	29/08/25	EG	SM	JMacC
Issued for RFI				
PL1	11/12/15	J.B.	J.B.	JMacC
Issued for Planning				
Rev	Date	By	Chkd	Appd

ARUP  
One Albert Quay  
Cork, Ireland  
Tel +353 (0)21 422 3200  
www.arup.com



Project Title  
Ringaskiddy Resource  
Recovery Centre

Drawing Title  
Proposed External Lighting  
Layout

Scale at A1 1:500	
Role	Site Infrastructure
Suitability	Response to Request for Information
Arup Job No	Rev
307174-00	PL2
Name	
C-000-041	