


LEGEND:

- Woodland Substation Planning Area
- Existing Woodland Substation Boundary
- +
 Existing Equipment
- +
 Proposed Equipment
- SW Proposed Land Drain
- Existing Surface Water Network
- Existing Surface Water Manhole
- +
 Surface Water Access Chamber
- Proposed Surface Water Manhole

NOTES ON SURFACE WATER AND SUDS:

1. Surface water attenuation & groundwater recharge via stone fill and land drain network to comply with GSDS requirement.
2. Outfall to existing drainage system to be restricted by throttle device to existing green field run-off rate.

DRAFT



NOTES:

1. FIGURED DIMENSIONS ONLY TO BE TAKEN FROM THIS DRAWING.
2. ALL LEVELS SHOWN RELATE TO ORDNANCE SURVEY DATUM AT MALIN HEAD

Rev	Date	Description	By	Chkd.
A	Jan. '14	PLANNING ISSUE	MN	DG

Client:

Project: **NORTH - SOUTH 400 kV INTERCONNECTION DEVELOPMENT**

Title: **MEATH STUDY AREA (MSA) WOODLAND 400 kV SUBSTATION SITE DRAINAGE PLAN**

Scale @ A1: **1:500**

Prepared by: M. Nolan	Checked: D. Grehan	Date: January 2014
Project Director: D. Grehan		
Planning Dwg. Ref: MT-006-005		

TOBIN
Patrick J. Tobin & Co. Ltd.

TOBIN Consulting Engineers,
Block 10-4, Blanchardstown Corporate Park,
Dublin 15, Ireland.
tel: +353-(0)1-8030406
fax: +353-(0)1-8030409
e-mail: dublin@tobin.ie
www.tobin.ie

TOBIN Consulting Engineers will not be liable for any use of this document for any purpose other than that for which it was originally prepared and approved. Except where specifically and explicitly agreed in writing by TOBIN Consulting Engineers, no copyright notice, all parts of this document may be reproduced or transmitted in any form and this document shall not be relied upon by any third party for any purpose.

Drawing No.: **6244-2056** Revision: **A**