

A = 125mm: Outer Diameter HDPE ESB Approved Duct, SDR=17.6 B= 160mm: Outer Diameter HDPE ESB Approved Duct, SDR= 21 C = 63mm: ECC Earth Continuity Conductor

Typical Section Through Off Road

Note:

- Duct and cable sizing to be confirmed as part of detailed design.
- This drawing is to be read in conjunction with relevant drawings, specifications and reports
- Dimensions are in millimeters, unless noted otherwise
- Drawings are not to be scaled use figured dimensions only
- Cable spacing to be confirmed as part of Cable Rating Study

ALL REINSTATEMENT WORKS ARE TO BE IN ACCORDANCE WITH LANDOWNERS/CARLOW Co. Co. REQUIREMENTS



Head Office Beenreigh, Abbeydorney, Tralee, Co. Kerry Ireland Tel: 00353 66 7135710 CLIENT



PROJECT

Garreenleen Solar Farm 110kV Grid Connection

PROJECT NUMBER 05-1020

SHEET NUMBER 051020-DR-104

Ducting through
Off Road Section
DRAWING STATUS
For Section 5

N1 27.09.23 Issued for Information
I/R DATE DESCRIPTION